Attachment to AECM-83/0178 Page 1 of 6

#### OPERATING DATA REPORT

DOCKET NO.	50-416
DATE	3-14-83
COMPLETED BY	J. D. Richardson
TELEPHONE	<u>601-969-2</u> 630

#### OPERATING STATUS

1	Unit Name Grand Gulf Nuclear Station	Notes	
	Reporting Period February, 1983	1	
	Licensed Thermal Power (MWt): 191		
4.	Nameplate Rating (Gross MWe): 1372.5		
5.	Design Electrical Plating (Net MWe): 1250		
6.	Maximum Dependable Capacity (Gross MWe):N/A	1 3.5.3	
7.	Maximum Dependable Capacity (Net MWe): N/A		

 If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: N/A

# 9. Power Level To Which Restricted. If Any (Net MWe): \_\_\_\_\_N/A

10. Reasons For Restrictions. If Any: As restricted by O.L. NPF-13 as listed in 3.0 above.

		This Month	Yrto-Date	Cumulative
11	Hours in Reporting Period	0	0	0
	Number Of Hours Reactor Was Critical	0	0	0
	Reactor Reserve Shutdown Hours	0	0	0
	Hours Generator On-Line	0	0	0
	Unit Reserve Shutdown Hours	0	0	0
	Gross Thermal Energy Generated (MWH)	0	0	0
	Gross Electrical Energy Generated (MWH)	0	0	0
	Net Electrical Energy Generated (MWH)	0	0	0
	Unit Service Factor	N/A	N/A	N/A
	Unit Availability Factor	N/A	N/A	N/A
	Unit Capacity Factor (Using MDC Net)	N/A	N/A	N/A
	Unit Capacity Factor (Using DER Net)	N/A	N/A	N/A
	Unit Forced Outage Rate	N/A	N/A	N/A
	source of the state	the second second second second second second second		

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup:		N/A	
	Test Status (Prior to Commercial Operation)	Forecast	Achieved
	INITIAL CRITICALITY	8/14/82	8/18/82
	INITIAL ELECTRICITY	5/83	
	COMMERCIAL OPERATION	11/83	

(9/77)

Actachment to AECM-82/0178 Page 3 of 6

- 19. UNIT SERVICE FACTOR. Compute by dividing hours the generator was on line (item 14) by the gross hours in the reporting period (item 11). Express as percent to the nearest tenth of a percent. Do not include reserve shutdown hours in the calculation.
- 20. UNIT AVAILABILITY FACTOR. Compute by dividing the unit available hours (item 14 plus item 15) by the gross hours in the reporting period (item 11). Express as percent to the nearest tenth of a percent.
- 21. UNIT CAPACITY FACTOR (USING MDC NET). Compute by dividing net electrical energy generated (item 18) by the product of maximum dependable capacity (item 7) times the gross hours in the reporting period (item 11). Express as percent to the nearest tenth of a percent.
- UNIT CAPACITY FACTOR (USING DER NET). Compute as in item 21, substituting design electrical rating (item 5) for maximum dependable capacity.
- 23. UNIT FORCED OUTAGE RATE. Compute by dividing the total forced outage hours (from the table in Unit Shutdowns and Power Reductions) by the sum of hours generator on line (item 14) plus total forced outage hours (from the table in Unit Shutdowns and Power Reductions). Express as percent to the nearest tenth of a percent.
- 24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH). Include type (refueling, maintenance, other), proposed date of start of shutdown and proposed length of shutdown. It is recognized that shutdowns may be scheduled between reports and that this item may not be all inclusive. Be as accurate as possible as of the date the report is prepared. This item is to be prepared each month and updated if appropriate until the actual shutdown occurs.
- 25. Self-explanatory.
- 26. Self-explanatory. Note, however, that this information is requested for all units in startup and power ascension test status and is not required for units already in commercial operation.

**TEST STATUS** is defined as that period following initial criticality during which the unit is tested at successively higher outputs, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the unit is generally considered by the utility to be available for commercial operation.

Date of COMMERCIAL OPERATION is defined as the date that the unit was declared by the utility owner to be available for the regular production of electricity, usually related to the satisfactory completion of qualification tests as specified in the purchase contract and to the accounting policies and practices of the utility.

Attachment to AECM-83/0178 Page 4 of 6

#### AVERAGE DASLY UNIT POWER LEVEL

DOCKET NO.	50-416
UNIT	1
DATE	3-14-83
COMPLETED BY	J. D. Richardson
TELEPHONE	601-969-2630

AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVE (Mwe-Net)
No Power Generated	17	
	19	
	20	
	21	
	22	
	23	
	24	
	25	
	25	
and the second	27	
	28	
	29	
	30	The second second
	31	

#### INSTRUCTIONS

February

MONTH .

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

COMPLETED BY February REPORT MONTH 601-969-2630 **TELEPHONE** Method of Shutting Down Reactor<sup>3</sup> Component Code<sup>5</sup> Reason 2 Duration (Hours) System Code<sup>4</sup> Cause & Corrective Typel Licensee Date No Event Action to Report # Prevent Recurrence N/A -3 4 Attachment to AECM-83/0178 Page 5 of 6 F: Forced Method: Exhibit G - Instructions Reason: S: Scheduled 1-Manual for Preparation of Data A-Equipment Failure (Explain) B-Maintenance or Test 2-Manual Scram. Entry Sheets for Licensee Event Report (LER) File (NUREG-C-Refueling 3-Automatic Scram. D-Regulatory Restriction 4-Other (Explain) 0161) E-Operator Training & Liceuse Examination  $\tilde{\gamma}$ F-Administrative Exhibit 1 - Same Source G-Operational Error (Explain) (9/77)H-Other (Explain)

#### UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. UNIT NAME DATE

## D. <u>50-416</u> E <u>Grand Gulf Nuclear</u> E <u>3-14-83</u> Y J. D. Richardson E <u>601-969-2630</u>

### INSTRUCTIONS

This report should describe all plant shutdowns during the report period. In addition, it should be the source of explanation of significant dips in average power levels. Each significant reduction in power level (greater than 20% reduction in average daily power level for the preceding 24 hours) should be noted, even though the unit may not have been shut down completely<sup>1</sup>. For such reductions in power level, the duration should be listed as zero, the method of reduction should be listed as 4 (Other), and the Cause and Corrective Action to Prevent Recurrence column should be used to provide any needed explanation to fully describe the circumstances of the outage or power reduction.

**NUMBER.** This column should indicate the sequential number assigned to each shutdown or significant reduction in power for that calendar year. When a shutdown or significant power reduction begins in one report period and ends in another, an entry should be made for both report periods to be sure all shutdowns or significant power reductions are reported. Until a unit has achieved its first power generation, no number should be assigned to each entry.

**DATE.** This column should indicate the date of the start of each shutdown or significant power reduction. Report as year, month, and day. August 14, 1977 would be reported as 770814. When a shutdown or significant power reduction begins in one report period and ends in another, an entry should be made for both report periods to be sure all shutdowns or significant power reductions are reported.

**TYPE.** Use "F" or "S" to indicate either "Forced" or "Scheduled." respectively, for each shutdown or significant power reduction. Forced shutdowns include those required to be initiated by no later than the weekend following discovery of an off-normal condition. It is recognized that some judgment is required in categorizing shutdowns in this way. In general, a forced shutdown is one that would not have been completed in the absence of the condition for which corrective action was taken.

DURATION. Self-explanatory. When a shutdown extends beyond the end of a report period, count only the time to the end of the report period and pick up the ensuing down time in the following report periods. Report duration of putages rounded to the nearest tenth of an hour to facilitate summation. The sum of the total outage hours plus the hours the generator was on line should equal the gross hours in greporting period.

**REASON**. Categorize by letter designation in accordance with the table appearing on the report form. If category H must be used, supply brief comments.

METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER. Categorize by number designation

<sup>1</sup>Note that this differs from the Edison Plectric Institute (EEI) definitions of "Forced Partial Outage" and "Scheduled Partial Outage". For these terms, EEI mass a change of 50 MW as the break point. For large power reactors 30 MW is too small a change to warrant explanation. in accordance with the table appearing on the report form. If category 4 must be used, supply brief comments.

LICENSEE EVENT REPORT #. Reference the applicable reportable occurrence pertaining to the outage or power reduction. Enter the first four pairs (event year, sequential report number, occurrence code and report type) of the five part designation as described in Item 17 c. Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161). This information may not be immediately evident for all such shutdowns, of course, since further investigation may be required to ascertain whether or not a reportable occurrence was involved.) If the outage or power reduction will not result in a reportable occurrence, the positive indication of this lack of correlation should be noted as not applicable (N/A).

SYSTEM CODE. The system in which the outage or power reduction originated should be noted by the two digit code of Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161).

Systems that do not fit any existing code should be designated XX. The code ZZ should be used for those events where a system is not applicable.

COMPONENT CODE. Select the most appropriate component from Exhibit I - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161), using the following critieria:

- A. If a component failed, use the component directly involved.
- B. If not a component failure, use the related component e.g. wrong valve operated through error: list valve as component.
- C. If a chain of failures occurs, the first component to malsumption should be listed. The sequence of events, including the other components which fail, should be described under the Cause and Corrective Action to Prevent Recurrence column.

Components that do not fit any existing code should be designated XXXXXX. The code ZZZZZZ should be used for events where a component designation is not applicable.

CAUSE & CORRECTIVE ACTION TO PREVENT RECUR-RENCE. Use the column in a narrative fashion to amplify or explain the circumstances of the shutdown or power reduction. The column should include the specific cause for each shutdown or significant power reduction and the immediate and contemplated long term corrective action taken. If appropriate. This column should also be used for a description of the major safety-related corrective maintenance performed during the outage or power reduction including an identification of the critical nath activity and a report of any single release of radioactivity or single radiation exposure specifically associated with the outage which accounts for more than 10 percent of the allowable annual values.

For long textood reports continue narrative on separate paper and references the shutdown or power reduction for this narrative