

LA SALLE - UNIT 1

TABLE 3.3.7.10-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. GAMMA SCINTILLATION MONITOR PROVIDING ALARM AND AUTOMATIC TERMINATION OF RELEASE		
a. Liquid Radwaste Effluent Line (0D18-R802)	1	100
2. GAMMA SCINTILLATION MONITORS PROVIDING ALARM BUT NOT PROVIDING AUTOMATIC TERMINATION OF RELEASE		
a. Service Water System Effluent Line (1D18-K608)	1	101
b. RHR Service Water (Line A) Effluent Line (1D18-K604)	1	101
c. RHR Service Water (Line B) Effluent Line (1D18-K605)	1	101
d. Service Water System Effluent Line (2 D18-K608)	1	101
3. FLOW RATE MEASUREMENT DEVICES		
a. Liquid Radwaste Effluent Line (OFIT-WF-017 and 018)	1	102
b. River Discharge - Blowdown Pipe (OFT-WL001)	1	102

B2092280161
PCR ADDCK 05000373
PDR
3/4 3-82
B20910