

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M A P P S I 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
8 9 14 15 25 26 30 37 44 51 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

0 1 R E P O R T S O U R C E 6 0 L 6 0 5 0 - 0 2 9 3 7 0 8 1 8 8 2 8 0 9 1 5 8 2 9
8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On 8/18/82, while conducting a plant startup from cold shutdown, the oxygen concen-
 0 3 tration and drywell to torus differential pressure was not established in 24 hours
 0 4 as required by T.S. A controlled plant shutdown was initiated per T.S. This event
 0 5 caused no threat to the public. NRC was notified via ENS.
 0 6
 0 7
 0 8

3 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
9 10 11 12 13 18 19 20
 S E (11) A (12) A (13) Z Z Z Z Z Z (14) Z (15) Z (16)

(17) LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
21 22 23 24 26 27 28 29 30 31 32
 8 2 - 0 3 2 / 0 3 L - 0

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
33 34 35 36 37 40 41 42 43 44 47
 A (18) Z (19) B (20) A (21) 0 0 0 0 (22) N (23) N (24) Z (25) Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A gasket failed on the nitrogen vaporizer due to ice buildup caused by an excessive
 1 1 flow of nitrogen. This event occurred when operators were attempting to meet the
 1 2 24 hour limits imposed by T.S. The gasket was replaced, tested and inerting started
 1 3 again. Shutdown was terminated when T.S. requirements were met. Existing operational
 1 4 procedures have been judged adequate to prevent a recurrence.
8 9 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

5 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
8 9 10 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 C (28) 0 7 0 (29) N/A A (31) Operational event

6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 Z (33) Z (34) N/A N/A

7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 0 0 0 (37) Z (38) N/A

8 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 0 0 0 (40) N/A

9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 Z (42) N/A

9 PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 N (44) _____

8209280215 820915
 PDR ADOCK 05000293
 S PDR

NAME OF PREPARER: G. G. Whitney PHONE: 617-746-7900

GPO 917-926