



June 6, 1994
JPN-94-024

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Station Blackout Rule - Completion of Modifications

- REFERENCES: 1. NRC letter, R. A. Plasse to R. E. Beedle (TAC M 8546) dated June 9, 1992, "Supplemental Safety Evaluation of JAFNPP Response to the Station Blackout Rule."
2. NYPA letter, R. E. Beedle to NRC (JPN-93-025) dated April 7, 1993, "Supplemental Response for Station Battery Capacity Calculations, SBO Procedure, EDG Reliability Program and Modifications."

Dear Sir:

The NRC accepted (Reference 1) the Authority's response to the SBO program and requested notification upon completion of program upgrades and modifications. The Authority committed (Reference 2) to complete modifications to the power supplies for both Reactor Core Isolation Cooling (RCIC) enclosure fans and the Monitoring Analysis Panel (27MAP) instrumentation during the April 1994 maintenance outage.

Installation of the power supply modifications for both RCIC enclosure ventilation fans, and the 27MAP instrumentation, was completed on April 26, 1994.

Installation of these two modifications completes all of the actions required by 10 CFR 50.63 "Loss of All Alternating Current Power." If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'W. Josiger'.

William A. Josiger
Acting Executive Vice President
Nuclear Generation

000067

9406090088 940606
PDR ADOCK 05000333
P FDR

A050 1/0

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. John Menning
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555