

RECEIVED
1982 SEP 20 11 17 AM
SCE
FRIEDMAN

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92572

H. B. RAY
STATION MANAGER

September 16, 1982

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-361
Revised Licensee Event Report 82-001
San Onofre Nuclear Generating Station, Unit 2


Reference: Letter, H. B. Ray (SCE) to R. H. Engelken (NRC),
dated March 18, 1982 (LER 82-001)

The referenced letter transmitted a 30-day written report and LER 82-001 for an occurrence involving the Control Room Emergency Air Cleanup System (CREACUS). As noted in that letter our investigation determined that the Fire Protection System for the charcoal filter bank is not required to be an automatic system. Amendment 7 changed the Unit 2 Technical Specifications such that the system is now properly identified as a manually actuated system. Thus, a continuous fire watch that has been maintained on both Units (SONGS 2 & 3) is not necessary. This was discussed with your Resident Inspector on September 10, 1982, and, with his concurrence, the continuous fire watch has been removed.

The permanent modification to make the CREACUS fire protection system a manual system is being implemented and is now expected to be completed by September 30, 1982. Revised procedures S023-7-1 Rev. 5 and S023-3-5.35 Rev. 3 instruct the operating personnel how and when the system is to be manually actuated. Revision to LER form 82-001 is not necessary since this was not addressed therein.

If there are any questions, please contact me.

Sincerely,



IE22

820928023C 820916
PDR ADOCK 05000361
S PDR

82-333

cc: A. E. Chaffee (USNRC Resident Inspector, San Onofre Unit 2)

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information and Program Control

Institute of Nuclear Power Operations