

June 1, 1994

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION
DETERMINATION, AND OPPORTUNITY FOR HEARING - MILLSTONE UNIT 1
(TAC NO. M89527)

Enclosed is a copy of the subject notice for your information. This notice
relates to your application dated May 27, 1994 pertaining to emergency service
water (ESW) sampling. The proposed amendment adds a new section to Technical
Specification Section 6.17 and would require that procedures be in place to
provide for monitoring and sampling of ESW discharge flow during accident
conditions when a positive differential pressure cannot be maintained between
ESW and low pressure coolant injection (LPCI) in the LPCI heat exchangers.

The notice has been forwarded to the Office of Federal Register for
publication.

Sincerely,

Original signed by:

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9406090131 940601
PDR ADCK 05000245
P PDR

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	SNorris	UPA
NRC & Local PDRs	JAndersen	OC/LFDCB
PDI-4 Plant 0002	OGC	LDoerflein, RGI
SVarga	DHagan	
JCalvo	ACRS (10)	

Handwritten signature
FOI
1/1

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME	SNorris	JAndersen:bp	JStolk		
DATE	6/1/94	6/1/94	6/1/94	/ /	/ /

OFFICIAL RECORD COPY
Document Name: G:\ANDERSEN\89527.FRN

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 1, 1994

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION
DETERMINATION, AND OPPORTUNITY FOR HEARING - MILLSTONE UNIT 1
(TAC NO. M89527)

Enclosed is a copy of the subject notice for your information. This notice relates to your application dated May 27, 1994 pertaining to emergency service water (ESW) sampling. The proposed amendment adds a new section to Technical Specification Section 6.17 and would require that procedures be in place to provide for monitoring and sampling of ESW discharge flow during accident conditions when a positive differential pressure cannot be maintained between ESW and low pressure coolant injection (LPCI) in the LPCI heat exchangers.

The notice has been forwarded to the Office of Federal Register for publication.

Sincerely,

A handwritten signature in dark ink, appearing to be "JW Andersen".

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 1

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

J. M. Solymossy, Director
Nuclear Quality and Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, Connecticut 06106-5127

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

H. F. Haynes, Nuclear Unit Director
Millstone Unit No. 1
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502