



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-266

POINT BEACH NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 69
License No. DPR-24

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated September 21, 1978 as modified October 1, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-24 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 69, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 11, 1983



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WISCONSIN ELECTRIC POWER COMPANY

DOCKET NO. 50-301

POINT BEACH NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 74
License No. DPR-27

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Wisconsin Electric Power Company (the licensee) dated September 21, 1978 as modified October 1, 1981, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-27 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 74, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 11, 1983

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 69 TO FACILITY OPERATING LICENSE NO. DPR-24

AMENDMENT NO. 74 TO FACILITY OPERATING LICENSE NO. DPR-27

DOCKET NOS. 50-266 AND 50-301

Revise Appendix B as follows:

Remove Pages

16-i
16.1-1
16.1-2
16.2-1
16.2-2
16.3-1
16.3-2
16.3-3
16.4-1
16.4-2
16.4-3
16.5-1
16.5-2
16.5-3
16.5-4
16.6-1

Insert Pages

16-i
16.1-1
16.1-2
16.1-3

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
16	NONRADIOLOGICAL TECHNICAL SPECIFICATIONS	16.1-1
16.1	Definitions	16.1-1
16.2	Limiting Conditions for Operation	16.1-2
16.3	Environmental Monitoring	16.1-2
16.4	Record Keeping and Monitoring Program for Nonradiological Parameters	16.1-2
16.5	Reporting Requirements	16.1-3

Unit 1 - Amendment No. 69
Unit 2 - Amendment No. 74

16-i

16. NONRADIOLOGICAL TECHNICAL SPECIFICATIONS

16.1 Definitions

The definitions for terms used in these Nonradiological Technical Specifications for Units 1 and 2 are stated below.

WPDES Permit

The WPDES permit is the Wisconsin Pollutant Discharge Elimination System Permit No. WI-0000957-2 issued by the State of Wisconsin Department of Natural Resources for the Wisconsin Electric Power Company, Point Beach Nuclear Plant, dated September 28, 1979, and as subsequently amended.

16.2 Limiting Conditions for Operation

None required.*

16.3 Environmental Monitoring

None required.*

16.4 Recordkeeping and Monitoring Program for Nonradiological Parameters

None required.*

* In consideration of the provisions of the Clear Water Act (33 USC & 1251, et seq.) and in the interest of avoiding duplication of effort, the conditions and monitoring and recording requirements related to water quality and aquatic biota are specified in the WPDES Permit. As a matter of law, the NRC acknowledges the applicability of the WPDES Permit limitations for protection of the aquatic environment due to nonradiological effluents.

Unit 1 - Amendment No. 69

Unit 2 - Amendment No. 74

16.1-2

16.5 Reporting Requirements

Specification

1. As part of the Semiannual Monitoring Report, described in Section 15.6.9.2.C of Appendix A, the following shall be reported:
 - a. All scheduled and unscheduled chemical discharge to the condenser cooling water.
 - b. A description of circulating water system operation for each unit which includes ambient temperature, intake temperature, discharge temperature, and circulating water system flow.