

APPENDIX A

NOTICE OF VIOLATION

Philadelphia Electric Company  
Peach Bottom Units 2 and 3

Docket/License: 50-277/DPR-44  
50-278/DPR-56

As a result of the inspection conducted on January 11 - February 24, 1983, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 9, 1982 (47FR 9987), the following violations were identified:

A.1 10 CFR 50 Appendix B, Criterion III, Design Control, requires measures to assure that applicable design bases are translated into specifications, drawings, and instructions. FSAR Section 5 and Appendix C indicate that the Containment Atmosphere Dilution (CAD) System is a Seismic Class I system. The CAD System atmosphere analyzers require a nitrogen reference gas supply for proper operation.

Contrary to the above, seismic design requirements of the CAD analyzer reference gas supplies were not translated into specifications, drawings, and instructions (i.e., the Construction Job Memorandum, Engineering Work Letter, and Construction Drawing), either prior to installation of the supplies during October 1978 through April 1979, or at any time thereafter until about February 7, 1983.

This is a Severity Level IV Violation (Supplement I) applicable to DPR-44 and DPR-56.

A.2 Technical Specification 6.8 and Regulatory Guide 1.33 (November 1972) require implementation of written procedures for fire protection. Administrative Procedure A-30, Revision 4, May 21, 1981, Plant House-keeping Controls, requires all fire doors to be kept closed except to accommodate the movement of personnel or equipment.

Contrary to the above, at 12:30 p.m., January 26, 1983, the fire door between Unit 3 RHR Rooms 'B' and 'D' was blocked open; and at 11:20 a.m. February 7, 1983, the fire door to the Diesel Driven Fire Pump Room was blocked open. Neither of these doors was open to accommodate the movement of personnel or equipment.

This is a Severity Level V Violation (Supplement I) applicable to DPR-44 and DPR-56.

Pursuant to the provisions of 10 CFR 2.201, Philadelphia Electric Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which have been taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations, and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8303250058 830311  
PDR ADOCK 05000277  
Q PDR

OFFICE	LFNF Blough	LFNF Architzel	DPRP Keimig				
SUPNAME							
DATE	2/28/83						