

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M A P P S I | 2 | 0 0 0 - 0 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | \_\_\_\_\_ | 5

CON'T  
0 1 | REPORT SOURCE | L | 6 | 0 5 0 - 0 2 9 3 | 7 | 0 2 1 5 8 3 | 8 | 0 3 1 5 8 3 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 2/15/83, during a surveillance, the belt driven fuel pump broke on the "A"  
0 3 | diesel generator. The "B" D/G belt was inspected on the same date, and showed no  
0 4 | unusual sign of wear, however on 2/28/83, the belt on "B" D/G pump broke. In  
0 5 | both events, the backup electric pump performed its intended function. The diesels  
0 6 | were shut down and made inoperable to replace the belts. T.S. required surveillances  
0 7 | were also performed in both cases.

0 8 | \_\_\_\_\_ 80

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
E E | E | B | E N G I N E | Z | Z  
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
8 3 | 0 0 9 | 0 3 | L | 0  
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
A | Z | Z | Z | 0 0 0 | N | N | Z | A 1 5 2

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Normal wear is the most probable cause of these events, since the inspection of the  
1 1 | belts revealed no unusual or abnormal indications. The belts were replaced and the  
1 2 | tests satisfactorily completed. No other corrective action is planned at this  
1 3 | time. The belts are ALCO #2491551-1

1 4 | \_\_\_\_\_ 80

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION  
C | 0 6 0 | NA | C | Surveillance Test

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE  
Z | NA | NA

1 7 | PERSONNEL EXPOSURES | DESCRIPTION  
0 0 0 | NA

1 8 | PERSONNEL INJURIES | DESCRIPTION  
0 0 0 | NA

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION  
Z | \_\_\_\_\_

2 0 | PUBLICITY ISSUED | DESCRIPTION  
N | NA

8303250074 830315  
PDR ADOCK 05000293  
S PDR

NAME OF PREPARER: G.G. Whitney PHONE: 617-746-7900

NRC USE ONLY