

March 17, 1993

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-93-012A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

Facility

Carolina Power & Light Co.
Brunswick 1 2
Southport, North Carolina
Dockets: 50-325, 50-324

Licensee Emergency Classification

X Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
Not Applicable

Subject: LOSS OF OFFSITE POWER - UPDATE

Offsite power to Brunswick Nuclear Plant Unit 2 was restored at approximately 11:09 a.m. EST, March 17, 1993. The offsite power to Unit 1 will be restored later this evening (approximately 10-12 hours) after completion of Unit 1 switchyard washdown.

The licensee has issued a press statement. The State of North Carolina and the local counties are being kept informed.

resident inspectors are onsite and monitoring the licensee's activities.

At 11:30 a.m. EST, the Region II Incident Response Center was placed in the Monitoring Mode to monitor recovery activities at Crystal River (see PN2-93-013).

This information is current as of 11:45 a.m. EST on March 17, 1993.

Contact: Harold Christensen
(404)331-5533

9406100015 930317
PDR I&E
PNO-II-93-012 PDR

IE34
110