



**Consumers
Power
Company**

Midland Project: PO Box 1963, Midland, MI 48640 • (517) 631-8650

PRINCIPAL STAFF			
RA		OI	
D/RA		ENE	
A/RA			
CP&RP			orig+3 ✓
DEFEOS		SIC	
DESTP			
ML			
OL		FILE	hs

January 25, 1983

Mr. W. D. Shafer, Chief
Midland Project Section
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND PROJECT GWO 7020
REMEDIAL SOILS WORK AUTHORIZATION
File: 0485.16 UFI: 42*05*22*04 Serial: CSC-6527
12*32

This letter confirms a telephone conversation on January 25, 1983 between our Mr. G. Johnson and Mr. R. Gardner of your staff, during which the installation of an additional conduit support for the Auxiliary Building underpinning instrumentation was discussed. This conduit support installation will disposition NCR No. FSO-033. The support will clamp on outside the conduit and the cable will not be disturbed. Mr. Gardner was contacted per the "NRC and CPCo Work Authorization Procedure." He considered this work to be minor and gave his permission to do it.

D. B. Miller
D. B. Miller
Site Manager

DBM/GBJ/dmw

8303280108 830125
PDR ADOCK 05000329
A PDR

JAN 31 1983

TEO1