LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | M N P I N 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 0 6 (7) | 0 2 1 6 8 3 (8) | 0 3 1 8 8 3 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During routine operator rounds, control switches for heat trace circuits
0 3 ET2R and ET47F were found in the OFF position. This heat tracing warms the
0 4 boric acid line to the suction of the SI pumps. The switches may have been
0 5 off for nine hours. No effect on public health and safety since redundant
0 6 circuits were operable. Tech Spec 3.2.C.5 applies.
0 7
0 8

0 9 | SYSTEM CODE R B (11) | CAUSE CODE A (12) | CAUSE SUBCODE F (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 3 | — | SEQUENTIAL REPORT NO. 0 0 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Personnel working in the area apparently unknowingly bumped the control switches
1 1 to OFF; insulating and NDE personnel were working there. Upon discovery the
1 2 switches were returned to AUTO. No further action is necessary because low
1 3 temperatures would have been annunciated.
1 4

1 5 | FACILITY STATUS E (28) | % POWER 0 9 6 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator observation

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

1 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

1 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

2 0 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8303280151 830318
PDR ADOCK 05000306
S PDR

NRC USE ONLY

NAME OF PREPARER A. A. Hunstad PHONE: 612-388-1121

PO 91 7-926