

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N Y | J A | F 1 | 2 | 0 0 - 0 0 0 0 - 0 0 0 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
7 8 9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
0 1 | L | 6 | 0 5 0 0 0 3 3 3 | 7 | 0 9 0 9 8 2 | 8 | 1 0 0 7 8 2 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the performance of the Residual Heat Removal MOV Operability
0 3 | Surveillance Test, (F-ST-2C) the motor operator electrical breaker
0 4 | tripped while attempting to cycle a LPCI injection valve (10MOV25A).
0 5 | The 'A' loop of LPCI was declared inoperable per TS 3.5.3A. The
0 6 | redundant system was available and operable. No effects upon public
0 7 | health or safety and no other safety implications associated with
0 8 | this event.
7 8 9

0 9 | S | F | 11 | E | 12 | A | 13 | V A L V O P | 14 | A | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 | LER/RO REPORT NUMBER | 8 2 | 21 22 | 0 4 4 | 24 26 | / | 0 3 | 28 29 | L | 30 | 0 | 32
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A | 18 | Z | 19 | Z | 20 | Z | 21 | 0 0 0 0 | 37 40 | N | 23 | Y | 24 | N | 25 | L 2 0 0 | 26
33 34 35 36 37 40 41 42 43 44 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | An electrical motor fault, resulting in insulation failure was created
1 1 | during the attempted valve cycling. Due to regulatory requirements
1 2 | the safety related motor is required to have 300 percent thermal over-
1 3 | load "protection" rather than a typical 100 to 120 percent overload
1 4 | which would ensure no motor damage as a result of an electrical fault.
7 8 9

The motor was replaced and the valve restored to service.
1 5 | E | 28 | 1 0 0 | 29 | NA | B | 31 | Operator Observation
7 8 9 10 12 13 44 45 46
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 6 | Z | 33 | Z | 34 | NA | NA
7 8 9 10 11 44 45
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 7 | 0 0 0 | 37 | Z | 38 | NA
7 8 9 11 12 13
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)

1 8 | 0 0 0 | 40 | NA
7 8 9 11 12
PERSONNEL INJURIES NUMBER DESCRIPTION (41)

1 9 | Z | 42 | NA
7 8 9 10
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)

2 0 | N | 44 | NA | S | PDR | 58 69 | _____ | 80
7 8 9 10
PUBLICITY ISSUED DESCRIPTION (45) NA S PDR NRC USE ONLY

NAME OF PREPARER W. Fernandez PHONE: 342-3840