NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | C A S O S 2 (2) LICENSEE CODE | 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE NUMBER | 4 1 1 1 1 (4) LICENSE TYPE | (5) CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 1 (7) DOCKET NUMBER | 0 9 1 8 8 2 (8) EVENT DATE | 1 0 0 8 8 2 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 2, the Condensate Storage Tank T-120 water level fell
03 below the Technical Specification 3.7.1.3 limit. There was no consequence
04 to public health and safety since there was no significant decay heat in
05 the core.
06
07
08

09 | SYSTEM CODE: H H (11) | CAUSE CODE: B (12) | CAUSE SUBCODE: A (13) | COMPONENT CODE: Z Z Z Z Z Z (14) | COMP. SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 8 2 | — | SEQUENTIAL REPORT NO.: 1 1 7 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | — | REVISION NO.: 0

ACTION TAKEN: X (18) | FUTURE ACTION: F (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: Z (25) | COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Inadequate makeup water control to Tank T-121 and a more restrictive than necessary
11 Technical Specification limit were the cause. Corrective actions include a proposed
12 Technical Specification change and a design change to install automatic level
13 control systems (expected to be installed prior to 100% power operation).
14

15 | FACILITY STATUS: B (28) | % POWER: 0 - (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operator Observation

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES
17 | NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES
18 | NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY
20 | ISSUED: N (44) | DESCRIPTION (45)

8210190323 821008
PDR ADOCK 05000361
S PDR

NRC USE ONLY

NAME OF PREPARER: H. B. Ray

PHONE: 714/492-7700