RILEY

arl

ORIGINAL

1	UNITED STATES OF AMERICA NUCLEAR REGULATORY COMMISSION
2	HOUDING RECORDENION
3	BEFORE THE ATOMIC SAFETY AND LICENSING APPEAL BOARD
4	x
5	In the matter of
6	CONSUMERS POWER COMPANY : (Spent Fuel Pool : Modification)
7	(Big Rock Point Nuclear Power Plant) :
8	x
9	
10	5th Floor Hearing Room
	Bethesda, Maryland
12	Thursday, March 24, 1983
13	Oral argument in the above-entitled case
14	convened at 9:30 a.m., pursuant to notice.
15	BEFORE: TROI
16	JUDGE THOMAS MOORE. ADD: LPDR to:
17	JUDGE JOHN BUCK.
18	JUDGE CHRISTINE KOHL. C. CATER
19	
20	APPEARANCES:
21	JOSEPH GALLO, ESQ. Isham, Lincoln & Beale
22	Washington, D.C. 20036
23	-and-
24	8303280220 830324 PDR ADOCK 05000155 PDR
25	

2. 1

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on <u>March 14, 1983</u> in the Commission's offices at 1717 H Street, N. W., Wasnington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determinations or baliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

PETER THORNTON, ESQ.
Isham, Lincoln & Beale
Three First National Plaza
Chicago, Illinois 60602,
COUNSEL FOR THE LICENSEE.
RICHARD BACHMANN, ESQ.
EDWARD REIS, ESQ.
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
wasnington, b.c. 20000,
COUNSEL FOR THE NRC STAFF.
HERBERT SEMMEL, ESQ.
Antioch School of Law
2633 16th Street, N.W.
Washington, D.C. 20009,
COUNSEL FOR INTERVENORS CHRISTA-MARIA.
MILLS AND BEIR.
ALDES AND DELA
JOHN O'NEILL II
Nonle City, Michigan 49664.
Mapre crey, menigen useer,
APPEARING PRO SE.
Alco Present:
AISO FIESENC.
RICHARD EMCH, NRC Staff.
JERRY UMBARGER, Consumers Power.
DENISE WIKTOR, Legal Intern.
 TAVIOE ASSOCIATES
REGISTERED PROFESSIONAL REPORTERS
NORFOLK, VIRGINIA

A Stky

2

ar2

100

		and the second se
,	$\underline{C} \ \underline{O} \ \underline{N} \ \underline{T} \ \underline{E} \ \underline{N} \ \underline{T} \ \underline{S}$	
2	Coul Deserve of Jeroph Colle	
3	on behalf of the Licensee.	4
4	Oral Argument of Richard Bachmann,	26
5	on benalf of the NRC Staff.	20
6	Oral Argument of Herbert Semmel, on behalf of Intervenors Christa-Maria, et al.	41
7	Oral Argument of John O'Neill II, on behalf of himself.	62
8	Rebuttal Argument of Joseph Gallo,	
9	on behalf of the Licensee.	80
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

2-A

5

4

2

3

4

5

6

7

8

9

10

11

12

13

PROCEEDINGS

3

JUDGE KOHL: Good morning. The Appeal Board is hearing argument this morning on the appeal of Consumers Power Company from the Licensing Board's October 29, 1982 partial initial decision concerning the neutron multiplication factor in this license amendment proceeding.

The argument is governed by the terms of our order of February 17th. As provided therein, each side is allotted one hour for their presentation of argument. Consumers Power, as the appellant, may reserve a portion of its time for rebuttal. If those arguing this morning would now introduce themselves for the reporter, we will then proceed. We'll start with the staff.

MR. BACHMANN: My name is Richard G. Bachmann,
I'm counsel for the NRC Staff. With me at the table is Mr.
Edward Reis, also counsel for the NRC Staff, and Mr. Richard
Emch, who is the Project Manager for Big Rock Point.

MR. GALLO: Good morning, Judge Moore, and members
of the Board. My name is Joseph Gallo with the law firm of
Isham, Lincoln and Beale, 1120 Connecticut Aveue, N.W.,
Washington, D.C. At the extreme end of the table is Mr.
Peter Thornton of the same firm. Together we represent
Consumers Power Company.

Seated between us is Mr. Jerry Umbarger; he is
 Operational Reactor Physics Administrator for Consumers

1	Power Company.
2	MR. O'NEILL: Good morning. My name is John O'Neill
з	II. I am an intervenor representing myself. I live in
4	Maple City, Michigan.
5	MR. SEMMEL: I am Herbert Semmel from Antioch Law
6	School. I represent Intervenors Christa-Maria, Mills and
7	Beir. With me, to my left, is Denise Wiktor, a legal intern.
8	JUDGE MOORE: Mr. Gallo, you may proceed.
9	ORAL ARGUMENT BY JOSEPH GALLO ON BEHALF OF LICENSEE.
10	MR. GALLO: Members of the Board, I will, indeed,
11	reserve a part of my time for rebuttal. I believe the issues
12	are guite simple, and I'd like to start out by pointing out
13	that the issue of supercriticality and whether or not this
14	phenomenon might occur at the Big Rock pool, the spent fuel
15	pool, first arose as a result of the Licensing Board's ruling
16	on the motions for summary disposition. Basically, information
17	was provided by the Intervenors in this case in connection with
18	another contention, that prompted the Board to look at an article
19	that appeared in Nuclear Technology, the 1980 edition. As a result
20	of the inquiry, the Board determined it appropriate to issue a
21	Board question asking that the Licensee and Staff explore the
22	question of supercriticality in connection with the spent
23	fuel pool application pending for the Big Rock Point plant.
24	When we received that Board question in the context
25	of the summary disposition order and ruling by the Licensing
	THURSE ASSOCIATES

4

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

Board, our reaction was that arguably, such an inquiry was beyond the design basis, but in the context of that order we believe the matter could be easily addressed where the question of super-criticality only arises if you have a loss of water condition where you begin to have the fuel uncovered and you have a mist or steam environment.

That very question -- that is, the question of loss of water -- had been raised in connection with another contention which we refer to in this case as the TMI-II contention. That contention suggested that in the event of a loss of coolant accident rendering containment inaccessible for some indefinite period of time, the spent fuel pool cooling system might fail, and as a result, pool boiling would ensue and the water would boil off and you would have a resultant melting of the spent fuel in the pool.

In response to that contention, in our motion for summary disposition we pointed out that assuming those circumstances, that the licensee, Consumers Power Company, was committed to put in something called a remotely activated makeup line, and that makeup line would prevent the very problem anticipated by the contention; that is, the loss of water.

The Board found that proposition persuasive in its order for summary disposition with one exception; it found that there was not enough evidence in the pleadings to

-

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

determine whether or not the remotely activated makeup line was sufficiently reliable for its intended purpose, and set down that question, among others, for hearing and for the taking of further evidence.

6

Moreover, in a companion issue, again raised by the intervenor in their response to the motions for summary disposition, suggesting that a loss of water situation would cause a zircaloy/steam reaction, the Board found that none of the evidence and none of the information supplied by the Consumers Power Company in connection with its application addressed a zircaloy-steam reaction.

The Board suggested that the staff and the applicant had to address that question, but it also opined in its order that of course, if the makeup line was determined to be sufficiently reliable in connection with the other issue raised by the Licensing Board as a genuine issue of fact, we need not -- that is, the licensee need not address the consequences of the zircaloy-steam reaction.

So it's in that context we viewed the further Board question on the super-criticality issue. It seemed quite 20 clear to the licensee that the makeup line, if it served the 21 purpose of negating an inquiry into the consequences of the 22 zircaloy-steam reaction, if it negated an inquiry into the 23 consequences of melted fuel in the spent fuel pool, it had 24 equal application to negate the need to do an analysis to 25

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

> > .

25

.

determine the consequences of a super-criticality accident. 1 2 JUDGE KOHL: Counsel, do you have any problem, then, with conditioning the finding on criticality on the 3 subsequent determination of the reliability of the makeup line? 4 5 MR. GALLO: Absolutely not. In fact, we so 6 stipulated in the findings of fact and material that we submitted at the conclusion of the hearing on this issue, and 7 indeed, have asserted that in the brief before this Board. 8 9 Now, it is with the background of the analysis that I have just presented with respect to the summary disposition 10 order of the Licensing Board that our witness, Dr. Kim, 11 12 drafted his testimony. He made it clear in his testimony, both in his prepared written testimony and in his testimony 13 under cross examination both by the intervenors and by the 14 Licensing Board that basically his criticality analysis was 15 on the basis of a sub-criticality analysis for the purposes 16 of keeping reactivity in the spent fuel pool below .95 under 17 conditions where the coolant water was maintained. And that 18

19 for the super-criticality situation he was relying on the 20 remotely-activated makeup line.

He did go further and attempt to address the Board's questions in the context of the matters raised by the article in the Nuclear Technology edition, but beyond that, his primary basis for his position was the makeup line.

Now, for the first time we discovered -- that was

8

	'	when the Board issued its decision on this matter that the
	2	Board felt it could not give credit to the makeup line. We
	3	believe I believe that the Board ordinarily would have
	4	given credit for the makeup line, witness its actions in
	5	connection with the TMI-II contentions, witness its actions in
	6	connection with the zircaloy-steam reaction that it posed.
	7	But it felt constrained by its interpretation of the staff's
	8	Safety Evaluation Report to not give credit to the makeup line.
	9	JUDGE KOHL: Counsel, don't the various staff
	10	Reg Guides and other guidance refer to the fact that these
	11	analyses, the criticality analysis, should be performed for
	12	all conditions so as to assure sub-criticality at all times?
D	13	I think at various points throughout the literature
	14	that phrase is used, and I think that's what the Licensing
	15	Board was relying on when it found that it could not take
	16	credit, as it were, for the remote makeup line.
	17	MR. CALLO: We have argued in our brief that it is
	18	our belief that that, in fact, is what the Licensing Board
	19	was relying on. I might say, Judge Kohl, that I spent
	20	considerable time reviewing the Standard Review Plan,
	21	Regulatory Guide 1.13, Proposed Revisica 2, the ANSI standard,
	22	and I find in none of those documents any statement that is
	23	an analog to the all-condition phrase to which you refer.
	24	JUDGE KOHL: What about the branch technical
	25	position? There is a reference there to excessive loss of

۱

4

5

6

8

9

10

2.5

12

13

14

15

16

17

18

19

20

21

22

25



water due to evaporation and/or because of fogging. What about that particular portion of the technical position?

MR. GALLO: Well, I believe the section to which you refer is included under a general caption. It's Section 1.5 entitled, "Acceptance Criteria for Criticalicy," and the introductory phrase contains the very language that the Board cited in the Safety Evaluation Report. And it is our belief that the SER language is really a reiteration and, to some extent, a verbatim reiteration, of the prefatory paragraph under 1.5 of the branch technical position. That's appearing at page III-3.

JUDGE KOHL: Just flip over two pages to III-5 where we're beyond the introductory or prefactory remarks. Under Section 5, Technical Specifications, .1, it says the neutron multiplication factor in the fuel pool shall be less than or equal to 0.95 at all times. Then dropping down below the explanatory material for that discrete section of the branch technical position is the portion that I'm referring to that does talk about an excessive loss of water and the fact that analyses of thermal loads should consider loss of all cooling -- all pool-cooling systems.

MR. GALLO: Yes.

23 JUDGE KOHL: What does loss of all pool-cooling 24 systems mean, as used in here?

MR. GALLO: Every spent fuel pool has a mechanism

1	called the spent fuel cooling system for essentially
2	dissipating decay heat that results from the spent fuel
3	sitting in residence in the pool. The water heats up because
4	the fuel generates heat, and as a result, the water heats up.
5	The spent fuel cooling system is a system that
6	removes that heat to avoid a situation where the temperature
7	would increase and ultimately reach a boiling condition.
8	JUDGE KOHL: So you are limiting that language to
9	a failure of the cooling system itself, as opposed to a loss
10	of the coolant.
11	MR. GALLO: That's correct. Well, I think there
12	is even a more persuasive reason for that statement.
13	JUDGE KOHL: Let me just follow up on that, though.
14	If that is your interpretation of that, how does that square
15	with the immediately preceding sentence that does talk about
16	excessive loss of water?
17	MR. GALLO: It's my view that what the staff meant
18	when they drafted this paragraph was that they were worried
19	about the effects of decay heat and the components of the
20	concrete within the pool, because look at the remedy that
21	they suggest. And I think that that is dispositive of
22	whatever meaning can be given to this paragraph.
23	The remedy they suggest is that a tech spec limit
24	should be considered. Not required; should be considered.
25	And the limit should be the limit temperature. They don't
	TAYLOF ASSOCIATES

REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

11

,	impose a condition to attempt to avoid the loss of pool
2	cooling, such as a makeup line might do. They simply
3	indicate a limit on the temperature level. My experts
4	advise me that this
5	JUDGE KOHL: But this is under the specific
6	section that deals with criticality, is it not?
7	MR. GALLO: That's correct. But the whole section
8	on acceptance criteria is kind of under Section 1.5 is
9	kind of a potpourri of analyses and requirements to satisfy
10	Criterion 62, and they deal with the conditions for the
11	analysis, the type of calculations for the analysis, the
12	type of accidents that need to be addressed, and finally, the
13	technical specification section to which you refer.
14	So they clearly intend to impose a limit of .95,
15	but this section and I'm referring now to the whole of
16	Section 1.5 has to be read in the context of the entire
17	branch technical position, which is clearly dealing with what
18	the branch technical position believes to be a credible
19	situation.
20	They use the term in the preamble, and beyond that,
21	it defines that is, the branch technical position, and
22	Section 1.5 in particular, defines the accidents that you
23	need to address. And nowhere in any of this branch technical
24	position is the loss of spent fuel pool coolant addressed,
25	except in the point that you point out, Judge Kohl. And it

١

2

3

4

5

6

7

leads me to believe that the staff did not have in mind, when they wrote that paragraph on page III-5, a supercriticality situation.

They, I believe, had in mind a situation of avoiding a matter where the decay heat might adversely affect the concrete, or might adversely affect some other component involved in the spent fuel pool cooling.

B JUDGE KOHL: If they have the fourth postulated accident, then, going back towards the beginning of the branch technical position where it does enumerate various accidents that must be considered in the analysis -- the fourth one, again, there is loss of all cooling systems or flow under the accident conditions unless the cooling system is single failure proof.

Again, you are reading that to limit it to loss of the system itself, as opposed to the loss of the pool coolant, and you don't regard that postulated accident scenario as encompassing what the Licensing Board had in mind here?

20 MR. GALLO: No, no, I do not. In fact, Dr. Kim 21 did exactly what item 4 indicates. He conducted a criticality 22 analysis where a pool boiling situation which results from 23 the occurrence of the loss of the cooling system, and the 24 answer, of course, as I have indicated, was that he gave 25 credit to the spent fuel pool makeup line. There is nothing

In

I know

in that section that says what you need to do is to assume 1 the condition the Board did and then analyze for it in terms 2 of maintaining your criticality below .95. 3 JUDGE KOHL: All right. If we assume that nothing 4 in any of the staff guidance, be it Reg Guides or branch 5 technical positions or whatever, requires the analyses 6 ordered by the Licensing Board, is there anything in that 7 that would prohibit it under certain circumstances? 8 other words, are these just minimum requirements? 9 MR. GALLO: Well, I believe that the -- I wish to 10 stress that our discussion of the interpretation of the 11 branch technical position and the other NRC staff guidance 12 is simply for the purpose, in my judgment, of trying to 13 understand how the Licensing Board went wrong. 14 The Licensing Board, to answer your question, 15 should have been controlled by Criterion 62. That's the 16 only binding regulation that applies in this situation. 17 Criterion 62 says quite clearly that you can meet its 18 requirements to prevent criticality, and we read that to 19 mean also, super-criticality; that you can meet that 20 requirement in two ways, either by geometric configuration, 21 even though that's the preferred method, or by physical 22 systems. And we submit that the makeup line is just such a 23 physical system. 24 JUDGE KOHL: What's your support for that? 25

2

3

4

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

that's the position I believe the staff takes also, and I am curious as to what information we have and what was meant by the expression "physical systems" in Criterion 62.

MR. GALLO: Well, the legislative history, if I can use that phrase, on Criterion 62 does not disclose exactly 5 what the term "physical systems" means. The early formulation 6 of Appendix A to Part 50 did establish the design criterion and had as a part of it a separate section that addressed a subject called "engineered safety features." It was a separate section and it explained how engineered safety features play a role in the overall design of the safety of a nuclear power reactor.

In the final formulation of Appendix A, that specific section was deleted, and instead, in a rather terse statement in the statement of considerations it said the section on engineered safety features was deleted, and instead, the concept was integrated into the various design criteria.

We believe, based on that statement, that the term "physical features" is one manifestation of that implementation. And by the plain meaning of the words, it can have no other meaning.

You've got a geometric configuration which means rack placement, spacing, and physical features means some other mechanism for maintaining reactivity beyond .95 or, in this case, below -- in excess of 1.

21

22

1 JUDGE KOHL: Might it not refer, though, to the 2 character of the ranks themselves as opposed to a separate 3 system like the makeup line? 4 MR. GALLO: No, I don't think so because then 5 the term "physical features" would be redundant and unnecessary because the term "geometric configuration" takes into account 7 the rack, design, the spacing and --8 JUDGE KOHL: Well, the spacing. But what about 9 the type of racks used, for example? Racks that have a 10 neutron-absorbing material in the rack itself, which I take 11 it this particular proposal does not have? 12 MR. GALLO: That's correct, does not have. No, I 13 can't agree with that because I think such an interpretation 14 would just do violence to the plain meaning of those words 15 because the insertion of a boron-absorbing or a poison 16 element into the rack, as I understand it, is physically 17 integrated into the spent fuel pool reactor in its 18 fabrication, and it essentially absorbs the neutrons. The 19 rack itself and its design accomplishes the spacing. That's 20 what is meant by geometric configuration.

"Physical system" has to mean something else, and in this case, we submit it's the makeup line.

JUDGE KOHL: I'm not sure you ever answered my
 question as to whether or not, assuming that there is
 nothing in any of the staff requirements or guidance, that

1 would require a mandate that the Licensing Board did here. 2 Is there anything to preclude it? The same statement of 3 consideration that you referred to for general design criterion 4 62 does state that those are only minimum requirements that 5 are being established. 6 MR. GALLO: Yes. 7 JUDGE KOHL: Given that the Big Rock Point spent 8 fuel pool is in a different situation from any other plant 0 insofar as it is within the containment building itself as 10 opposed to a separate auxiliary building, perhaps it is just \$1 the special circumstance that might require exceeding the 12 minimum guidance or the minimum requirements. 13 MR. GALLO: Well, of course, our position is that 14 criterion 62 is controlling on the Board. But to answer your 15 question specifically, there is no actual predicate below 16 which would support that the Licensing Board's action of 17 departing from criterion 62 in this case -- there is no 18 factual predicate or other evidentiary basis upon which the Board could have asserted its conclusion. 19 20 Indeed, it didn't attempt to do it on any factual basis; it attempted instead to bottom its interpretation on 21 the interpretation of the safety report issued by the NRC 22 23 staff.

I agree with you that Appendix A to Part 50 does
 indicate that those are minimum requirements, and it does

25

indicate there may be circumstances under which there are 1 additional requirements in that situation, though a factual 2 predicate, a technical basis, has to exist in order to 3 support such a departure, and that doesn't exist in this record. 4 JUDGE BUCK: May I get into this for a few minutes? 5 MR. GALLO: Please do, Dr. Buck. 6 JUDGE BUCK: I think there is a lot of confusion --7 there seemed to be on the part of the Licensing Board -- as 8 to the reason for the Big Rock spent fuel pool being, shall 9 we say, over moderated. The lack of, or the conservation of, 10 a keff of below .95 was basically a spacing thing. The 11 rack out there is made up of stainless steel. Stainless steel 12 itself is a poison just like boron is; not quite as effective 13 but it is a poison. The only difference between this and 14 many other pools -- not all other pools -- is the fact that 15 the water spacing here is greater than other pools and you 16 have more water than you need. 17

If you boil some of that away, you get the density down and your criticality tends to go up, and I think this is what seemed to have the Board worried. That if you did heat this thing and you got bubbles in there, your density went down and criticality went up for a short time. If it got below that as it boiled down further, the criticality curve goes down.

And for some reason or other -- and I think the

1 Board got completely confused about this and got worried 2 about it, because if I am correct, then the applicant's 3 calculations were all done on new fuel. And I think Dr. Kim 4 stated that the keff of the fuel would be about .15 or more, 5 or greater than the spent fuel. Is correct? 6 MR. GALLO: I believe that's correct. 7 JUDGE BUCK: Was that controverted by anybody in this hearing? I didn't see it, but as far as I know, it is B correct because the spent fuel would have a lot more actual 9 fissionable fuel in it after having been through the reactor. 10 One question is, do you -- or when do you put 11 12 fresh fuel into this pool. MR. GALLO: My understanding, Judge Buck, is it 13 would only occur under one circumstance. That you might load 14 the reactor with fresh fuel at a refueling. 15 JUDGE BUCK: But you do go through this pool in 16 loading, don't you? Do you put the fresh fuel into the -- ? 17 you don't? In some reactors you put it into this pool and 18 then --19 MR. GALLO: My understanding is that the fresh 20 fuel is stored in a vault, so to speak, right near the 21 reactor head. 22 JUDGE BUCK: That's a dry vault. But you're moving 23 into loading it and you've got to get it underwater 24 somewhere to move it into the tunnel, to the reactor. 25 TAYLOE ASSOCIATES

REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

	1	MR. GALLO: May I refer to my expert?
0	2	JUDGE BUCK: Surely.
	3	MR. GALLO: How do we move it from the dry vault
	4	into the reactor?
	5	MR. UMBARGER: In general, it does not go through
	6	the spent fuel area, but it could possibly go in there if you
	7	had something happen to a bundle and you wanted to remove it,
	8	you wanted to take it apart and put another pin in it, or
	9	you wanted to do an experiment.
	10	I believe during the refueling you might take a
		new bundle in there, work on it and then move it.
	12	JUDGE BUCK: All right. You're telling me that
	13	you move a new bundle directly into the in the passageway
•	14	into the reactor itself. Is that right? You don't have to
	15	put it into the pool first?
	16	MR. UMBARGER: To the best of my knowledge, that's
	17	true.
End tp 1	18	
	19	
	20	
	21	
	22	
	23	
	24	
-	25	
	L	TAYLOE ASSOCIATES
		REGISTERED PROFESSIONAL REPORTERS

NORFOLK, VIRGINIA

19

Riley 20 Tape 2 3-24 Connelly JUDGE BUCK: So the only time you would have a lot 1 in there -- for example, you put a new loading of a third of 2 the reactor into the reactor, and then for some reason just 3 on startup something happened that you have to unload the 4 whole thing, then you would have that one-third load as fresh 5 fuel in the pool, is that correct? 6 MR. GALLO: That's correct, sir. 7 JUDGE BUCK: But that's about the only time that 8 would happen? 9 MR. GALLO: That's correct. 10 JUDGE BUCK: Do you know anything about how they 11 would load that in the pool if they did it? 12 MR. GALLO: Well, they would remove the assemblies 13 from the reactor in a spent fuel transfer cask and then 14 transport the cask into the pool and unload the fuel assembly. 15 JUDGE BUCK: Do you know anything about how they 16 would place it? Would they place it all together, or would 17 they place it --18 MR. GALLO: They would put it in the existing spent 19 fuel pool racks that have already been analyzed for purposes 20 of criticality. Does that address your question? 21 JUDGE BUCK: No. What I'm asking is if you brought 22 out a third of that reactor as fresh fuel and put it into 23 the pool, would you spread it around the pool? Is that the 24 normal circumstances? 25 TAYLOE ASSOCIATES

1	MR. GALLO: I believe they would. They would not
2	concentrate it in one area, that's correct, sir.
3	JUDGE BUCK: All right.
4	Now, the other thing is it's my understanding that
5	you can't possibly cause overheating in the pool with fresh
6	fuel. Is that correct?
7	MR. GALLO: I really can't address that.
8	MR. UMBARGER: That's true.
9	JUDGE BUCK: So that you only have boiling in the
10	pool if you had a high level of spent fuel in there. That's
11	where the heat comes from.
12	MR. GALLO: That's correct. Primarily, Judge Buck,
13	from the spent fuel that was removed at the prior refueling.
14	That's where most of the decay heat generates from.
15	JUDGE BUCK: You see, what's bothering me about this
16	thing, and I think we've caused a lot of confusion on the part
17	of the Board, is the calculations were all done on a complete
18	fuel pool loading of fresh fuel to get a reactivity level
19	or a k level of .95 under Dr. Kim's and Dr. Lantz's calcula-
20	tions. Under those circumstances you can't possibly boil any
21	water in the fuel, so you'd have to have some other untoward
22	accident if you did have it in there. But if you had
23	old fuel in there when you could possibly get boiling, the
24	k eff is so far down that there's no reason to worry about it.
25	And I wondered as far as I can see, the Board just got

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

sc2

completely confused by the calculations being done on 1 completely fresh fuel. 2 MR. GALLO: I think Dr. Kim testified to just the 3 point you're making now, Judge Buck. He pointed out that there 4 was just conservatism upon conservatism built into this 5 criticality analysis. At the end of two and a half days of 6 cross examination he was permitted to make a statement, and 7 in that statement he pointed out that the criticality analysis 8 bore no relation to the real world of what the environment 9 in the pool was. So I think that's correct. 10 JUDGE BUCK: I've read that statement, and to me 11 it just pleaded for a little bit of communication or under-12 standing, and I couldn't quite understand why this was gone 13 through. 14 JUDGE KOHL: Mr. Gallo, if I could ask one clarifica-15 tion here. Doesn't the Staff requirements always require 16 for spent fuel pool criticality calculations that built-in 17 conservatism of new fuel? Isn't that a --18 MR. GALLO: Yes. My understanding is that's one 19 of the criterion of the Staff's guidance in this area, that 20 you do your analysis on the assumption of new fuel. 21 JUDGE KOHL: Thank you. 22 JUDGE MOORE: Mr. Gallo, excuse me. 27 Assume for the moment that the Licensing Board has 24 misread the Staff guidance and its reliance on its 25

interpretation of what the Staff guidance meant by "under all 1 conditions." The Board concluded, did it not, that even with 2 that assumption, that even if it were in error on the first 3 point, it said, "Second, even while we do apply more lenient 4 standards to the pool, we would accept a portion of Dr. Kim's 5 testimony adverse to the position of this claim in this pro-6 ceeding that the calculational methods so far employed for 7 this fuel pool are not adequate to give confidence that keff 8 will remain below .95 once the density of water had declined 9 below .50." 10 That's on page 22 of the Licensing Board's opinion. 11 MR. GALLO: I recall the statement. 12 JUDGE MOORE: Does that statement indicate that 13 should we disagree with the Licensing Board's reading of the 14 Staff guidance that we also must disagree with the Board's 15 reading of the testimony in order to reverse in this case? 16 MR. GALLO: I'm sorry. The last part of your ques-17 tion, must we also agree --18 JUDGE MOORE: Must we also disagree with the 19 Licensing Board's reading of Dr. Kim's testimony to reverse 20 in this case? 21 MR. GALLO: I think that -- well, I think the 22 answer is yes, and I think the Board did mischaracterize 23 Dr. Kim's testimony. He said what the Board indicated, but 24 it was in the context of setting aside for the moment taking 25

13

14

15

16

17

18

19

20

21

22

23

24

25

credit for the makeup line. Dr. Kim's talking about his 1 calculations and his analysis, and he quite candidly points 2 out that his calculations and his analysis don't go to the 3 point of analyzing for purposes of reactivity the condition of A supercriticality. 5 It is in that context he makes that statement, but 6 in making the statement he was not abrogating reliance on the 7 spent fuel pool makeup line; and that's the important point 8 here. 9 JUDGE MOORE: Assume that we agree with you that it 10 was error not to take into account an engineered safety feature, 11

was error not to take into account an engineered safety feature, your Criterion 62, Appendix A of Part 50 of the Commission's regulation, and that the Licensing Board should have waited until it had heard testimony and decided that issue before it decided the k_{eff} issue.

Assume that. In the present posture of this case what steps should we then take?

MR. GALLO: Well, the Licensee's position is that the Licensing Board's order should be vacated, no requirement to do the analysis, and that the contention itself -- that is, the criticality contention -- essentially be dismissed, and not, as the Staff suggests, be held in abeyance pending the outcome of the Board's consideration of the reliability of the makeup line.

By implication, what I'm saying, of course, you have

to give credit to the makeup line in order to dismiss the 1 criticality issue. 2 Now, let me explain why I say that. 3 JUDGE MOORE: But aren't you asking us, Mr. Gallo, 4 to essentially overrule what amounts to a credibility finding 15 of the Licensing Board and how they credited Dr. Kim's testimony? 7 MR. GALLO: No, because if the Board erred as a 8 matter of law in failing to give credit to the makeup line. a Dr. Kim's testimony is no longer material to the issue. 10 JUDGE MOORE: Fine. 11 JUDGE BUCK: Going back to Judge Kohl's question, 12 I took your answer to her questions about the cooling ensuing 13 under normal conditions as being something that was part of 14 the structure and processes of normal maintenance of pool 15 water, is that correct, as against the safeguard situation 16 of having a separate control on for emergency conditions? 17 MR. GALLO: Yes, that's the separate condition 18 of the temperature specifications. Yes, that's correct. 19 JUDGE MOORE: Mr. Gallo, your time is about up. 20 MR. GALLO: I would like to make just one last point, 21 and that is on the remedy. The Staff and the Licensee disagree 22 on whether or not the criticality contention should be dismissed. 23 They believe it should be held up pending a resolution of the 24 reliability of the makeup line. 25

sc7

	In our view, the criticality issue should be
(dismissed because and I would analogize as a reason for
	doing that is because, to digress for just a second, the
-	only difference between our position and the Staff position
	is a procedural one. The reason why we take our position is
	we want the doctrine of repose to apply. This issue has been
	pending for some time. If it remains in its present state,
1	the ability to reopen issues with respect to it is very, very
	iffy. If the issue is dismissed, then it can only be reopened
	subject to complying with the Vermont Yankee judgment for
	reopening records, and the Board would still have jurisdiction
	to do so if they so decided. I might also point out,
	parenthetically, that if the Board found against us on the
	reliability issue, it does not mean automatically that we
	have to do the analysis. We simply have to make it reliable
	in whatever respect the Board found it was insufficient.
	Thank you.
	ORAL ARGUMENT OF R. BACHMANN, ON BEHALF OF THE STAFF
	MR. BACHMANN: Before I give you my argument, I woul
	like to reserve five minutes for rebuttual if necessary. I
	did not put it in my letter, but if that is all right
	JUDGE MOORE: Fine.
	MR. BACHMANN: It is indicated by Mr. Gallo the
	Licensing Board has ordered the Licensee to perform criticality
	calculations under conditions postulated by the Board; that is

NORFOLK, VIRGINIA

a significant loss of water in the pool. This is by the 1 Board's own wording in its decision. 2 General Design Criterion 61, which was not mentioned 3 by Mr. Gallo, requires that spent fuel pools be designed in 4 such a manner to prevent a significant loss of coolant inventory. 5 To comply with that particular general design criterion, the 6 Licensee has proposed a remotely activated water makeup line. 7 Therefore, it is the Staff's position that the Licensing Board 8 has erred in not considering this remotely activated makeup 9 line which is required by General Design Criterion 61. 10 JUDGE KOHL: Mr. Bachmann, you said in your brief, 11 I believe, that you do regard the remotely controlled makeup 12 line as a physical system under Criterion 62. 13 MR. BACHMANN: That's correct. 14 JUDGE KOHL: So, in other words, you would regard 15 that as applicable to both of these criteria. 16 MR. BACHMANN: That is correct. 17 JUDGE KOHL: Then you disclaim somewhat in your 18 brief the close relationship or the linkage between the two 19 criteria that Applicant's counsel demonstrated in its brief 20 or argued for in its brief. 21 Are you now closer in agreement with counsel for 22 Applicant, or what is your position on that? 23 MR. BACHMANN: We stated in a footnote that the 24 Staff did not support the "strong interplay" between 61 and 25

62 that Mr. Gallo indicated was there. It is the Staff's 1 position, however, that a physical system can be, by inference, 2 this remotely activated makeup line. 3 JUDGE KOHL: Do you have anything further to add 4 by way of other Staff guidance or legislative history on that 5 matter other than just the logical inferences that you asked 6 us to draw and the wording of the passage itself? 7 MR. BACHMANN: I cannot cite any legislative history, 8 but I can tell you that it is on the advice of the technical 0 staff of the NRC that I make these statements. We have a 10 number of people who are involved in applying these criteria, 11 and I discussed it with them; and they say yes, a water 12 makeup line in general can be considered a physical system to 13 prevent criticality under certain circumstances. 14 The point I'm trying to make there is that General 15 Design Criterion 61 precludes the significant loss of coolant 16 inventory. Where the conditions do exist as postulated by 17 the Licensing Board, the Licensee would be in violation of a

Commission regulation, and we would not grant the license

amendment. Therefore, they are being asked to do calculations

and analyses in a situation that would preclude getting the

amendment to rewrite the spent fuel pool. It is not logical

to ask them to postulate conditions we would not permit to

28

24 exist.

25

JUDGE KOHL: In other words, if you're in compliance

12

13

14

15

16

17

18

21

22

23

24

25

with Design Criterion 61, you cannot have the scenario that 1 was postulated by the Licensing Board. 2 MR. BACHMANN: Exactly, exactly. The Staff also 3 went on to argue and support as a secondary argument to support A our first argument that the conditions postulated for 0.95 = neutron multiplication factor is supposed to be with a full 6 pool, and this also goes back to General Design Criterion 61. 7 You are not allowed not to have a full pool by our regulations. 8 JUDGE KOHL: By a full pool you mean full of water? 9 MR. BACHMANN: Yes. I cannot cite you the exact 10

page, but there are at least two occasions in the initial decision the Licensing Board stated that this low density water condition could only occur were there to be almost a total loss of water in the pool.

JUDGE MOORE: Is it your argument then that the Licensing Board has posited an incredible scenario, and it shouldn't have?

MR. BACHMANN: Yes, sir. Exactly.

JUDGE KOHL: Is it incredible giving credit to the makeup line?

MR. BACHMANN: Yes.

JUDGE KOHL: Or is it incredible without giving credit to the makeup line, since I believe your analysis -the SER, and Mr. Blanchard, I believe, in his statement did say there were analyses done taking account of the fact that



.

1

2

3

4

5

6

7

8

0

10

11

12

15

16

17

18

19

20

21

22

23

24

there would be no makeup line. The analyses were done to show what amount of makeup would be necessary to prevent this from happening.

MR. BACHMANN: Let me backtrack for just a second. The General Design Criterion 61 says you will not have significant loss of coolant inventory. That is primarily designed to make sure they do not uncover the fuel and cause a fuel melt and therefore a release of fission products. That is the primary purpose of it. That's the reason why before I said we did not agree with the Licensee on the strong interplay between 61 and 62. You keep the pool full of water so you don't melt the fuel.

The secondary benefit of that is it helps prevent criticality.

Now, were there not a makeup line -- I also must go back again. Sixty-one says the pool must be designed under normal and accident conditions. Now, the accident condition we are considering is the loss of the cooling system. If the cooling system is lost, then there is no access into the containment under an accident condition, which is a credible scenario, then how do you prevent the bad effects of what happens in the pool?

Well, you then must come up with something -- and the Licensee has proposed a remotely activated water makeup line. This would keep the pool full, assuming that you lost

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA



25

31

the cooling system and there was boiling in the pool and you 1 were losing water, you must make that up and keep the pool 2 full. As a secondary benefit it keeps the pool full and pre-3 vents the scenario the Licensing Board postulated for which 4 criticality must be calculated. 5 Did I lose anyone on that one? 6 Our second phase of our argument is the misapplication 7 of the Staff guidance. The Board is not bound by using Staff A guidance, but they chose to "rigorously" apply it. If you 9 go back through the Standard Review Plan, as Mr. Gallo alluded 10 to, it says we will apply American Nuclear Standard 57.2, 11 0.95 with a pool flooded with unborated water. 12 Those are the conditions. If one chooses to apply 13 this guidance, one should apply all of the guidance; and this 14 test considers this a second source of error by the Licensing 15 Board. 16 JUDGE KOHL: Counsel, I have a question about the 17 Standard Review Plan. 18 Back in Part 2 under "Acceptance Criteria" where 19 it refers to General Design Criteria 61 and 62, for example, 20 in the part relating to Criterion 62, it says, "Acceptance 21 for meeting this criterion is based on conformance to positions 22 C-1 and C-4 of Reg Guide 1.13 and the appropriate paragraphs 23 of ANS 57.2." 24 Turning to Reg Guide 1.13, the two reference sections

C-1 and C-4 refer to the fact that the facility should be 1 designed to Category 1 seismic requirements and that the 2 concrolled leakage building should enclose the fuel pool. 3 Point C-8 is the one that refers to makeup systems 1 and makeup lines. 5 Can we infer anything from the fact that the Standard 6 Review Plan does not refer to C-8, the makeup line provision? 7 Is that a significant provision in the Standard Review Plan? 8 Does it have any significance? What does that tell us about 0 these documents? 10 MR. BACHMANN: I would say it's an omission but 11 not significant. In fact, I had the exact same question of 12 the technical staff myself. It just simply did not get put 13 in there. 14 JUDGE KOHL: Can you elaborate on what was meant 15 by the appropriate paragraphs of ANS 57.2? Is there any 16 further elaboration other than the entire ANS document? 17 MR. BACHMANN: Yes, Judge. If you will look at 18 page 11 of our brief where we specifically zeroed in on the 19 end tp 2 20 particular paragraph of ANS 57.2. 21 22 23 24 25

32

3-joy-1

1

2

3

JUDGE KOHL: You are referring to the requirement that the calculations are done on the basis of a fully-flooded pool.

MR. BACHMANN: Yes, ma'am. I cannot emphasize too strongly the fact that the Board chose to apply Staff guidance as applicable law in this decision and then seems to have selectively picked parts of it and then not applied all of it. It is basically the Staff's position as its second argument that if you are going to use our guidance, use it properly.

JUDGE KOHL: Do you agree with Mr. Gallo's explanation my question on the Branch technical position and the references in there to the loss of all pool cooling systems and flow and the excessive loss of water? I think his explanation was that is talking about a loss of the system itself as opposed to the coolant.

Does the Staff agree with that interpretation of its own document?

MR. BACHMANN: Yes, we do to the extent that the 18 makeup line is proposed under the accident condition of loss 19 of coolant and therefore that is the reason -- in other words, 20 the accident we are looking at is loss of coolant, How do you 21 prevent bad things happening if you have loss of coolant? You 22 propose a makeup line. And if indeed that makeup line proves 23 adequate to prevent the significant loss of coolant inventory 24 as required by General Design Criterion 61, then they will 25

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

33

3-joy-2

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

19

fill that and the scenario postulated by the Licensing Board could not exist.

JUDGE KOHL: Now, the various references in the different Staff papers that refer to "under all conditions, under all certainties at all times," et cetera, you again would say that that is limited by the Reg Guide 1.13 and Standard Review Plan that says that you are talking about a fully-flooded spent fuel pool; that that is the basic starting point from which you do these calculations and from which you must apply all other Staff guidance, interpretations, whatever?

MR. BACHMANN: Exactly. In fact, I might point out that the Standard Review Plan does take precedence over a branch technical position and an SER, Safety Evaluation Report. A Standard Review Plan is more binding, shall we say, than these other letters that have been forwarded.

JUDGE KOHL: I thought the SER was plant-specific. That is a piece of evidence in this case, is it not? It was 18 prepared specifically for the spent fuel pool. Wouldn't that have a higher level? The Standard Review Plan just tells the 20 Staff how to go about doing an SER and other analyses. 21

MR. BACHMANN: When the Staff does a plant-specific 22 review, it will of necessity paraphrase other guidance that 23 it has, and rather than repeat all of the words of the 24 Standard Review Plan, certain phrases were chosen. Perhaps 25

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

34
3-joy-31

2

3

4

5

6

we did not choose the right phrases and thus the Licensing Board may have been a bit confused.

JUDGE KOHL: So when the SER says under all conditions, we refer back to the generic Staff guidance that exists at all times for our interpretation of what "under all conditions" means.

MR. BACHMANN: That is correct. That is correct. 7 I have just one more point, and that is I would 8 like to address something that Mr. Gallo said earlier, and that 9 is about dismissing the contention. It is still the Staff's 10 position that while the Licensee need not perform the calcu-11 lations given, what we consider incredible conditions, we have 12 not yet litigated this. The Staff cannot say that this con-13 tention should be just dismissed until such time as we are 14 assured that the makeup line is adequate to give us this full 15 pool and the 0.95. 16

I might add that it is probably a very good inference
that the Licensing Board, had they found the makeup line
adequate and had they determined that the pool would remain
full, would have found that K_{eff} would remain below 0.95.
But we have not yet litigated the makeup line. We did
litigate it but the Licensee withdrew its proposal, and it
still had to be heard in an open public hearing.

JUDGE KOHL: When are those further hearings scheduled, or are they yet?

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

3-joy-4

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

MR. BACHMANN: Our best estimate is sometime this summer at this point, but we would ask this Appeal Board to vacate the order making the Licensee perform these calculations under conditions of extremely low water density, what the Staff considers incredible conditions but remand back to the Licensing Board until such time as the makeup line has been litigated and we can determine the conditions under which these calculations must be done if these calculations are required.

JUDGE BUCK: The Licensing Board seems to place a great deal of weight on one of the Intervenor's exhibits, the supercriticality through optimum moderation of nuclear fuel. Do you have any comments on the comparability of the type of fuel element that was being studied in that paper as compared to the Big Rock fuel elements?

MR. BACHMANN: I can only tell you, since I am not an engineer but a lawyer, the advice I have gotten from my technical staff is that the type of fuel element is somewhat -is it somewhat analogous to -- excuse me, sir.

MR. EMCH: There were some differences in general. Lantz felt that what was presented in this article was not a departure from the Staff method. He agreed with it.

MR. BACHMANN: Yes, that's the best of my recollection of what I was told, that they were similar enough but that at the same time, through some form of calculation,

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

3-joy-5 1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

whatever, our technical advisers have said this article supports the Staff's position. They did some interpolation with the graphs given there and came out with the fact that there was no problem, assuming the pool was full.

JUDGE BUCK: On the basis of it, the supercriticality experiments were done with much larger fuel elements and a lot higher loadings, so you would have to interpolate down on loading and size to come down to a comparable fuel element to the Big Rock, as I see it; but I don't think the Licensing Board did that. That is what is bothering me.

MR. BACHMANN: Well, we had done it when we presented our testimony. The Licensing Board chose not to accept the Staff's testimony so I have not pursued that any further, but we are just arguing on what they have done here. JUDGE BUCK: Thank you.

JUDGE KOHL: I thought one reason the Board didn't accept the Staff's testimony was that the calculations had been done for a different type of fuel than was used at Big Rock. Wasn't there some reference to the fact -- I think it was Mr. Lantz' calculations were done -- do you recall the section of the Licensing Board's --

MR. BACHMANN: I do recall that. We did not pursue that any further on this basis. The Licensing Board by its own admission adopted Mr. Gallo's findings of fact virtually verbatim and then drew different conclusions. Since they did

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

3-joy-6

3

2

3

4

5

6

7

8

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

not accept the Staff's testimony, we did not pursue our theory any further than that. I can't tell you any more than that. We were willing to adopt the testimony in findings that the Licensee submitted, and we did not pursue that any further.

JUDGE KOHL: Does it matter for purposes of the supercriticality article that Dr. Buck referred to that this is a mixed oxide fuel? Isn't that what Big Rock is?

9 MR. BACHMANN: May I consult with my technical 10 person?

MR. EMCH: They had not in recent years loaded any mixed oxide fuel. There may still be some mixed -- there may possibly be some mixed oxide fuel left in the reactor, and there certainly is some left in the pool, but they do not -they are getting ready to go down for refueling soon and they won't be loading mixed oxide fuel. They didn't last time.

MR. BACHMANN: Does that answer your question? JUDGE KOHL: Yes.

JUDUE BUCK: One other thing while you are standing there. The Board in its decision on page 14 makes the statement, "We cannot accept as a basis for safety assurance a technical review that starts with a questionable assumption (that changes in K_{eff} are density dominated) and reaches its conclusions from questionable inferences about a graphical analysis of data for a type fuel we are not considering."

3-joy-7

1

2

3

4

5

6

7

8

23

24

25

Do you know where in the evidence here the Licensing Board would have picked up the idea that the changes in K_{eff} are density dominated is a questionable assumption?

MR. BACHMANN: No, sir, I don't. I accepted that as the Staff's position. That was the testimony we filed. Mr. Lantz was cross-examined at the hearing on it. At no time until they had written this decision did I believe that they would consider that a questionable assumption.

JUDGE BUCK: I am a little puzzled by it because every diagram of the criticality function here is shown, including this Exhibit 5 here which shows the variation of criticality with the density of the water, as it should because you are relying on the hydrogen atoms to slow down your neutrons.

So I wondered if you knew whether somebody had given evidence to that effect. I didn't find it, but this statement came out in the decision.

MR. BACHMANN: Mr. Lantz' testimony -- this was a Staff witness at the hearing -- went specifically to the fact that reactivity is a function of water density. All I can suggest is perhaps Mr. Lantz was not a persuasive witness. That was the Staff testimony and it was not accepted.

JUDGE BUCK: Okay, thank you.

MR. BACHMANN: If you have no other questions, I will conclude at this point.



REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

40

1

,

SY/AR4/1

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

24

25

ORAL ARGUMENT BY HERBERT SEMMEL ON BEHALF OF INTERVENORS, CHRISTA-MARIA, MILLS & BEIR JUDGE MOORE: Proceed, Mr. Semmel.

MR. SEMMEL: I am going to take not more than 30 minutes, after which Mr. O'Neill will speak for not more than the balance of the time. I'd like to begin by just reminding us what this hearing is about.

There has been enormous fanfare here over a rather simple question of whether the licensee has to perform a study which the Licensing Board thought was necessary to determine the safety of this pool; a study which is not terribly difficult to perform, not terribly time consuming, and in view of the expense that has been undertaken in this proceeding, is not relatively expensive.

There were varying estimates as to how long it might take to complete this study. For example, in the deposition of Mr. Brooks, one of the staff experts that was deposed in late December and early January of this year, he estimated that if certain data was already available on computer cards, that the study could be completed in two weeks.

There was other testimony during the hearing that it might take two months, and Mr. Brooks said someone thought it might even take six months.

> MR. GALLO: Excuse me, I am going to object. JUDGE MOORE: Mr. Gallo, this is an oral argument

> > TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1

2

3

4

5

6

7

8

9

10

11

12

13

•

at the appellate level, and your objection would be out of order. We are listening to Mr. Semmel's presentation. You have your rebuttal time, we will hear from you then.

MR. GALLO: All right, I apologize to the Board. MR. SEMMEL: Whatever the time limit, it is also worth noting to put this all in context that the Board's order was in October; it is now March, five months later. Had the licensee prepared this report we probably would have had it now under the worst of circumstances. The expense of preparing the report I doubt would exceed the expense that has gone into this appeal in which, for example, not only do we have all of the counsel time, the licensee has flown in one attorney from Chicago --

JUDGE KOHL: Mr.Semmel, hasn't all this delay 14 15 worked to the detriment of the applicant in this case? I'm not sure that the argument that you're pursuing here is 16 17 a proper basis for us to make a decision. We do have an appeal before us. The applicant had a right of appeal. It 18 may have been a bad judgment in your view, strategically and 19 otherwise, to take the appeal, but nonetheless, it is before 20 us. I think we have to decide it on the basis of the law 21 and the record that was developed below. 22

MR. SEMMEL: I agree with that, but I think it's
relevant to the interpretation of various legal provisions
to the discretion of the Licensing Board in this case.

JUDGE KOHL: Was this a decision that was made in 1 the Licensing Board's discretion? I thought the Licensing 2 Board felt it was obliged by various staff documents to order 3 the analysis that it did. 4 MR. SEMMEL: Well, we would submit that the Licensing Board was, in fact, so obliged, bu: also, that this is well 6 within the discretion of the Licensing Board. 7 JUDGE KOHL: Why was it obliged to do that? Let's 8 focus on that aspect of the Reg Guides and Standard Review 9 Plan, et cetera, that says that criticality calculations shall 10 be done for a fully flooded pool. Now, given that as the 11 basic starting point, how can there ever be a requirement 12 that you do analyses for criticality on the assumption that 13 the coolant has completely boiled off, or at least substan-14 tially boiled off? 15 MR. SEMMEL: First, let me located General Design 16 Criterion 62 which says criticality shall be prevented by 17 physical systems or processes, preferably by use of 18 geometrically safe configurations. 19 JUDGE KOHL: Is a remotely-controlled makeup line 20 a physical system? 21 MR. SEMMEL: We would content that that is not what 22 is referred to as a physical system. 23 JUDGE KOHL: We heard from Mr. Gallo and Mr. Bachmann 24 as to what they think that means. What is your interpretation 25

43

.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

of that?

MR. SEMMEL: The physical system is the normal cooling systems of the type that is in effect, but which requires access to the containment in this particular plant, because the spent fuel pool is within containment. And so, postulating an accident that would deny access to containment, that physical system would fail or might fail.

What the Licensing Board wanted to know is what happens if you have that kind of failure. But what I want to draw your attention to is the end of General Design Criterion 62 which says that the criticality shall be prevented by physical systems or processes, preferably by use of geometrically safe configurations, and that's why I submit it was within the discretion of the Licensing Board to simply ask that the licensee get them information about the route which the general design criteria says is preferable.

They want to know what would happen, based on geometrically safe configurations, in the event of loss of coolant because then they can determine whether that loss of coolant is a situation that has to be taken into account. It may affect a number of considerations including the extent of reliability of the makeup line.

JUDGE BUCK: Is it your contention that this is not a safe configuration?

MR. SEMMEL: It is not a safe configuration if

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1 super-criticality could be reached in the event of a loss 2 of coolant. 3 JUDGE BUCK: But it is a safe configuration if the 4 pool is full of coolant; is that correct? 5 MR. SEMMEL: Our position is that the configuration 6 is not safe even if it's full. That is, it has not been 7 demonstrated because of what we argued at the hearing were 8 non-conservative assumptions that were made by Dr. Kim in 9 his testimony. That is not an issue here, and we did not --10 JUDGE BUCK: If you're arguing that we don't have 11 a safe configuration, I'd like to know on what basis you're 12 arguing that this is not a safe configuration. First of all, with a full pool, and secondly, what are the deficiencies. 13 14 MR. SEMMEL: In the original testimony -- excuse me. 15 In the original application, Dr. Kim made calculations based on a steam void which extended the full length of the fuel. 16 After the denial of summary disposition when the Board also 17 indicated that it wanted the temperature used in the calcula-18 tions increased from 212° to the Board's suggestion of 243°, 19 Dr. Kim recalculated, and in those recalculations only used 20 a figure for steam void at the top guarter inch of the fuel. 21 And also, only used average temperature between the bottom 22 of the pool, which would be -- they postulated 2120 and 23 the highest temperature at boiling, which would be 243°, and 24 25 we submitted that both of those were non-conservative

45

assumptions and that the higher figure should have been used. 1 2 If you use the higher figures, the calculation comes to 3 greater than 0.95. 4 Now, as you may recall, when we opposed hearing this case at this time we mentioned there were issues --5 JUDGE MOORE: Mr. Semmel, can you tell me how it 6 would exceed 0.95 if you're talking about spent fuel now and 7 only spent fuel could boil water, and the reactivity of the 8 spent fuel is less than the new fuel? 9 MR. SEMMEL: Let me answer you in this way because 10 I'm not an expert on this, but the calculation that was 11 submitted in the final testimony by Dr. Kim was slightly 12 just -- I forget the exact figure, but it was just slightly 13 below 0.95. Computing the steam void at a lower value than 14 he had done previously when he computed for the entire length 15 of the rod. 16 JUDGE KOHI .: That was based, though, on the 17 evidence, as I understand it, that there would not be a steam 18 void the entire length of the rod but rather, it only 19 extended for the top -- I think it was .276 inches -- at 20 the very top. And, therefore, his calculations were 21 assertedly more accurate as recomputed. 22 MR. SEMMEL: That was his position, but our 23 position was that he indicated clearly what he regarded as 24 a conservative calculation when he did it the first time, and 25

46

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

it was only when it became clear that if you increase the temperature and you kept the fuel constant you would be going above 0.95 that the licensee determined that it was sufficiently conservative and described it as over-conservative.

JUDGE BUCK: I'm not sure the evidence says that, because as I recall it, first of all, Dr. Kim was making the conservative assumption that this was fresh fuel in there; not only fresh fuel, it was higher in uranium content than the fuel that was going to be used at Big Rock. And with those figures and the 212 or whatever the temperature used before he came out, as I recall, with a number of .946. Then when he changed his temperature, the temperature has some effect but not very much on the criticality, and he came up with exactly .95 on the basis that fresh fuel, which was greater enrichment than presently used.

Now, why are those calculations not conservative, even assuming now that we are looking at a situation which is not required, shall we say, in the rules that we have? Full pool water. That's assuming that we're getting the boiling. Why are those figures not correct?

MR. SEMMEL: Just so we're getting boiling.

JUDGE BUCK: I don't know how you can get boiling with the fresh fuel which he calculated. So am I asking 23 why, under those circumstances, you come out with .95 with 24 fresh fuel in using a greater concentration of uranium than 25

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1

2

14

15

16

17

18

19

20

25

•

Big Rock does. Why is that figure not very conservative when the pool itself is going to be filled with used fuel?

MR. SEMMEL: It may be conservative in the sense of different fuel. However, the guidelines first require the calculations to be conservative, use fresh fuel, and secondly, that you must take into account steam voiding if it will exist. And the calculation only took into steam voiding in a way which we believe is not conservative.

Now, in fact, when this is all over we do intend to move to reopen on this point because we have now obtained what we think is additional evidence through these depositions that calculating steam void only at the top was a nonconservative calculation.

But it was my understanding that that was not an issue in this appeal, that the Board ruled that we could not appeal since we had prevailed, and therefore, we did not ask the Board to hear this matter at this time. And indeed, now we think it would preferable if we could make a complete record on this point and the conservatism of the steam void calculation.

JUDGE KOHL: Counsel, let's focus on what I think is the critical issue here -- no pun intended -- and that is whether or not credit may be taken for the engineered safety feature, the remote-controlled makeup line

I take it your position is that it cannot; that

that is not even permitted under staff guidance.

1

2

3

4

5

6

7

8

9

11

17

18

20

21

22

23

24

25

MR. SEMMEL: That's correct.

JUDGE MOORE: Excuse me, counsel. If that's your position then how do you arrive at your position that one has to calculate "eff taking into account steam voids? Because it would seem to me one is the left glove and one is the right glove.

So when you answer Judge Kohl's question would you then follow and answer mine?

10 MR. SEMMEL: The question of steam void was used --I think it's a different issue, but the question of steam 12 void was used in the calculation postulating boiling, but not necessarily boil-off. The calculation that was not made 13 14 here and which the Board simply wanted was what happens if 15 you have a situation where the water boils down below the level of the fuel roas. 16

The calculation that we were talking about and that was discussed in the testimony was steam void assuming the pool reaches boiling, but the pool still remains full. 19 You haven't had any boiling there as yet, and that was the difference in the calculation there. The makeup water line doesn't come into play until the pool begins to boil down. Until some water has left the pool you can't put anymore water in it, if the pumping system is not working.

JUDGE KOHL: Let me restate my question again.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

For purposes of the scenario that you posit, why can't we take account of an engineered safety feature when engineered safety features are taken account of for other postulated accidents considered for purposes of the criticality calculations?

MR. SEMMEL: First, there's sort of a formal matter that the Grimes memo -- which is the staff guidance here -- specifically spoke about taking into account all uncertainties under all conditions.

JUDGE KOHL: But the prefatory letter on that branch technical position states that this guidance is really a compilation in a single document of the pertinent portions of other applicable references, the Standard Review Plan, Reg Guides, et cetera, that are needed in addressing spent fuel pool modifications. No additional regulatory requirements are imposed or implied by this document.

Where, in addition, then, to the branch technical position do you find support for the fact that under all conditions means a spent fuel pool that has had substantial or complete boil-off?

MR. SEMMEL: I'm not sure if it's actually contained in any of the previous regulations or rulings, but it's not precluded by anything else. I mean, there is the possibility here that you would have a TMI type accident which prevents access to the containment, and then even if

1 there was a makeup water line that the makeup water line 2 might not operate under those circumstances. 3 JUDGE KOHL: Well, that is a function of the 4 reliability, though. If the reliability of the makeup line 5 is established, in your view is there any need, then, to 6 perform the criticality analyses that you request? 7 MR. SEMMEL: Yes, because reliability is just a 8 relative matter; it doesn't mean that it's not possible for these two events to occur at once. It simply means that the 9 chances of the two events occurring and of the water line not 10 11 functioning is substantially decreased, but that it is still a possibility. 12 JUDGE BUCK: Well, let's assume that you had a 13 TMI-II type accident and you did not have your water line. 14 One of the safeguards that is used against an accident such 15 as this is the containment spray, and in this case, you'd 16 probably be using the containment spray for the TMI-II accident, 17 and that overhangs the pool and goes into the pool -- part of 18 that spray goes into the pool as well as into the containment. 19 So that safeguard would prevent you from boiling off, would 20 it not? 21 MR. SEMMEL: I must confess that I'm not sure. I 22 don't understand --23 JUDGE BUCK: The point I'm trying to make here is 24

51

25

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

there are engineered safeguards for all kinds of accidents,

and these are required. They are not considered in looking 1 at whether the accident can happen or something like that; 2 they just say if it happens, this is what we've got to do, and 3 you put in an engineered safeguard. I don't see that a line 4 that is being proposed by the applicant here, which is 5 controlled from outside the building, as I understand from 6 a separate water source and all that sort of thing, does not 7 require building power or anything of that nature to turn it 8 on, is nothing more than a safeguard similar to all the other 9 safeguards that we have in a nuclear reactor. And I think 10 this is what Judge Kohl was asking. 11

MR. SEMMEL: I can't answer about the sprays, but --12 JUDGE KOHL: What about the point along the same 13 lines -- I'm sorry to interrupt, but maybe we can focus 14 this discussion a little better. Mr. Gallo in his brief, I 15 believe, refers to one of the postulated accidents that 16 should be considered for criticality purposes, and that is 17 the cask drop, and one of the -- Reg Guide 1.13 describes 18 several mechanisms that can prevent, or that you can use to 19 mitigate the effects or, indeed, prevent such an accident 20 from occurring. They may be considered engineered safety 21 features. 22

Can we not analogize to this situation focusing
on the accident scenario that you postulate, and that is
pool boil-off. Isn't there a relevant comparison here

2

3

4

5

6

7

8

9

10

11

between the engineered safety features designed to prevent dropping of a heavy load and engineered safety features of a remotely-controlled makeup line designed to prevent boiloff? MR. SEMMEL: There is some similarity. JUDGE KOHL: Isn't it more than a similarity, though? We're talking about the very same general matter,

and that is calculation of criticality in the neutron multiplication factor. What's the difference? Why is it okay to consider one engineered safety feature for one type of postulated accident but not to consider a different engineered safety feature for a different postulated accident?

MR. SEMMEL: Well, I would, for one thing, suggest that perhaps when those regulations were drawn, that there was a greater degree of confidence for one reason or another in certain kinds of safety engineering features. I think it is much simpler to provide nets and double-failure safety features to prevent a cask drop than to provide this makeup water line.

This makeup water line comes into the plant and runs all around the plant, through the reactor and ends up in the pool.

JUDGE BUCK: But easy or not easy, it's an allowable feature, is it not?

24 MR. SEMMEL: The safety features for the cask are25 allowable; it's been specifically stated they're allowable.

1

2

3

4

5

I would draw the opposite inference; namely, that by not discussing a makeup water line in the context of criticality and discussing it in other areas, that it was simply not intended that that that would be a sufficient engineering feature.

JUDGE KOHL: Perhaps it was not discussed because 6 the basis for calculating criticality assumed a fully flooded 7 pool. If you're assuming the same guidance says that when 8 you do the criticality calculations you must assume a fully 9 flooded pool with unborated water, if that's your basic assump-10 tion, then there's no need, is there, to consider a makeup 11 line? There would have been no purpose in mentioning it in 12 that context. 13

MR. SEMMEL: That may be true, that may be the reason why they left it out. You know, I can't speculate on that. But I think that --

JUDGE KOHL: Well, it is important, though, because the Licensing Board was relying on the various staff documents for its finding that these additional analyses were, indeed, required.

MR. SEMMEL: The Grimes memo -- the branch technical position was fairly clear. I think they were perfectly right. It says including all uncertainties under all conditions, and there is an uncertainty -- if there is an accident which prevents access to the containment where the

1

2

3

4

5

6

7

8

9

10

25

pool is and for one reason or another the makeup line is also not operative, it seems to me that the Licensing Board was correct. They said let's have the information, let's find out what happens. Maybe nothing happens, maybe it doesn't become critical even under those circumstances. But we're simply entitled to that information. We're entitled to present expert testimony on the subject as intervenors, and then the Board can make its decision based on that information. JUDGE KOHL: Did you present any expert witnesses on this matter before the Licensing Board?

MR. SEMMEL: We did not present any witnesses on this matter before the Licensing Board. There was, in fact, no real testimony because the calculations had never been made as to what would happen under these circumstances.

The other point I want to get back to, though, 15 which I think also raises it in terms of this particular case, 16 is that the General Design Criterion 62 says that criticality 17 shall be prevented by physical systems or processes, preferably 18 by use of geometrically safe configurations. And that would 19 be within the discretion of the Licensing Board to give 20 consideration to that preference and to see whether in the 21 event of loss of coolant the criticality would be achieved or 22 not achieved or reached simply by geometrically safe configura-23 tions with partial or substantial loss of coolant. 24

And so, under that criteria, the Board would have

4

5

6

7

8

9

10

11

12

13

14

15

17

the right to ask for that information. Whether --If they did it for some other reason, which I would submit is correct, but even if you disagreed with it, they should be allowed to request that information under General Design Criterion 62.

JUDGE KOHL: Mr. Semmel, what about the argument that staff counsel makes; that is, that General Design Criterion 61 requires the prevention of a significant reduction in coolant inventory under accident conditions? He argues that if the applicant or licensee is in compliance with that design criterion, then the scenario that you postulate simply cannot happen. And for that reason, performing the analysis is really an unnecessary and redundant exercise.

MR. SEMMEL: Well, in that case, to a certain extent, what it really means is that you can never take into account an accident in applying General Design Criterion 62 16 because the Board --

JUDGE KOHL: No, a specific accident. We're not 18 talking about any accident; we're talking about the accident 19 that you postulate and the Licensing Board focused on, and 20 it was a loss of significant coolant inventory. 21

MR. SEMMEL: It would mean you could never take 22 into account significant loss of coolant inventory under 23 General Design Criterion 62 simply because 61 says you've 24 got to prevent certain kinds of accidents or mitigate the 25

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

•

effects of certain kinds of accidents.

JUDGE KOHL: Doesn't the one thing follow from the other, though, logically? If you really are in compliance and assume for purposes of this that the plant is able to meet and to prove compliance with that criterion, then logically, that isn't the kind of criticality accident that General Design Criterion 62 is focusing on. It might be another type of criticality accident but it's not one that is a result of a loss of coolant.

MR. SEMMEL: Well, we would still submit that the question of the reliability of the makeup water line in preventing a loss of coolant still is different than the question of what would happen in the event that that fails. There's no system that is absolutely fail proof. All they are is saying we are making reliable to a certain degree.

JUDGE KOHL: But I said for purposes of my question, assume that it's reliable.

MR. SEMMEL: Assuming it's reliable within Design 18 Criterion 61, I would still submit that 62 says let's take 19 a look and see whether you can meet the criticality require-20 ments in the event that one of those so-called reliable 21 safeguards still, nevertheless, fails, because there's always 22 the possibility of failure even though they're deemed to 23 be reliable. There's no suggestion that reliable means 24 100 percent perfection. Otherwise, nothing would ever be 25

	1	reliable. And so 62 is looking at that and what would happen
•	2	in the event of a failure with those contingencies.
nd Tp4	3	
	4	
	5	
	6	
	7	
	8	
	9	
	10	
	11	
	12	
•	13	
	14	
	15	
	16	
	17	
	18	
	19	
	20	
	21	
	22	
	23	
•	24	
	25	
		TAYLOE ASSOCIATES

REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

Riley Tape 5 3-24 Connelly 1

5

6

7

R

0

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



MR. SEMMEL: We question that. If the pool began to boil -- if the pool began to boil, we question whether or not the pool could become critical even though the water had not boiled down below the level of the rods. That is what I was referring to before when I said there was a dispute at the hearing over the conservatisms of the calculations postulating a full pool but at 212 degrees at the surface.

JUDGE BUCK: All right. But assuming boiling, your curves that are shown in this exhibit of yours, I believe it is, indicate that if you are overmoderated, as this pool is, your k_{eff} will go up to a point and then go down again.

In the calculations that I remember that come from Dr. Kim is that the density of the water which would have the highest k_{eff} would be a density of somewhere around .98, I think it was, or something of that order.

Do you agree with that?

MR. SEMMEL: I think that's my recollection, yes. JUDGE BUCK: So that it would go up from a full density of the water, and the k_{eff} would go up until the water got to a density now of .98 or thereabouts, and then it would

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1	tend to go back down again. Do you agree with that?
2	MR. SEMMEL: The keff would go back down again?
з	JUDGE BUCK: Yes.
4	MR. SEMMEL: No, that wasn't my understanding. My
5	understanding was that the k _{eff} might increase up to a density
6	of .5.
7	JUDGE BUCK: Where do you get that?
8	MR. SEMMEL: I can't tell you where I get that right
9	now, but it seemed to me that the chart, Figure 1 on page 13A
10	of the Board's decision, indicates k _{eff} rising between 0 and
11	.4 actually, not 0, but there is a dip. It starts at 1,
12	goes up at .98 as you indicate. It then slightly goes down
13	and starts going up again somewhere around 20 percent void.
14	As the Board indicated, this was only the first six calculations.
15	JUDGE BUCK: Well, the points up above there show
16	the high peak of this thing at well, they don't go below
17	.5 on this; that's the problem. If you look at your exhibit,
18	your 5, all of your curves there, if you compare them and
19	put them down to the same spacing in the same fuel level as
20	Big Rock rather than what you have in this particular experiment
21	there, they would come down and agree pretty well with Dr.
22	Kim, somewhere between .9 and 1.
23	MR. SEMMEL: Actually, I believe that this exhibit
24	that we are referring to was prepared by Dr. Kim.
25	JUDGE BUCK: Was what?
1	

MR. SEMMEL: Was prepared by Dr. Kim. We put in 1 testimony on certain of Dr. Kim's calculations. 2 JUDGE BUCK: I'm talking about this supercriticality 3 paper here that I think was your exhibit. 4 MR. SEMMEL: Are you referring to Exhibit Intervenor's 5 JUDGE KOHL: He's referring to the article by 6 Cano, Caro, Martinez-Val. 7 MR. SEMMEL: The Figure 1 here on page --8 which is indicated on the next page, was a calculation by 9 Dr. Kim. In the middle of the next page it says Dr. Kim did 10 similar calculations from G-3 fuel. 11 JUDGE BUCK: This is Dr. Lantz's calculation actually. 12 MR. SEMMEL: You're talking about Mr. Lantz's 13 calculation, Exhibit 5. But, you see, there's just a typo-14 graphical mistake there because it says here the numbers 15 apparently came from work by Dr. Kim, presented graphically 16 at page 133 of Intervenor's Exhibit 5, see Figure 1. Figure 1 17 comes from the calculations made by Dr. Kim, and then the 18 Board added to that. 19 JUDGE MOORE: Mr. Semmel, your time is up. 20 JUDGE KOHL: The Board superimposed the darker 21 triangle, and it was to represent Mr. Lantz's testimony, and 22 the circles below represent the exhibit as it was originally 23

61

prepared by Dr. Kim.

24

25

MR. SEMMEL: That's my understanding.

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

sc 3

Thank you very much. 1 JUDGE KOHL: I have one question about the super-2 criticality article. Was that ever introduced into evidence? 3 MR. SEMMEL: I actually don't recall it being 4 introduced into evidence. It was used on the motion for 15 summary disposition, but I cannot state for certain whether 6 it was ever actually introduced into evidence at the hearing. 7 JUDGE KOHL: Thank you. 8 ORAL ARGUMENT BY JOHN O'NEILL, II 9 ON BEHALF OF HIMSELF 10 MR. O'NEILL: Good morning. 1.1 I would like to treat one item that seems to trouble 12 the Board quite a bit, and then revert to my prepared statements 13 and kind of flesh those out in the statement. 14 The Board has asked over and over again can credit 15 be taken for the makeup line, and I believe there are five 16 reasons why credit cannot be taken for the makeup line. 17 First of all, we have to look at the precedent that 18 was cited by Consumers Power. These are the cases on evacua-19 tion in which environmentally-qualified systems are assumed 20 to fail and analyses even in light of that are made. 21 The second is the makeup line itself may not be 22 able to be proven to be reliable. The makeup line is dependent 23 upon the emergency core cooling system, and the emergency 24 core cooling system has several lifetime exemptions from single 25 TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS

62

NORFOLK, VIRGINIA

2

3

4

5

6

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

failure criteria. Also, there may be conditions that could occur the makeup line could not remedy, such as failure of the concrete due to thermal stresses, as outlined in the testimony of Mr. Herring, a Staff witness.

Third, even if the makeup line does fail, even if it is considered single failure-proof, there is no remedy. The pool is not accessible. That's a very important point. And 7 that principle of accessibility was the main principle on which the Zion Board made its decision.

Four, the reg guides say that criticality should be looked at under all conditions. And, five, the regulations themselves say that criticality shall be prevented, preferably by geometry. You have to have a strong burden of proof to go beyond that requirement of preferably the geometric configuration.

JUDGE KOHL: What about this specific inc.dent or scenario or discussion in Mr. Gallo's brief about the fact that an engineered safety feature can be taken into account to prevent criticality occurring from the dropping of a heavy load?

I ask you the same question I asked Mr. Semmel: Why can't a different engineered safety feature, i.e., the remotely controlled makeup line, be used in the same way here to present the scenario that you postulated -- the loss of pool coolant?

14

15

16

17

18

19

20

21

22

23

24

25

MR. O'NEILL: That's a good question, and I think 1 I dealt with that quite convincingly on pages 18 through 21 of 2 my brief. The differences are if the cask drop were to fail, 3 I don't think there have been any scenarios that indicate that A containment would then be accessible so that the workmen on 5 the scene could take action to remedy the situation.

JUDGE KOHL: What if that happened in the scenario 7 that you posited, though, a TMI-2 type incident? That, as I 8 understand it, is the basic starting point for your contention Q that if that happens, that's what makes the building accessible. 10 And over and above that incident, if you have another failure in the pool cooling system, that's when the problems begin, 12 as you see it. 13

Let's assume the same thing with the heavy load drop. Let's assume a pre-existing accident situation that makes the building inaccessible, and then you have that incident occur.

MR. O'NEILL: It would be impossible to operate the crane while the containment is inaccessible. The operator rides right along in the gantry crane, and that's within the containment, so I don't think that scenario could ever occur.

JUDGE KOHL: But you have a worse scenario. At least with remotely controlled makeup line, though, you can, assuming its reliability -- that could be operated to mitigate the effects of the loss of pool coolant scenario.

MR. O'NEILL: I'm afraid I don't understand.

JUDGE KOHL: I'm trying to understand the consistency and how we can take credit for engineered safety features, when can we do so and when can't we and why. I don't see much difference, frankly, between the remotely controlled makeup line as a mechanism to prevent the accident that you posit and the various mechanisms that can be used to prevent a different type of accident.

MR. O'NEILL: Well, I think there are about three criteria. 10

One is is there a remedy to the failure of the proposed system, so if the safety slings on the cask drop failed, is there a remedy. Well, there would be because the pool would be accessible. People would be in there.

Number two, what are the consequences of it failing? In an emergency evacuation if the environmentally qualified systems, which are considered incredible as far as failing, if they fail, what are the consequences?

Well, the consequences dictate that the area has to be evacuated or the site has to be a low density population site. I don't know -- well, to go on, concerning the possibility of a safety feature failing, Mr. Gallo cited the idea of the zircaloy/steam reaction; what would happen if the makeup line failed and the racks were uncovered.

Well, the zircaloy accident would only occur after

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

sc 7

1

2

3

4

5

7

8

9

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

2

3

4

55

6

7

A

9

10

11

12

13

14

15

18

19

20

21

22

25

about a month of boiling and only after the pool water came down to the level of the racks. I believe that's according to Blanchard's testimony, although I'm not sure.

But concerning criticality, significant questions begin to arise after the water level drops to only about four feet. The Board said according to a guess of Dr. Prelowitz, you could have significant steam void fractions anywhere from the point four feet below the normal level of the pooled water down to the level of the racks. So the significant questions exist very early on.

In extrapolating from the testimony, again I believe of Blanchard, I came up with the figure that after a TMI-type accident this water level could drop within about five and a half days, so that's a much more critical event. I think your criticality accident would happen before that.

JUDGE KOHL: But the racks are still covered in that situation.

MR. O'NEILL: Right. The pressure is just relieved enough so that steam bubbles form and exist along the --

JUDGE BUCK: Suppose the pool boils dry and gets down below the level of the elements. Would you still have criticality?

MR. O'NEILL: I think the Board wants to know. I don't know.

JUDGE BUCK: I'm asking you specifically if you have

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

fresh fuel, you store it dry, okay? Now we've got burned 1 fuel, a lot less radioactive -- a lot less reactive, I should 2 say. And if we boil out all the water, is there any possi-3 bility of criticality? 4 MR. O'NEILL: Well, I think --5 JUDGE BUCK: No. Don't you go and think. Is there 6 any possibility of it, because what enables criticality? 7 MR. O'NEILL: The neutrons. 8 JUDGE BUCK: Right. Neutron movement and what else? 9 What has to happen to the neutrons? 10 MR. O'NEILL: The speed of the neutrons. 11 JUDGE BUCK: What slows those neutrons down? 12 MR. O'NEILL: Water, boron, et cetera. 13 JUDGE BUCK: If you take all the water out, I'm 14 asking you can you have criticality? 15 MR. O'NEILL: I think there's a significant question 16 about that in the Board's mind. 17 JUDGE BUCK: I'd like to know on what basis. 18 MR. O'NEILL: Well, I'm not a criticality expert. 19 I also understand that the optimum moderating conditions are 20 mist conditions, not dry conditions. 21 JUDGE BUCK: All right. Let's assume we have 22 criticality as to what really happens in here. You have 23 criticality on parts of your rod. Is that right? You boil and 24 you get boiling. You have criticality. And then we heat those 25

68

, [rods up some more so you'll have more boiling. And you will
2	very rapidly empty that pool because you've got more heat in
3	there, so it will empty very rapidly.
4	As it empties, the void gets larger, and you get
	down to the dry condition where there is no criticality, so
5	what happens? Nothing, except your fuel will get overheated.
6	MR. O'NEILL: I think there's a Sandia report in
7	this article that was just discussed that significantly
8	questioned that, that there is significant question.
9	JUDGE BUCK: Of what? Of what? Significant question
10	of what?
11	MR O'NEILL: Of criticality occurring.
12	where puck. Suppose it does occur for a while. The
13	JUDGE BOCK: Suppose it does beeur ror a anner
14	point I'm getting at, as it boils diy do you maintain origon
15	cality?
16	MR. O'NEILL: I don't know if you would boil dry
17	before you had significant deformation of the rod assembly.
18	I just don't know.
19	JUDGE BUCK: Well, you're not going to get any more
20	significant deformation if you go through criticality and
21	then you dry out and then your criticality stops; then you're
	back to where you were before. If you don't have criticality,
22	all you do is you heat the fuel elements up.
23	MR. O'NEILL: Well, I'm saying while those conditions
24	

of mist exist you might have derormation of the racks. The

.

other thing is you mentioned the containment spray. Even 1 though the pool would be boiled away, you would still have 2 this containment spray raining down a certain amount of water. 3 I don't know how much. I think it's fairly moderate. 4 JUDGE BUCK: Only if you turn it on. 5 MR. O'NEILL: Well, I think as a result of a 6 reactor accident it would probably go on, wouldn't it? 7 JUDGE BUCK: Let's take a pool accident by itself 8 under the conditions we've got here. You don't have to turn 9 it on. You've got other water supplies, for example. Supposing 10 you don't turn it on? 11 MR. O'NEILL: Well, I think in a pool accident 12 itself it would be unlikely the containment would be isolated, 13 although it's possible; and therefore, you could make up 14 the water through a fire hose or something. 15 JUDGE BUCK: If you had broken fuel elements and 16 you were pushing radioactivity up there, wouldn't you have 17 to get out of the containment? 18 MR. O'NEILL: Right. It seems to me that if the 19 temperatures were high enough, you know, if you had that 20 criticality and the water was boiling, you could begin -- you 21 begin the questionable period --22 JUDGE BUCK: What questionable period? 23 MR. O'NEILL: According to Perlowitz's testimony. 24 Just to jump back for a second, you said Lantz's testimony 25 TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS

NORFOLK, VIRGINIA

			100
100	12	- 1	- 2
2	-		6

1	was thrown out because it said the criticality is based on
2	density. Well, I think the critical question
3	JUDGE BUCK: Wait a minute. Wait a minute. It was
4	thrown out?
5	MR. O'NEILL: It was disregarded by the Board.
6	JUDGE BUCK: Because he said what?
7	MR. O'NEILL: Because he said criticality is
в	dependent upon density.
9	JUDGE BUCK: Isn't it?
10	MR. O'NEILL: Yes. But the big question is what
11	are the temperatures and how do they affect density. I think
12	that's the main question.
13	JUDGE BUCK: How do they affect it?
14	MR. O'NEILL: As temperatures go up, steam voids
15	form.
16	JUDGE BUCK: All right. But what else does it
17	affect?
18	MR. O'NEILL: What does this temperature affect?
19	JUDGE BUCK: Yes. It also affects the neutron
20	velocity, too, doesn't it?
21	MR. O'NEILL: I defer to your judgment. But the
22	point is if the water drops to a level of three or four feet
23	below the top level of the pool, then you have this area
24	where the evidence does not substantiate saying that the
25	k _{eff} level is below .95. There's a real question about the
1	temperature of the water coming up to the bottom of the racks
----	---
2	and the steam void fractions, and so it's possible that you
3	could have boiling in those rods, significant boiling and
4	significant steam void fractions as you drop from the level
5	of four feet all the way down the bottom of the pool. And
6	that's the time that you would have this critical period;
7	that's the time we conservatively have to consider that
8	you have the steam void fractions that would cause criticality.
9	And that time would be about 25 days, and I think
10	that would be enough time to cause a serious problem with
11	criticality and meltdown, et cetera. But the real question
12	arises
13	JUDGE BUCK: I'm sorry. I missed your point, because
14	what time is 25 days?
15	MR. O'NEILL: According to the Blanchard testimony,
16	the boiling water would take 30 days for the water to enter
17	the pool down to the level of the racks, okay?
18	JUDGE BUCK: Okay.
19	MR. O'NEILL: I drew from that that in about five
20	and a half days the water level would drop about four feet
21	by calculating how much water was in the pool.
22	JUDGE BUCK: How far are you above the top of the
23	fuel elements at that point?
24	MR. O'NEILL: I believe you are about 25 feet or
25	so.
	TAYLOF ASSOCIATES

sc 14

1

15

16

17

18

JUDGE BUCK: Okay.

2 MR. O'NEILL: You have 25 feet, and then all the way 3 down to the bottom of the pool you have 25, maybe 30 feet of 4 water to boil away. And during that entire time you have a 5 question about the criticality of the rods, because you don't 6 know what the effect will be on the steam void fractions. So 7 you have to conservatively assume that that water will boil 8 on a significant portion of the racks for 25 feet -- I'm sorry --9 that whole level from four feet below the top level of the 10 peol down to the bottom of the pool. That would give you 11 about 25 days of boiling. To be conservative, you'd have to 12 consider 25 days of criticality, and that would be enough to form a gross distortion of the racks in significant 13 14 radioactive releases.

JUDGE BUCK: How are you going to change the temperature at the bottom of the pool? As long as you have 30 feet over the top of the rod, you're going to have cold water from the top flowing down to the bottom and being recycled.

MR. O'NEILL: Well, according to the testimony, sir,
the steam void fractions were in question once you drop four
feet below the level of the water, of the original water.
JUDGE BUCK: Do you know where in the testimony?
MR. O'NEILL: I can find it very quickly.
JUDGE BUCK: Don't do it now, but you can give it
to me later on.







ANN t.6 pat p.1

1

2

3

A

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25



are the rules in effect. The regulatory guides, according to the Gulf State Utilities Company, 6 NRC 760 1977, say that the regulatory guides are not regulations per se and are not entitled to be treated as such.

And skipping down a little bit, in other words, the guides set forth one, but not necessarily the only, method in which an applicant may choose to employ in order to conform to a regulatory standard. While the Staff will accept such a method, an applicant is not precluded from utilizing some other method which it can demonstrate is appropriate in the particular case. Nor are other parties precluded from demonstrating that the prescribed method is inadequate in the particular circumstances of this case.

JUDGE KOHL: Doesn't that cut against Mr. Semmel's argument then that because General Design Criterion 62 says that criticality shall be prevented preferably by geometrically safe configurations, when what you just read suggests that if the applicant feels some other method, i.e., a remotely controlled makeup line, is preferable for its purposes, that it can then do so?

MR. O'NEILL: No, because this decision is talking about regulatory guides and using the regulatory guides. It's not talking about regulations themselves. It's saying that the regulatory guides are guidelines. I will get to that

question of Criterion 61 and 62.

1

2

3

4

19

20

21

22

23

24

25

The regulatory guides themselves, I don't think I need to reread those. I think we are pretty familiar with those.

But 62 is short, and it's guite important. Criticality 45 in the fuel storage and handling systems shall be prevented by 6 physical systems or processes, preferably by the use of 7 geometrically safe configurations. This is exactly what the 8 licensing board required. Proof that criticality would be 9 prevented by a geometrically safe rack configuration. TO 10 ensure that criticality not be reached the .95 value used by 11 the Staff was the standard not to be exceeded, Staff and 12 Consumers Power glossed over the rule's insistence that 13 geometric configuration is preferable. Yet deciding between 14 engineering safeguards, such as a water makeup line, and 15 geometrically safe rack configurations is not a matter left 16 to the board's discretion. The geometric solution is by the 17 regulations preferable. 18

Applicant must bear a considerable burden of proof to set this aside. It must prove that the engineered safeguards are as good or better than the geometric configurations.

JUDGE KOHL: Well, isn't that just what it proposes to do in the upcoming hearings with respect to the makeup line? MR. O'NEILL: Well, as I said, there are several very important questions concerning that, including the fact

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

1

2

3

4

5

6

7

8

that emergency core cooling system has been granted certain lifetime exemptions from the single-failure criterion, and also the possibility of accidents that would not be remedied by the makeup lines, such as thermal failure of the concrete base, as is --

JUDGE MOORE: Mr. O'Neill, you requested 20 minutes. Your 20 minutes just expired.

MR. O'NEILL: Can I sum up?

JUDGE KOHL: I have one question: What's wrong with remanding to the licensing board with directions to defer ruling on the criticality until the matters you just raised with respect to the reliability of the makeup line are litigated and hopefully satisfied?

MR. O'NEILL: I think the evacuation cases cited 14 by the Consumers Power strongly cut against that. And the test 15 in those is that what are the consequences of the failure with 16 even environmentally qualified systems? The reg guides are 17 very, very specific that the emergency core cooling system 18 should be single-failure-proof, that the containment shall be 19 such as to prevent significant escapes of gases. And yet in 20 these cases, as I quoted passages not stated by Consumers Power, 21 significant degradation, if not complete failure, of these 22 systems is considered in the evacuation cases. And I think 23 that's very important. Those pages are pages 4 through 7 in 24 my brief. I think that's a very important precedent. 25

The point that it goes to is what are the 1 consequences of the failure of a particular system, whether it 2 be single-failure-proof or not? 3 JUDGE KOHL: Well, don't those same --4 MR. O'NEILL: And in this case, the consequence is 5 very serious because you can't get in the pool to remedy the 6 situation. That access is the principle in Zion. Excuse me. 7 JUDGE KOHL: Assuming the worst of all cases, and 8 that there is some accident, the remotely controlled makeup 9 line doesn't work, and there are releases to the environment. 10 Don't the same evacuation plans come into effect or operation 11 if there were a reactor accident? Don't they also apply if 12 there's an accident of this nature to the spent fuel pool? 13 MR. O'NEILL: Well, Big Rock has a very small 14 evacuation zone. It's only 5 miles. That's based on the fuel 15 inventory of the reactor. It's not based on the fuel inventory 16 of the pool, which will be significantly greater than the fuel 17 inventory of the reactor. 18 Also, that fuel is not standard fuel. There is 19 a mixed oxide fuel in the reactor. There is experimental fuel 20 and there is high burnup fuel in there. 21 So the consequences of a pool accident escaping 22 containment would be far greater than the evacuation that would 23 be required as a result of the reactor accident. 24 JUDGE BUCK: When you say "significantly greater," 25

TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA

the fuel in the pool is significantly greater than that in the
reactor, exactly what do you mean?
MR. O'NEILL: Basically, guantitatively there is far
more fuel in the fuel pool.
JUDGE BUCK: You mean the number of fuel elements?
MR. O'NEILL: Sure.
JUDGE BUCK: How about the amount of radioactivity?
MR. O'NEILL: Well, I think in certain elements, such
as iodine, that the reactor fuel would be less benign than
the pool fuel. But in the long-lived elements, such as
the plutonium and the others, the consequences of a pool
emptying are far greater than the reactor.
JUDGE BUCK: But the immediate effect of a reactor
accident, such as the TMI-2, if that had gotten out, for example
and all of that fuel had broken up, the short half-life far
overpowered the radioactive levels of the other elements. And
that is far, far greater. And that's the ones you're afraid of
in getting the evacuation. It's the short-term stuff.
MR. O'NEILL: Nonetheless
JUDGE BUCK: Well, J am getting at the actual
radioactivity, I think if you look it up, I think that you're
not correct in saying that the reactivity may get out, the
radioactivity that may get out from the fuel elements is far
less than that could possibly get out of an operating reactor.

NORFOLK, VIRGINIA

78

.

t.6 p.5



elements, and in many of those you are correct that the
longer-lived elements are more of a concern during evacuation,
but say, if plutonium is ingestible through the air passages,
that is -- the inventory in the pool is much greater, especially
since most of the mixed oxide fuel is in the reactor pool, not
the reactor itself.

JUDGE BUCK: Well, it's got to be airborne, of course. 7 MR. O'NEILL: I had one or two points that I wanted 8 to make. I would like to point out an internal consistency 9 in the Staff's brief. The Staff maintains that the .98 KEFF 10 value provides fuel is not applicable here. They want to stick 11 to the .95 level in analyzing spent fuel under dry or mist 12 conditions. But there is no point in analyzing the spent fuel 13 under dry or mist conditions if that's a condition that you 14 can never analyze. 15

So in arguing that-the .95 level should be maintained, they are, in effect, granting in a backward way the fact that there are conditions under which you must analyze the KEFF under mist conditions.

As I say, Big Rock is a very small plant. The precedent set by this case should be rather limited. I understand that there may be no other operating reactors that have a spent fuel pool in containment. If there are, there are less than five. I checked this out with the Staff and project managers.

> TAYLOE ASSOCIATES REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA



pieces that implement Criterion 61 and 62 and demonstrate 1 the strong interplay between the two design criteria 2 maintained by the licensee. 3 JUDGE KOHL: Well, Counsel, you don't expect us to 4 rely on something that is only in draft form? 5 MR. GALLO: Well, I don't expect you to rely on it 6 for purposes of substance, but for purposes of indicating the 7 state of mind of the Staff in dealing with their disclaimer in 8 the footnote in their draft. It seems to me that while it's not 0 an effective position of the Commission, or albeit the NRC Staff, 10 it is proposed by the Staff, it seems to me contradicts their 11 suggestion that this strong interplay doesn't exist. I am 12 offering it for that limited purpose. 13 Thank you. 14 JUDGE KOHL: Perhaps you can answer one question I 15 asked earlier. Is the supercriticality article, was that 16 ever offered into evidence? 17 MR. GALLO: To my recollection, it was not. 18 JUDGE KOHL: It was attached to the motion for --19 MR. GALLO: Yes. It was attached -- or referred to -20 JUDGE KOHL: Submitted at the summary disposition 21 level? 22 MR. GALLO: It was referred to, but not attached, is 23 my recollection. So it would be intervenor's material. It was 24 referred to by citation in an affidavit by Dr. Hoover, and the 25 TAYLOE ASSOCIATES

> REGISTERED PROFESSIONAL REPORTERS NORFOLK, VIRGINIA



82

1	decision for a substantive point. And I think that is
2	appropriate.
з	JUDGE BUCK: They used it also to defend the double
4	peak situation, as I recall it. And I thought that was
5	MR. GALLO: I believe they used it to justify their
6	further inquiry into that. Maybe that's the difference without
7	a distinction from a substantive point.
8	JUDGE MOORE: Fine. Thank you.
9	MR. GALLO: Thank you.
10	MR. MOORE: Mr. Bachmann, do you have anything
11	further to add?
12	MR. BACHMANN: Unless this board has further
13	questions, the Staff has nothing further to add.
14	MR. O'NEILL: Point of information. I would just
15	like to tell you the page number on which dropping the water
16	level is indicated in the board's decision per your request.
17	That is page 18 in the order.
18	JUDGE MOORE: Thank you.
19	JUDGE BUCK: That's in the board decision, you say?
20	MR. O'NEILL: Correct.
21	JUDGE MOORE: The case is submitted. Thank you.
22	(Whereupon, at 11:40 a.m., the Board was adjourned.)
23	* * *
24	
25	

83

CERTIFICATE OF PROCEEDINGS

1

2	
3	This is to certify that the attached proceedings before the
4	ATOMIC SAFETY & LICENSING APPEAL BOARD
5	in the matter of: BIG ROCK POINT NUCLEAR POWER PLANT
6	date of proceeding: March 24, 1983
7	place of proceeding: Washington, D.C.
8	were held as herein appears, and that this is the
9	original transcript for the file of the Commission.
10	
11	ANN RILEY
12	official Reporter - Typeu
13	and Riles
14	Official Reporter - Signature
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

.