

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)NRC USE ONLY

8210190355 821011
PDR ADOCK 05000305
S PDR

68 69 80 81
414) 388-2560 Ext. 340 0

Kewaunee Nuclear Power Plant

LER 82-29/01X-1

ATTACHMENT I

27. Cause Description and Corrective Actions

The backup radiation monitor to R-11 and R-12, R-21, was out of service waiting for parts. With this monitor out of service the automatic actions to be tested by the surveillance were defeated. The surveillance procedure was set aside until R-21 was back in service and by a personnel oversight, the testing period was exceeded. When the LCO was discovered, R-21 was jumpered out allowing the test on R-11 and R-12 to be performed. The monitors were tested satisfactory and declared back in service.