Docket No. 50-219

GPU Nuclear Corporation
ATTN: Mr. P. B. Fiedler
Vice President and Director

Gentlemen:

P. O. Box 388

Subject: Inspection No. 50-219/80-17

Forked River, New Jersey 08731

Oyster Creek Nuclear Generating Station

This refers to your letter dated August 31, 1982, in response to our letter dated April 16, 1982.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

Regarding Item D of your letter, based on a September 29, 1982 telephone discussion between Mr. J. Sullivan, Plant Operations Director, and Mr. R. Nimitz of this office, the New Radioactive Waste Building HEPA Filter System has been returned to service and is undergoing DOP testing. In addition, a safety evaluation will be performed if system operation in continuous bypass mode is planned.

If this is not your understanding, please notify this office within 30 days of receipt of this letter.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By: Jun Jayrer

Thomas T. Martin, Director Division of Engineering and Technical Programs

OFFICIAL RECORD COPY

8210190375 821012 PDR ADOCK 05000219 Q PDR TEOL

cc:
M. Laggart, Licensing Supervisor
J. Knubel, BWR Licensing Manager
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
State of New Jersey
NRC Resident Inspector

bcc: Region I Docket Room (with concurrences) Chief, Operational Support Section Chief, Reactor Projects Section 2A

RI:DETP Nimitz/gwc 10/1/82 RANGE P

RI:DETP Greenman RATE DETP

RI DETP Martin

OFFICIAL RECORD COPY