

June 3, 1994

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Gipson:

SUBJECT: FERMI-2 - RESPONSE TO NRC BULLETIN 90-01, SUPPLEMENT 1, "LOSS OF
FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT" (TAC NO. M85388)

On December 22, 1992, the Nuclear Regulatory Commission (NRC) issued NRC Bulletin 90-01, Supplement 1 (Bulletin). The Bulletin informed addressees of activities taken by the NRC staff and the industry in evaluating Rosemount Transmitters and requested that licensees review the Bulletin for applicability to their facilities and modify their actions and enhanced surveillance programs as appropriate. You responded to the Bulletin by letters dated March 5, 1993 and December 20, 1993 for Fermi 2. In your response you committed to replace nine transmitters of concern during the current refueling outage.

We have completed our review of your submittals and have determined that you have adequately resolved the concerns of the Bulletin. The details of our evaluation are contained in the enclosed staff Safety Evaluation and Technical Evaluation Report prepared by our contractor, EG&G of Idaho. You are reminded that you were requested to provide a statement confirming completion when the specific actions committed to in your letters have been completed.

This completes our review for TAC No. M85388. Should you have any questions, please contact me at (301) 504-1341.

Sincerely,

Original signed by

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9406100320 940603
PDR ADOCK 05000341
P PDR

Enclosures:

- 1. Safety Evaluation
- 2. Technical Evaluation Report

DISTRIBUTION:

Docket File TColburn M. Phillips, RIII
NRC & Local PDRs DSpaulding
PD31 Reading File JWermiel
JRoe CJamerson
JZwolinski OGC
LBMarsh ACRS (10)
cc: Plant Service list

NRC FILE CENTER COPY

OFFICE	LA:PD31	PM:PD31	D:PD31
NAME	CJamerson	TCoiburn:g11	LBMarsh
DATE	06/2/94	06/2/94	06/3/94

000039

Handwritten initials/signature

Mr. Douglas R. Gipson
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Robert Newkirk
Director - Nuclear Licensing
Detroit Edison Company
Fermi-2
6400 North Dixie Highway
Newport, Michigan 48166