LICENSEE EVENT REPORT

	CONTROL BLOCK: [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	M 1 D C C 1 2 0 0 - 10 10 10 10 - 10 10 3 4 11 11 11 1 1 5 57 CAT 58 5
CON'T	REPURT L 6 0 5 0 0 0 3 1 5 7 0 9 1 4 8 2 8 1 0 1 3 8 2 9
0 2	WITH THE REACTOR COOLANT SYSTEM IN MODE 3, ON 9-14-82, A SUPPLY BREAKER FOR HEAT
0 3	TRACE CIRCUITS WAS FOUND TRIPPED. THIS BREAKER SUPPLIES POWER TO TRAIN "A" HEAT
04	TRACE CIRCUITS FOR THE BORON INJECTION TANK. ON 9-16-82, DURING MODE 2 THIS
0 5	BREAKER WAS AGAIN FOUND TRIPPED. THESE EVENTS ARE CONTRARY TO TECHNICAL SPECI-
06	FICATION 3.5.4.2. THE PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS
0 7	OCCURENCE OF A SIMILAR NATURE INCLUDE: 315/81-039.
0 8	
7 8	SYSTEM CAUSE SUBCODE COMPONENT CODE SUBCODE SU
10	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) INVESTIGATION HAS BEEN UNABLE TO DETERMINE THE CAUSE OF THE BREAKER TRIPPING.
	MONITORING OF THE PANEL TO INSURE THE PANEL IS OPERABLE WILL CONTINUE UNTIL THE
1 2	CAUSE CAN BE DETERMINED. AN UPDATED LER WILL FOLLOW WHEN THE CAUSE IS DETERMINED.
1 3	
1 5	ACILITY TATUS S POWER OTHER STATUS OTHER
	LEASED OF RELEASE AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA NA LOCATION OF RELEASE 36
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA
1 1 1	PERSONNEL INJURIES 13 NUMBER DESCRIPTION (1) 0 0 (40) NA
	OSS OF OR DAMAGE TO FACILITY 43 PDR ADDCK 05000315 PDR
8 9	PUBLICITY (AS)
2 0 1	NA IIIIIII
	NAME OF PREPARER R. A. PALMER PHONE (616) 465-5901