

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | D | R | S | 3 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE JO CAT 58

CONT
0 1 | L | 0 | 5 | 0 | 0 | 0 | 2 | 4 | 9 | 0 | 9 | 2 | 2 | 8 | 2 | 3 | 1 | 0 | 0 | 6 | 8 | 2 | 9
7 8 9 50 51 58 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operations while exercising the TIP ball valves, 3E TIP ball valve would
0 3 | not automatically reclose using the control switch. This was of minimal safety signi-
0 4 | ficance since the TIP shear valve was available to isolate the TIP if necessary. There
0 5 | was no effect on public health or safety. Last occurrence was reported by R.O.
0 6 | 82-30/03L-0 on Docket #50-249.
0 7 |
0 8 |
0 9 |

0 9 | S | D | E | B | V | A | L | V | E | X | A | D | 11 12 13 14 15 16
9 10 11 12 13 14 15 16 17 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 | LER/RO REPORT NUMBER | 8 | 2 | 0 | 3 | 7 | 0 | 3 | L | 0 |
21 22 23 24 25 26 27 28 29 30 31 32
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRO-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
B | Z | Z | Z | 0 | 0 | 0 | 0 | N | Y | N | X | 9 | 9 | 9 | 26
33 34 35 36 37 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Cause was attributed to a loss of tension in a high tension spring located in the TIP
1 1 | drive mechanism. Immediate action was to close the "E" ball valve mechanically. The
1 2 | spring was re-tensioned and the valve was tested successfully for operability. DOS
1 3 | 1600-8 will continue to be performed weekly. The .25 inch solenoid actuated valve is
1 4 | supplied by General Pneumatic Corporation.

1 5 | E | 0 | 9 | 9 | N/A | B | Routine Test
7 8 9 10 11 12 13 14 15 16
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | N/A | N/A |
7 8 9 10 11 12 13 14 15 16
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | Z | N/A
7 8 9 10 11 12 13 14 15 16
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 3 | 0 | 0 | 0 | N/A
7 8 9 10 11 12 13 14 15 16
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | N/A
7 8 9 10 11 12 13 14 15 16
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | N/A
7 8 9 10 11 12 13 14 15 16
PUBLICITY ISSUED DESCRIPTION

8210190412 821006
PDR ADOCK 05000249
S PDR

NAME OF PREPARER Wayne Morgan

PHONE: 815-942-2920, X-489
NRC USE ONLY



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 3 - 82 - 61
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION "E" TIP Ball Valve Did Not Close OCCURRED 9/22/82 0001
DATE TIME

SYSTEM AFFECTED 700 PLANT STATUS AT TIME OF EVENT TESTING
TIP MODE Run, PWR(MWT) 2509, LOAD(MWE) 830 YES NO

DESCRIPTION OF EVENT While doing DOS 1600-8, "TIP system isolation valve exercising", the "E" TIP ball valve would not automatically close by the control switch. The "E" ball valve was closed mechanically. Work request was written to repair valve.

10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO

EQUIPMENT FAILURE 22952 WORK REQUEST NO. RESPONSIBLE SUPERVISOR Gary L. Smith DATE 9/22/82

PART 2 OPERATING ENGINEER'S COMMENTS TIP shear valve was operable and could have been initiated if necessary.

EVENT OF PUBLIC INTEREST
TECH. SPEC. VIOLATION
NON REPORTABLE OCCURRENCE
14 DAY REPORTABLE/T.S.
30 DAY REPORTABLE/T.S. 6,6.B.2.b
ANNUAL/SPECL REPORT REQ'D
24-HOUR NRC NOTIFICATION REQ'D
TELEPH N/A REGION III DATE TIME
TELEGM/TELECOPY N/A REGION III DATE TIME
CECO CORPORATE NOTIFICATION MADE
IF ABOVE NOTIFICATION IS PER 10CFR21
5-DAY WRITTEN REPORT REQ'D PER 10CFR21
A.I.R. #
L.E.R. # 82-37/03L-0
Teletcopy Dennis P. Galle 9/24/82 1515
CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED John W. Wujciga 9/24/82
OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW Jack Bunner 10/12/82 Michael Wright 10-12-82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION Douglas Scott 10/12/82
STATION SUPERINTENDENT DATE