



**Consumers
Power
Company**

50-330

file

Donald B Miller, Jr
Site Manager
Midland Project

Midland Project: PO Box 1963, Midland, MI 48640 • (517) 631-8650

March 8, 1983

Mr. W. D. Shafer, Chief
Midland Project Section
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

PRINCIPAL STAFF	
RA	INF
D/RA	SCS
A/RA	PAO
OPRP	SLO
CMVA	RC
CRISP	
DE	
ML	
OL	FILE

MIDLAND PROJECT GWO 7020
FINAL DISPOSITION OF THE SLOPE LAYBACK
File: 0485.16 UFI: 07070(S) Serial: CSC-6595

This is to confirm a telephone conversation between Mr. Wheeler and Mr. Murray of our office and Dr. Landsman of Region III on March 4, 1983.

The purpose of the call was to inform Dr. Landsman of the final disposition of the slope layback. Bechtel Engineering analyzed the existing conditions and determined the as-built condition is acceptable. The only remaining work is to place temporary cribbing on the east side of the layback adjacent to the Unit 2 Turbine Building.

Dr. Landsman concurred that the remaining work is covered under the work activity entitled "Redress the slope layback surfaces" and work could proceed.

D. B. Miller
Site Manager

DBM/GMM/dmh

8303280275 830308
PDR ADOCK 05000330
A PDR

1021

MAR 17 1983