

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: Outfall 001c Low Volume Waste Radwaste
Discharge Tanks

PARAMETER AND PERMIT LIMIT: Oil and Grease, 15 mg/l

NONCOMPLIANCE, DATE, AND DURATION:

27 mg/l, September 10, 1982, 11- $\frac{1}{2}$ hours

CAUSE OF NONCOMPLIANCE:

Mechanical failure of the Radwaste Evaporator allowed an unknown quantity of poor quality water to be discharged through this outfall.

CORRECTIVE ACTION:

Work on Work Request Number L17658 is in progress to correct the malfunctioning equipment. In addition, if visual inspection, upon sampling, indicates the potential for exceeding the NPDES Permit, the tank will be reprocessed.

DATE RECOGNIZED AS A VIOLATION:

September 16, 1982

DATE INVESTIGATED:

September 18, 1982

8210190481 820929
PDR ADOCK 05000373
S PDR