



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

September 29, 1982

50-373

Mr. James G. Keppler
Regional Administrator
Director of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Sir:

In accordance with LaSalle County Station Unit 1 Facility Operating License NPF-11, Appendix B, Section 3.2, we are submitting to you a copy of the NPDES noncompliances for LaSalle County Nuclear Generating Station Permit No. IL0048151.

G. J. Diederich
Superintendent
LaSalle County Station

GJD/FRL/JDW/lrw

Enclosure

cc: DVR Report

8210190509 820929
PDR ADOCK 05000373
S PDR

OCT 15 1982

LED2



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

U.S. Environmental Protection Agency
Region V, Enforcement Division
ATTN: Chief, Compliance Unit
230 South Dearborn Street
Chicago, Illinois 60604

Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Management Unit
2200 Churchill Road
Springfield, Illinois

SUBJECT: NPDES Noncompliances For LaSalle County Nuclear
Generating Station - Permit No. IL0048151

Dear Sir:

In accordance with Standard Condition 12, we wish to submit the following notice of noncompliances, which are listed chronologically in the attached table.

A correction to a previously submitted notice of noncompliance is also enclosed.

If there are any questions, please contact Joe Williams of my staff at (815) 357-6761, extension 201.

A. J. Diederich
G. J. Diederich
FRL JDW
GJF/FRL/JDW

cc: Director of Water Quality, Environmental Affairs
Manager, Nuclear Stations Division

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001c - Low Volume Waste
Radwaste Discharge Tanks

PARAMETER AND PERMIT LIMIT: Total Suspended Solids - 15 mg/l
Total Iron - 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION:

TSS, 22 mg/l, August 1, 1982, 13 hours

Total Iron, 6.0 mg/l, August 1, 1982, 13 hours

CAUSE OF NONCOMPLIANCE:

Mechanical problems with the Radwaste evaporators resulted^{IN} poor quality water being processed to this out fall. This water was known to have been of poor quality prior to processing forward, but was not acted upon due to high water inventories in Radwaste. Once the water was discharged to this out fall tank, it could not be reprocessed, and must be discharged to the cooling Pond Blowdown line.

CORRECTIVE ACTION:

Operating personnel were notified of the need to reprocess poor quality water, instead of processing it forward. Operating personnel agreed with this, and will reprocess poor quality water. They are also attempting to correct the problems with the evaporators, which will alleviate the need for reprocessing.

DATE RECOGNIZED AS A VIOLATION:

August 3, 1982

DATE INVESTIGATED:

August 3, 1982

Dupe of 8210190468