

GPU Nuclear Corporation
One Upper Pond Road
Parsippany, New Jersey 07054
201-316-7000
TELEX 136-482
Writer's Direct Dial Number.

June 6, 1994 C321-94-2080 5000-94-0026

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generation Station (OCNGS)

Operating License No. DPR-16

Docket 50-219

Additional Information Requested by the NRC Staff Re: Generic Letter 92-01, Revision 1, "Reactor Vessel

Structural Integrity"

On April 19, 1994, GPU Nuclear responded to your letter dated March 30, 1994 concerning Generic Letter 92-01, Revision 1, "Reactor Vessel Structural Integrity" issues.

Subsequently, Mr. A. Dromerick, Sr. Projector Manager, NRR-NRC requested GPU Nuclear to complete the "Equivalent Margin Analysis Plant Applicability Verification Form" (Appendix B, NEDO-32205) with the plant specific data.

Enclosed is the completed verification form. If you have any questions concerning the data provided, please contact Mr. M. W. Laggart, Manager, Corporate Licensing at (201) 316-7968.

Sincerely,

R. W. Keaten

Vice President and Director

Technical Functions

/crb

cc: Administrator Region I NRC Oyster Creek Project Manager Senior Resident Inspector

9406130123 940606 PDR ADDCK 05000219 PO28 1

NEDO-32205-A

EQUIVALENT MARGIN ANALYSIS PLANT APPLICABILITY VERIFICATION FORM

FOR Oyster Creek

BWR/2-6 WELD

	Surveil	lance	Weld	USE:
--	---------	-------	------	------

%Cu = 0.28

Capsule Fluence = $7.46 \times 10^{17} (n/cm^2)$

Measured % Decrease = NA (Charpy Curves)

R.G. 1.99 Predicted % Decrease = 24% (R.G. 1.99, Figure 2)

* Based on one surveillance data point.

Limiting Beltline Weld USE:

%Cu = 0.35

32 EFPY Fluence = $2.36 \times 10^{18} (p/cm^2)$

R.G. 1.99 Predicted % Decrease = 34 (R.G. 1.99, Figure 2)

Adjusted % Decrease = NA** (R.G. 1.99, Position 2.2)

Creek has only one credible surveillance data. Therefore, RG 1.99

** Oyster Creek has only one credible surveillance data. Therefore, RG 1.99 position 2.2 is not applicable.

34 % ≤ 34%, so vessel welds are bounded by equivalent margin analysis

EQUIVALENT MARGIN ANALYSIS PLANT APPLICABILITY VERIFICATION FORM

FOR	Oyster Creek

BWR/2 PLATE

Surveillance Plate USE:

%Cu =
$$0.17$$

Capsule Fluence = $7.46 \times 10^{17} (n/cm^2)$

Measured % Decrease = 7* (Charpy Curves)

R.G. 1.99 Predicted % Decrease = _______* (R.G. 1.99, Figure 2)

*Based on one surveillance data point.

Limiting Beltline Plate USE:

%Cu = 0.21

32 EFPY Fluence = $2.36 \times 10^{18} (n/cm^2)$

R.G. 1.99 Predicted % Decrease = 21.5 (R.G. 1.99, Figure 2)

Adjusted % Decrease = NA (R.G. 1.99, Position 2.2)
*** Oyster Creek has only one credible surveillance data. Therefore, RG 1.99
position 2.2 is not applicable.

21.5% ≤ 26%, so vessel plates are bounded by equivalent margin analysis