

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

① | 0 | 1 | G | A | E | I | H | 2 | ② | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | ③ | 4 | 1 | 1 | 1 | 1 | ④ | _____ | ⑤

CON'T
① | 0 | 1 | L | ⑥ | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 6 | ⑦ | 0 | 9 | 0 | 7 | 8 | 2 | ⑧ | 1 | 0 | 0 | 5 | 8 | 2 | ⑨

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩
① | 0 | 2 | On 9/7/82, with Unit 2 in run mode at 1826 Mwt, personnel discovered
② | 0 | 3 | that the "EMERGENCY BUSES 2E, 2F, & 2G UNDERVOLTAGE RELAY INSTRUMENT F.T."
③ | 0 | 4 | monthly surveillance procedure had not been performed by 9/2/82 as re-
④ | 0 | 5 | quired by T.S.4.3.8 Table 4.3.8-1. The due date was 8/27/82; a 7-day
⑤ | 0 | 6 | grace period (25% per T.S.4.0.2.a) gives the latest allowable date
⑥ | 0 | 7 | 9/2/82. The procedure was performed on 9/3/82. The health and safety of
⑦ | 0 | 8 | the public were not affected by this non-repetitive event. ⑧

① | 0 | 9 | E | E | ⑪ | A | ⑫ | C | ⑬ | R | E | L | A | Y | X | ⑭ | M | ⑮ | Z | ⑯

① | 1 | 0 | The cause of this event was personnel error. The latest allowable date
② | 1 | 1 | for the missed surveillance procedure was inadvertently transposed to
③ | 1 | 2 | the work assignment sheet as 9/3/82 instead of 9/2/82. Personnel have
④ | 1 | 3 | been counseled to be more attentive to detail when making work assign-
⑤ | 1 | 4 | ments and complying with Tech. Specs. ⑧

① | 1 | 5 | E | ⑲ | 0 | 7 | 8 | ⑳ | NA | A | ㉑ | Administrative Review ㉒

① | 1 | 6 | Z | ㉓ | Z | ㉔ | NA | NA | NA ㉕

① | 1 | 7 | 0 | 0 | 0 | ㉖ | Z | ㉗ | NA ㉘

① | 1 | 8 | 0 | 0 | 0 | ㉙ | NA ㉚

① | 1 | 9 | Z | ㉛ | NA ㉜
8210190602 821005
PDR ADOCK 05000366
S PDR

① | 2 | 0 | N | ㉝ | NA ㉞