

NOTICE OF VIOLATION

Illinois Power Company
Clinton Power Station

Docket No. 50-461
License No. NPF-62

During an NRC inspection conducted on April 15 through May 16, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Clinton Operating Licensee NPF-62, section 2.C.(1), "Maximum Power Level", states, in part, "IP is authorized to operate the facility at reactor core power levels not in excess of 2894 megawatts thermal (100 percent rated power)...."

Contrary to the above, on April 15, 1994, the plant was operated at power levels in excess of 100% rated (a peak of 106% mean power, 109.8% APRM power) for 75 seconds.

This is a Severity Level IV violation (Supplement I). (461/94009-01(DRP))

The inspection showed that steps had been taken to correct the identified violation and to prevent recurrence. Consequently, no reply to the violation is required and we have no further questions regarding this matter.

Dated at Lisle, Illinois
this / 5th day of June 1994

9406130144 940601
PDR ADOCK 05000461
PDR