

Westinghouse Electric Corporation **Energy Systems**

Box 355 Pittsburgh Pennsylvania 15230-0355

NTD-NRC-94-4152 DCP/NRC0076 Docket No.: STN-52-003

May 31, 1994

E004

Document Control Desk U.S. Nuclear Regulatory Commission Washington, D.C. 20555

ATTENTION: R. W. BORCHARDT

SUBJECT: PRESENTATION MATERIALS FROM THE MAY 25, 1994 MEETING ON AP600 PASSIVE CONTAINMENT COOLING SYSTEM ANALYSES

Dear Mr. Borchardt:

Attached are presentation materials used during the May 25, 1994 meeting at the Westinghouse offices in Rockville, MD to discuss AP600 Passive Containment Cooling System analyses. The following materials are attached:

Attachment 1 Presentation material, May 25, 1994 meeting

The Westinghouse Electric Corporation copyright notice is also attached.

Please contact Brian A. McIntyre on (412) 374-4334 if you have any questions concerning this transmittal.

N. J. Liparulo, Manager'

N. J. Liparulo, Manager' Nuclear Safety Regulatory And Licensing Activities

/nja

Attachment

- cc: R. Hasselberg, NRC
 - T. Kenyon, NRC (w/o attachments)

9406130145

- L. Shotkin, NRC (w/o attachments)
- B. McIntyre, Westinghouse (w/o attachments)
- P. A. Boehnert, ACRS

1780A

COPYRIGHT NOTICE

The reports transmitted herewith each bear a Westinghouse copyright notice. The NRC is permitted to make the number of copies of the information contained in these reports which are necessary for its internal use in connection with generic and plant-specific reviews and approvals as well as the issuance, denial, amendment, transfer, renewal, modification, suspension, revocation, or violation of a license, permit, order, or regulation subject to the requirements of 10 CFR 2.790 regarding restrictions on public disclosure to the extent such information has been identified as proprietary by Westinghouse, copyright protection not withstanding. With respect to the non-proprietary versions of these reports, the NRC is permitted to make the number of copies beyond those necessary for its internal use which are necessary in order to have one copy available for public viewing in the appropriate docket files in the public document room in Washington, D.C. and in local public document rooms as may be required by NRC regulations if the number of copies submitted is insufficient for this purpose. Copies made by the NRC must include the copyright notice in all instances and the proprietary notice if the original was identified as proprietary.

ATTACHMENT TO WESTINGHOUSE LETTER NTD-NRC-94-4152

NRC / Westinghouse Meeting on PCCS

Overview and Status of Westinghouse AP600 PCCS Test Analysis and SSAR

May 25, 1994

Agenda

- 1. Content of Westinghouse June 30, 1994 Report
- 2. NRC PCCS Review Schedule Information Needs
- 3. Schedule of W/NRC Meetings and Reports
- 4. Objectives and Schedule for PCCS Work Plan
- 5. Plans for Next Meeting
- 6. Discussion of NRC Severe Accident information needs
- 7. Discussion of Detailed PCCS Work Plan
- 8. Wrap-up and Action Items



1. Content of Westinghouse June 30, 1994 Report

Westinghouse Presentation to NRC - May 1994 - Page 2 of 43

Content of Westinghouse June 30, 1994 Report

• Report:

"Confirmation of PCCS DBA Bases in SSAR"

Objectives

- Show appropriate margins are retained to demonstrate that AP600 containment DBA pressure response has equal or more design margin relative to current operating plants.

- Demonstrate clear connection from SSAR Rev. 0 containment DBA models to current code version.

- Demonstrate that uncertainties in code usage are bounded appropriately.

Schedule

 Report will be issued by Westinghouse to NRC on June 30, 1994

W

Content of Westinghouse June 30, 1994 Report

- WGOTHIC Relative to SSAR Rev. 0
 - WGOTHIC_S Version 1.1 re-run of SSAR Rev. 0 calculation; to demonstrate effect of new heat and mass transfer models on SSAR DBA pressure response

- WGOTHIC_S Version 1.1 calculation; to quantify significant conservatism due to boundary conditions and initial conditions in SSAR Rev. 0

Table of Contents (handout)



Content of Westinghouse June 30, 1994 Report

Conclusions

A report content has been presented which is expected to provide AP600 DBA PCCS information on a schedule that is consistent with DSER needs.

A report will be issued by June 30, 1994 that will demonstrate that AP600 SSAR Rev. 0 DBA containment analyses remain conservative relative to WGOTHIC upgrades.

Subsequent SSAR Rev. 0 lumped parameter model calculations of confirmatory LST are planned.



2. NRC PCCS Review Schedule -Information Needs

Westinghouse P esentation to NRC - May 1994 - Page 6 of 43

NRC PCCS Review Schedule - Information Needs

- RAI Status
- Status of Future RAIs from NRC

Westinghouse Presentation to NRC - May 1994 - Page 7 of 43

PCCS TEST ANALYSIS RAI SUMMARY

RAI #	SUBJECT			
480.2	Mechanistic Heat/Mass Transfer Correlations ³			
480.4	Dry Shell LST and SST Data ³			
480.8	Natural Circulation of Air in the PCCS ³			
480.9	HT to Internal Structures and Mixing in the Containment ³			
480.10	Jet Discharge: Location/Orientation/Scaling ³			
480.11	1/8 Scale Facility Instrumentation ³			
480.12	1/8 Scale Facility Test Matrix ³			
480.13	Westinghouse Scaling Approach ¹			
480.14	Mechanistic Correlations in WGOTHIC ¹			
480.15	WGOTHIC Validation Using Test Data ¹			
480.16	WGOTHIC Numerics ¹			
480.17	External Film Pattern/Water Distribution Tests ²			
480.18	Degree of "Rain" in the AP600 Containment ³			
480.32	Hydrogen Control-Prediction of Hydrogen Distribution ³			
951.2	WGOTHIC Condensation Model ³			
480.66	Margin between max calc. and design containment pressure			
480.67	HT coefficient sensitivity to node size near the wall			
480.68	Postulated break size for subcompartment analysis			
480.69	Use of TMD code for M&E releases			
480.71	Testing of containment heat transfer			

¹ To be further addressed in WCAP-13246, Rev. 1 ² To be addressed further in an RAI revision, and in some cases a

supplemental report. ³ Complete

2

Westinghouse Overview of PCCS Topics

Discussion

Westinghouse Presentation to NRC - May 1994 - Page 9 of 43



3. Schedule of W/NRC Meetings and Reports

Westinghouse Presentation to NRC - May 1994 - Page 10 of 43

Schedule of W/NRC Meetings and Reports

Schedule Item from March 17, 1994 NRC Meeting

- Westinghouse/NRC agreed to an overall SER information exchange process from March 1994 through issuance of WGOTHIC WCAP in May 1995

Schedule Item from March 16, 1994 ACRS Meeting

Added September 1994 ACRS meeting on PCCS scaling based on SASM methodology

 "Draft Information Exchange Schedule In Support of AP600 PCCS Review" resulting from weekly telecons

- Moved "Mid-stage 2 WGOTHIC" meeting ahead from Sep 9, to late July, 1994

 Added August 1994 "PCCS Scaling and Phenomena" meeting

 Added November 1994 end-stage 2 WGOTHIC meeting

Schedule of W/NRC Meetings and Reports

Conclusions

A schedule of meetings and reports has been presented that meets NRC information needs that have been identified to date.

Westinghouse is committed to continued open dialog on schedules and content as the most effective way to proceed with the AP600 Design Certification process.

Westinghouse Presentation to NRC - May 1994 - Page 12 of 43

 For each category of the detailed PCCS work plan, the objective, content, and schedule status are given.

• Informational slides on certain topics are also discussed under the relevant work plan category.



WGOTHIC Programming

Objectives

Support the development of an efficient PCCS analysis tool with clear documentation in a controlled process.

Develop graphics and post-processing module (convenience code) upgrades following same stringent QA requirements as for solver.

Task Content Analytical model upgrades for the solver module

Supporting upgrades for graphics and post-processing modules

Some separate effects validation is also included under this heading

Schedule See following slide on code versions.



Currently Planned WGOTHIC Versions

Module	Version	Upgrade	Status
Solver WGOTHIC_S	1.0	 Baseline code consistent with GOTHIC 3.4d Wall-wall radiant H.T. Colburn force convection McAdams free convect. 	Configured
	1.1	 Mixed convection p/P_{BM} in mass transfer Entrance effect multiplier Flat plate correlation error corrections NAI GOTHIC WGOTHIC 	Configured
	1.2	 Liquid film enthalpy transport with 2 layer film Dimensionless group printout 	Expected to be configured by mid-June
	1.3	 Consistency with graphics/preprocessor upgrades (no analytical model changes) 	In progress

1	-		~		
10	1	Ŗ		Ι	
1	٧	١	1	-)	
1	100	55	8	1	
1		_	1	<u>.</u>	

Module	Version	Upgrade	Status
Preprocessor WGOTHIC_P	1.0	 Baseline code consistent with GOTHIC 3.4d. 	Configured
	2.0	 Add Clime table input capability. 	Verified. Configuration in progress
	2.1	Add Clime plot options	In progress
		• NSAPLOT, MOVIE	
Graphics WGOTHIC_G	1.0	Baseline code consistent with GOTHIC 3.4d.	Configured
	1.1	Add Clime plot options	In progress
		• NSAPLOT, MOVIE	

16.11

Usage of WGOTHIC Code Versions

 WGOTHIC Preprocessor and Graphics Version Releases

- Westinghouse QA process ensures that WGOTHIC_P and WGOTHIC_G correctly process input and output to correctly execute WGOTHIC_S and accurately process data

- Both WGOTHIC_P and WGOTHIC_G are considered to be convenience codes for input and output processing. They have no impact on specific analytical models or methodology

- Westinghouse has no plans to submit specific additional information beyond this meeting for the convenience codes

Usage of WGOTHIC Code Versions (continued)

WGOTHIC Solver Version Releases

- Version 1.1

Configured

(Through configuration control at this point, will be able to clearly show the effect on LST predictions of adding film enthalpy transport separate from H&MT correlation upgrades)

- Version 1.2

Film enthalpy transport is a negligible effect for AP600 calculations due to small dome area over which this mechanism is active

Film enthalpy transport is active over a larger fraction of the LST, so inclusion of this model is expected to allow clear demonstration that all other significant phenomena are modelled correctly in the computer code

Film enthalpy transport needed to accurately model transient tests, including blind test

Version 1.2 expected to be configured during June 1994

Will include status of results during November meeting

Westinghouse Presentation to NRC - May 1994 - Page 18 of 43

The W Code Development Process

Summary of NTD QA Program (WCAP-9565) Software Development Process

Consistent with NQA 2a Part 2.7 which emphasizes maintaining formal documentation at each step of development

Functional Specification (functional group calc note) Design Specification (programmer's calc note) Verification / Validation Formal review and signoff of specifications and documentation Configuration Release to users (any constraints identified) Error reporting

Configuration control is performed by a dedicated group which is responsible for maintaining configured code versions

The W Code Development Process (continued)

The following NTD QA procedures apply to WGOTHIC development

- DP 3.7.1 Computer Software Development Process
- DP 3.7.2 Verification and Validation of Computer Programs
- DP 3.7.3 Configuration Control of Computer Programs
- DP 3.7.4 Software Error Reporting and Resolution
- DP 3.7.5 Dedication and Installation of External Computer Programs (followed for configuration control of incoming NAI GOTHIC versions)

The W Code Development Process (continued)

Relationship of WGOTHIC to EPRI's GOTHIC Code

GOTHIC Qualification Report documents a large set of qualification cases developed by EPRI / NAI to demonstrate the modelling capability of GOTHIC

8 standard theoretical problems

13 tests at 6 different facilities (including CVTR)

Westinghouse will reference the CVTR cases in June 30 report to support blowdown modelling

WGOTHIC differs in the addition of PCCS correlations that are exercised similar to other heat transfer options, such as Uchida heat transfer coefficient option

PCCS correlation subroutines serve to provide energy and mass source terms for control volumes similar to other GOTHIC subroutines

The W Code Development Process (continued)

 Relationship of WGOTHIC to EPRI's GOTHIC Code (continued)

WGOTHIC upgrades are verified not to adversely impact NAI qualification cases since NQA 2a Part 2.7 requires demonstration that upgrades do not affect previously released code

Initial WGOTHIC release reran every <u>GOTHIC Qualification Report</u> case - documented in baseline calc note

For subsequent versions, reran a selected set of the most sensitive cases - calc note

GOTHIC error reports are filed with NAI for resolution

Westinghouse incorporates into WGOTHIC any error corrections issued by NAI, according to severity level

Helps all GOTHIC users to benefit of error notification/correction

The W Code Development Process (continued)

Relationship of WGOTHIC to EPRI's GOTHIC Code (continued)

Westinghouse supports longer term code consistency
 Mutually exchange information with NAI on code usage

 Present summaries of lessons learned at GOTHIC Advisory Group meetings

- Westinghouse participates in "GOTHIC Tailored Collaboration Program" wherein NAI performs code upgrades and adds useful models

 Tailored collaboration program has provided an industry Design Review on GOTHIC

Future WGOTHIC upgrades

- Westinghouse may incorporate future GOTHIC code upgrades and error corrections into WCOTHIC without explicit notification to NRC as long as AP600 PCCS Design Certification submittals are not adversely impacted

Such upgrades are required to follow explicit QA procedures

QA process includes steps to demonstrate that previous code results are not invalidated, including

- EPRI/NAI qualification cases
- Submitted AP600 PCCS validation cases

The W Code Development Process (continued)

 Relationship of WGOTHIC to EPRI's GOTHIC Code (continued)

Conclusions

WGOTHIC upgrades have no adverse impact on previously developed GOTHIC qualification cases

Several processes and activities are expected to continue to keep GOTHIC and WGOTHIC on equal footing

Processes are in place to prevent future non-AP600 WGOTHIC upgrades from adversely impacting AP600 PCCS Design Certification submittals



WGOTHIC Test Analysis

Objectives See next page for LST specifics

Content See next page for LST specifics

Schedule Subdivided LST model input is complete and calc note under review

Initial runs have begun. Preliminary results will be discussed in the July 1994 meeting on code comparisons to test data



LST TASKS and OBJECTIVES

<u>Task</u> A	<u>Node Type</u> Lumped	<u>Test</u> Baseline	Code Version Version 1.0	<u>Objective</u> V&V WCAP-13246 & SSAR, Revs. 0
В	Lumped	Baseline	Version 1.1	Supports DSER and shows net effect of new models. It will justify the acceptability of the SSAR REV 0 models with respect to the correlation upgrades.
C	Subdivided	Phase 2/3	Version 1.2	Show phenomena are modelled correctly and all the important phenomena are modelled, therefore will show that final step for SASM is complete. (Two tests will be run and detailed local comparisons made.)
D	Lumped	Phase 2/3	Version 1.2	Show effect of noding and momentum equation on pressure. Demonstrate that using lumped model is acceptable for vessel pressure response by comparison to "C" and to measured data.
E	Lumped	Blind	Version 1.2	Add confidence to the modelling techniques by performing blind prediction.
F	Lumped	Phase 2/3	Version 1.0	Demonstrate that SSAR Rev 0 remains conservative including confirmatory tests. Same cases as "C".

Westinghouse Presentation to NRC - May 1994 - Page 26 of 43

Wind Tunnel

Objectives

Identify effects of terrain, buildings, and wind turbulence on PCCS performance

Develop bases for boundary conditions used within WGOTHIC (pressure boundary condition)

Evaluate PCCS effluent recirculation due to wind and thermal inversions (temperature, humidity boundary condition).

Identify any plant site constraints relative to terrain or buildings

Wind Tunnel (continued)

Schedule

Wind Tunnel Tests Phases 1, 2, and 4 are completed

Wind Tunnel Test data reports on Phases 1 and 2 have been issued to the NRC

Wind Tunnel Test data reports on Phases 4A and 4B are undergoing final review before being issued

Wind Tunnel Phase 3 has been eliminated based on literature study. Effluent recirculation report is expected to be sent by end of May 1994

Other evaluations begin in fiscal year 1995

Scaling

Objectives

- Provide scaling rationale for applying LST and separate effects tests results to full scale AP600

Phenomenological model development (ongoing; intermediate results have been presented to NRC and ACRS)

Formal top down scaling report per Appendix D of NUREG/CR-5809 has been added to address NRC information needs

- Top down scaling gives dimensionless Π groups which typically encompass ratios of the usual dimensionless numbers

- Π groups are used to demonstrate that important phenomena for plant are represented in tests and to identify any distortions due to scale

Overview of Severe Accident Scaling Methodology

(SASM)

Objectives

Demonstrate that

- all important phenomena have been addressed, and relative importance is correctly ranked

- the test database is appropriate to validate WGOTHIC

- factors affecting AP600 PCCS performance have been clearly identified

Benefits

- Assures experimental and analytical methods used to resolve issues are comprehensive, auditable, systematic, and traceable

- Demonstrates that all important features of an issue are fully addressed

- Allows certification process to focus on phenomena of greatest importance to PCCS performance

Westinghouse Presentation to NRC - May 1994 - Page 30 of 43

Key Points

Component I

Problem specification and concurrent PIRT development

```
Break problem into
systems
subsystems
:
processes (fluxes) ---> time constant
(Component II)
```

PIRT (Phenomena Identification and Ranking Table) is major outcome

Iteration with subsequent steps updates PIRT until SASM objectives have been met for application to AP600

Key Points

Component II

Develop time constants and time ratios (or Π groups) to quantify and rank important phenomena

Generally, may iterate with PIRT to modify relative ranking based on outcome of this component

Allow relating tests to AP600 - show that important phenomena in prototype are properly represented in tests

Key Points

Component IV

Incorporates into WGOTHIC the correlations / models necessary to accurately predict tests and AP600

Closure of SASM iteration is primarily based on a successful comparison of WGOTHIC to test database, which when complete:

- demonstrates that SASM process has identified the important phenomena in calculational process so the PIRT would then be complete

- validates WGOTHIC for use on full scale AP600

WGOTHIC Role

WGOTHIC is the computer code selected for analysis of the AP600 Design Basis Analysis containment pressure response, based on the following characteristics

- → ability to predict stratification
- → flexibility to model ... portant phenomena
- → good experience with other PCCS designs
- → extensive, high quality V&V of base GOTHIC

A conservative AP600 analysis methodology has been submitted (SSAR Rev. 0) based on WGOTHIC validated with separate effects tests and integral tests (SST, Baseline LST)

Overview of SASM (continued)

WGOTHIC Role (continued)

Subsequent LST test analyses and further phenomenological model development pointed to upgrades that would improve test agreement:

- refined correlations to more accurately model ranges of parameters in AP600 geometry

- liquid film enthalpy transport (to address practical problem of modeling subcooled liquid film heat transfer on LST dome for the Blind Test)

- subdivided formulation with finer nodes

Completion of defined work scope is expected to demonstrate incorporation of all phenomena important in PCCS performance evaluations

This will indicate successful completion of the SASM iterative scaling process for PCCS Design Basis Analysis

Overview of SASM (continued)

Westinghouse Approach

- First iteration of SASM report (tasks 26620W6001-4) will provide a complete application of SASM to one of the most important regions relative to PCCS performance:

"Internal containment above operating deck"

- Second iteration of SASM report (task 26620w6005) will complete the scaling for <u>all</u> other regions of importance for containment DBA, including downcomer-baffle regions

The *preliminary* breakdown of the final report consists of the following "modules":

- → Internal, above deck
- → Internal, below deck, closed compartments
- → Internal, below deck, open compartments
- → Internal, below deck, break compartment
- → External, riser
- → External, downcomer

- Westinghouse experience with previous PCCS design and test program and existing studies by other authors will help form basis of phenomena selection and ranking. This will be clearly documented as part of SASM reports.



• Scaling (continued)

Schedule

Bottom up statuses and reports	April - December 1994
SASM report iteration 1 to NRC	June 27, 1994
NRC opportunity to provide comments	August 12, 1994
SASM report iteration 2 to NRC	September 9, 1994

Phenomenological Models

Objectives

- Develop phenomenological models required to model AP600 PCCS performance

Define correlations used in computer code

Define appropriate boundary conditions for PCCS performance calculations

Schedule

- Status of heat and mass transfer models provided at ACRS meeting on March 16, 1994

 Reports on "Liquid Film Model Validation" and "Radiation Heat Transfer through Fog in the PCCS Air Gap" issued to NRC

- Other reports will be issued as they are completed

 Water coverage report has been moved ahead to better address NRC needs on schedule of information

Phenomenological Models (continued)

Water Distribution Test Status

All tests (Phases I, II, and III) are completed

Test Data reports have been issued to NRC

Data will be factored into phenomenological report on water film

summary of test data bases for SSAR Rev. 0
 WGOTHIC boundary condition assumptions on water coverage fractions

- liquid film stability

 evaluation of effect of hot containment surface on room temperature water coverage test results

PCCS SSAR Evaluations

Discussion

Westinghouse Presentation to NRC - May 1994 - Page 40 of 43

5. Plans for Next Meeting

Westinghouse Presentation to NRC - May 1994 - Page 41 of 43

Plans for Next Meeting

- Topic: Detailed review of Westinghouse and NRC code comparisons to LST
- Scheduled for July 1994
- Suggested Agenda
 - Discuss test measurements methods and data

- Show status of subdivided WGOTHIC test predictions compared to LST

Discuss status of NRC code comparisons to LST

Comments

- Westinghouse planned work scope for subdivided model
 - * Phase 2 Test #212.1 (Stepped transient)
 - * Phase 3 Test #222.1 (Blowdown)

- Data comparisons in similar formats would make most effective use of meeting time



Suggested Data Comparison Formats

Handouts

Westinghouse Presentation to NRC - May 1994 - Page 43 of 43

Suggested LST Data Comparison Format

Westinghouse Plans

Lumped Parameter runs


Pmeas vs Ppredict to show conservative underestimate of total heat removal

Subdivided

Detailed comparisons to test data will be made to demonstrate agreement with test data to meet stated objectives


Attached format shows information on code results that Westinghouse will bring to July meeting, along with appropriate detailed printouts

Steady State Data Comparisons



Transients

.



Time

Response to AP600 Test Program issues Identified in 11 4 95 Letter


		Table					
Draft Information	Exchange	Schedule	In Su	pport of	AP600	PCCS	Review

1.2


Jel

FORMAT	DATE	TOPICS/AGENDA ITEMS			
Telecons	Weekly	NRC review status.	 Suggested agenda items forwarded prior to telecons Format similar to test schedule phone calls 		
Meeung	Early May. 1994	 DSER/FSER supporting information plans WGOTHIC development 	 PCCS analysis work plans DSER information exchange schedule/content Schedule for resolution of technical issues TOC for June 30, 1994 report TOC for scaling report Summary of WGOTHIC development Relationship to EPRI GOTHIC development programs 		
Report	June 30, 1994	SSAR Bases for PCCS DBA			
Meeting	July 1994	- PCCS Computer Code Validation (M.d. storge 2) - SSAR Containment DBA	 WGOTHIC validation results and status NRC CONTAIN validation results and status Review status and future data needs 		
Report	July 1994	Phenomenlogical Report	Document containment surface wetting basis with respect to requirements and film stability (26620W6106)		
Report	July 1994	Draft PCCS scaling report	SASM Component I		
Report	August 1994	Phenomenological Report	Convective heat transfer basis with respect to laminar/turbulent flow (26620W6102)		
Meeting	August 1994	 PCCS Scaling PCCS Phenomena Schedules 	 Top down scaling results Bottom up scaling results NRC comments on phenomena (bottom up) report NRC comments on PCCS scaling report 		
ACRS mtg	September 1994	PCCS Scaling			
Report	September 1994	PCCS scaling report	Incorporation of NRC comments		
Report	October 1994	Phenomenological Report	Condensation and evaporation mass transfer basis with respect to laminar/turbulent, inclined plane (26620W6103,26620W6104)		
Meeting	November 1994	 WGOTHIC model review Discussion of remaining issues, schedule 	Model review prior to start of blind test predictions (End of Stage 2)		
Report	December 1994	Phenomenological Report	Internal transient and stratification processes (26620W6201, 26620W6301)		

(from March 17 Presentation) Proposed NRC / Westinghouse Information Exchange Schedule to Support NRC Safety Evaluation Report Needs.



AP600 CONTAINMENT DSER REPORT SCHEDULE



AP600 CONTAINMENT DSER REPORT SCHEDULE

AND PRELIMINARY OUTLINE

PRELIMINARY

1.0 Revised AP600 LOCA Analysis with WGOTHIC

1.1 Objective

The objective of this step is to calculate the revised pressure/temperature transient for the AP600 Design with improved WG0THIC models using a consistent version of the SSAR Rev. 0 input deck. The results of this analysis should be lower than those presented in the SSAR.

2.0 Revised LST Analysis with WGOTHIC

2.1 Objective

The objective of this step is to demonstrate that the revised code version is conservative and improves the predictions with respect to the large scale tests.

3.0 AP600 Model/Design Conservatism

3.1 Objective

The objective of this step is to highlight the significant factors affecting conservatism included in the analysis

4.0 Demonstration of Model/Design Conservatism

4.1 Objective

The objective of this step is to demonstrate the margin to the design limits that is retained by the use of the input and boundary conditions identified in step 3.0.

5.0 Validation of WGOTHIC

5.1 Objective

The objective of this step is to provide confidence that the code can predict the large scale tests. It is limited to the cases in Section 2.

6.0 Main Steamline Break

6.1 Objective

To demonstrate that the steamline break analyses presented in the AP600 SSAR remain conservative when reanalyzed with the revised code version.

PRELIMINARY

7.0 Prepare DSER Report

7.1 Objective

The objective of this report is to provide the NRC with enough information that they can feel comfortable with the conservatism associated with the AP600 Containment analysis and to provide confidence in the WGOTHIC code to predict these types of transients.

It is intended to demonstrate that the original analysis bounds the new analysis with the improved WGOTHIC version and that there remains substantial conservatism in the resultant transient.

8.0 Report Outline

- 8.1 Introduction
 - 8.1.1 AP600 containment design overview
 - 8.1.2 PCCS design overview
 - 8.1.3 WGOTHIC code overview

8.2 SSAR Analysis

- 8.2.1 Analysis methodology
- 8.2.2 Original LOCA analysis results
- 8.2.3 Main steamline break results
- 8.3 AP600 vs. Current Designs and Assumptions
 - 8.3.1 AP600 design vs. current plants
 - 8.3.1.1 power to volume
 - 8.3.1.2 # penetrations
 - 8.3.1.3 fewer pipes to break
 - 8.3.2 Input conservatisms
 - 8.3.2.1 Decay heat
 - 8.3.2.2 Primary side volumes
 - 8.3.2.3 Initial conditions
 - 8.3.2.4 etc. from NRC presentation
 - 8.3.3 Discussion of transient
 - 8.3.4 Code sensitivities
 - 8.3.4.1 Data transmitted to NRC from presentation

AP600 CONTAINMENT DSER REPORT SCHEDULE

PRELIMINARY

8.4 Demonstration of conservatism

- 8.4.1 Compare results of with and without modelling/input conservatisms
- 8.4.2 Comparison of code predictions with test data to demonstrate appropriateness of code.
- 8.5 Conclusions
 - 8.5.1 Design features of the AP600 containment with PCCS result in improvements in ability to meet safety goals relative to operating plants.
 - 8.5.2 Assumptions made in the analysis are conservative
 - 8.5.3 Amount of total conservatism is significant
 - 8.5.4 The original SSAR analysis is very conservative and bounds the reanalysis using the same model and the modified code.

D