

OCT 15 1982

Docket No. 50-440
Docket No. 50-441

The Cleveland Electric Illuminating
Company

ATTN: Mr. G. R. Hicks
PQS/Unit Supervisor, SQE
Mail Zone S-150
Post Office Box 5000
Cleveland, Ohio 44101

Gentlemen:

On October 6, 1982, Mr. Hicks of your staff called Mr. F. W. Reimann of Region III to follow up on earlier discussions of methods which could enhance the affectiveness and the efficiency of the NRC review of your preoperational testing program. As a result of that conversation it was agreed that it is not required for Cleveland Electric Illuminating to continue sending preliminary copies of preoperational test procedures to Region III. Instead, copies of the current status of the procedures and their implementation will be forwarded to the Regional Office whenever the status is updated (at least monthly). Additionally, the most current revision of individual procedures will be forwarded to the Regional Office when requested.

The following procedures are requested for submittal to Region III at this time:

1. Preoperational Test for 125 vdc batteries and distribution
2. Preoperational Test for the Standby Liquid Control System
3. Containment Types A and C Leak Rate Test Procedure
4. Preoperational Test for Low Pressure Core Spray
5. Preoperational tests for Emergency Diesel Generators
6. Procedures which implement the QA Program requirements for the Preoperation Testing Program

Please submit the above to the attention of Mr. I. N. Jackiw. Your continued prompt attention to the requirements for testing program review are appreciated.

Sincerely,



W. S. Little, Chief
Engineering Inspection Branch

8210190619 821015
PDR ADOCK 05000440
A PDR

cc: DMB/Document Control Desk (RIDS)

OFFICE	Resident Inspector, RIII	R III	R III	R III	R III
SURNAME	Harold W. Kohn, Power Siting Commission	Reimann/lc	JacRiw	Konklin	Little
DATE	Daniel D. Wilt, Attorney Felen W. Evans, State of Ohio	10/12/82		10/14/82	