

STONE & WEBSTER ENGINEERING CORPORATION



245 SUMMER STREET, BOSTON, MASSACHUSETTS

ADDRESS ALL CORRESPONDENCE TO P.O. BOX 2325, BOSTON, MASS. 02107

NEW YORK
BOSTON
CHICAGO
HOUSTON
DENVER
CHERRY HILL, N.J.
PORTLAND, OREGON

DESIGN
CONSTRUCTION
REPORTS
EXAMINATIONS
CONSULTING
ENGINEERING

Mr. Richard C. DeYoung
Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

March 31, 1983

BEAVER VALLEY POWER STATION-UNIT NO. 1
DUQUESNE LIGHT COMPANY
AMENDMENT OF 10CFR21 REPORT

Stone & Webster Engineering Corporation (SWEC), pursuant to the provisions of 10CFR21, provided notification to NRC on December 10, 1982 by telephone and by letter dated December 10, 1982 of a "defect" concerning the Beaver Valley Power Station Unit No. 1. The subject of our notification was defective mechanical shock suppressors supplied by Pacific Scientific Company and tested by Wyle Laboratories.

Further investigation shows that the corrective action taken (para vii of our December 10, 1982 letter) was to replace the defective shock suppressors with new shock suppressors. Of the 11 mechanical shock suppressors which were in question, it is understood that four are disassembled and stored at Pacific Scientific Company. The remaining seven are held in a warehouse in Midland, PA.

If you require any further information, please contact Mr. J.R.Coombe at (617) 589-8990.

P.A. Wild
Director of Engineering

IE19

8304060234 830331
PDR ADOCK 05000334
S PDR