

LICENSEE EVENT REPORT

CONTROL BLOCK:										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
01 MIPAL1 200-00000-000341111 4 5										LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT									
01 L605000025570927828 1011182 9										REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)																			
02 During normal plant operation, boric acid heat trace circuit 432 failed.																			
03 Redundant channel remained operable. No threat to public health or safety.																			
04 Condition reportable per TS 3.2.2.d and 6.9.2.b(2).																			
05																			
06																			
07																			
08																			
09																			
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE																			
RB E A HEATER Z Z																			
LER RD REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.																			
82 030 03 L 0																			
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER																			
A Z Z 0000 N Y A C332																			
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																			
10 Event caused by blown fuse in controller. Circuitry was tested and fuse																			
11 replaced to restore operability.																			
12																			
13																			
14																			
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION																			
E 100 NA A Observation																			
ACTIVITY RELEASED CONTENT OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE																			
Z Z NA NA																			
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION																			
000 Z NA																			
PERSONNEL INJURIES NUMBER DESCRIPTION																			
000 NA																			
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION																			
Z NA																			
PUBLICITY ISSUED DESCRIPTION																			
N NA																			
NRC USE ONLY																			