

June 8, 1994

Mr. Douglas R. Gipson
Senior Vice President
Nuclear Generation
Detroit Edison Company
6400 North Dixie Highway
Newport, Michigan 48166

Dear Mr. Gipson:

SUBJECT: FERMI-2 - RESPONSE TO NRC BULLETIN 93-02, SUPPLEMENT 1, "DEBRIS
PLUGGING OF EMERGENCY CORE COOLING SUCTION STRAINERS" (TAC NO.
M89287)

This letter acknowledges receipt of your response dated April 19, 1994, to NRC Bulletin 93-02, Supplement 1 (Bulletin). The Bulletin was issued February 18, 1994, for action to all Boiling Water Reactor (BWR) licensees and for information to all Pressurized Water Reactor (PWR) licensees. The purpose of the Bulletin was to inform BWR and PWR licensees about the vulnerability of ECCS suction strainers in BWRs and containment sumps in PWRs to clogging during the recirculation phase of a loss-of-coolant accident (LOCA), to request that BWR licensees take the appropriate actions to ensure reliability of the ECCS in view of the information discussed in this bulletin supplement, and to require that BWR licensees report to the NRC on the requested actions taken. Your response adequately addressed the actions you have taken and will take to assure the operability of ECCS recirculation. We await your report confirming completion of the requested actions. Please retain any records of your actions in response to this Bulletin, as subsequent inspection activities may be conducted in regard to this issue.

Should you have any questions, please contact me at (301) 504-1341 or the lead Project Manager for this issue, John B. Hickman, at (301) 504-3017.

Sincerely,

Original signed by

Timothy G. Colburn, Sr. Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

9406130233 940608
PDR ADDOCK 05000341
PDR

100015

cc: see next page

DISTRIBUTION:

Docket File TColburn
NRC & Local PDRs JHickman
PD31 Reading File RElliott, 8H7
JRoe CJamerson
JZwolinski OGC
LBMarsh ACRS (10)

M. Phillips, RIII

NRC FILE CENTER COPY

cc: Plant Service list

OFFICE	LA:PD31	PM:PD31	BC:SCSB	D:PD31
NAME	CJamerson	TColburn:gll	RJBarrett	LBMarsh
DATE	05/25/94	05/25/94	05/18/94	05/18/94

DFOI 10

Mr. Douglas R. Gipson
Detroit Edison Company

Fermi-2

cc:

John Flynn, Esquire
Senior Attorney
Detroit Edison Company
2000 Second Avenue
Detroit, Michigan 48226

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3423 N. Logan Street
P. O. Box 30195
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission
Resident Inspector Office
6450 W. Dixie Highway
Newport, Michigan 48166

Monroe County Office of Civil
Preparedness
963 South Raisinville
Monroe, Michigan 48161

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Robert Newkirk
Director - Nuclear Licensing
Detroit Edison Company
Fermi-2
6400 North Dixie Highway
Newport, Michigan 48166