

3/4.6 CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. Verifying that each unit operates for at least 15 minutes.
 3. Verifying a cooling water flow rate of ≥ 2000 gpm to each cooling unit when the full flow service water outlet valves are fully open.
- REFUELING INTERVAL
- b. At least once per ~~18 months~~ by verifying that each unit starts automatically on the appropriate ESFAS test signal.

ATTACHMENT (2)

UNIT 2
TECHNICAL SPECIFICATION
MARKED-UP PAGE

3/4 6-15

3/4.6 CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. Verifying that each unit operates for at least 15 minutes.
 3. Verifying a cooling water flow rate of ≥ 2000 gpm to each cooling unit when the full flow service water outlet valves are fully open.
- REFUELING INTERVAL
- b. At least once per ~~18~~ months by verifying that each unit starts automatically on the appropriate ESFAS test signal. /