

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | N | P | I | N | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
7 8 9 14 15 25 26 30 57 58

CON'T  
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 0 | 6 | 7 | 0 | 9 | 0 | 8 | 8 | 2 | 8 | 1 | 0 | 0 | 8 | 8 | 2 | 9  
7 8 60 61 68 69 74 75 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During surveillance test, 1. undervoltage relays were found to trip outside  
0 3 | their tolerance band of 90±2% of nominal voltage.  
0 4 | Relay 27A1/B25 for Bus 25 tripped at 92.13% and relay 27A1/B26 tripped at 95.17%  
0 5 | Tech Spec Table 3.5-1, Item 10, applies. Recent similar event was RO 81-30.  
0 6 | No effect on public health and safety since other relays in logic scheme  
0 7 | would have prevented improper operation.  
0 8 | \_\_\_\_\_

0 9 | SYSTEM CODE: E B (11) CAUSE CODE: X (12) CAUSE SUBCODE: Z (13) COMPONENT CODE: Z Z Z Z Z Z Z (14) COMP. SUBCODE: X (15) VALVE SUBCODE: Z (16)  
17 | LER RO REPORT NUMBER: 8 2 (17) SEQUENTIAL REPORT NO.: 0 1 7 (18) OCCURRENCE CODE: 0 3 (19) REPORT TYPE: L (20) REVISION NO.: 0 (21)  
ACTION TAKEN: E (18) FUTURE ACTION: X (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: N (23) NPRD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: Z (25) COMPONENT MANUFACTURER: Z 9 9 9 (26)

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Relays were recalibrated and found to operate properly.  
1 1 | Subsequent routine testing showed that the relays operate properly.  
1 2 | \_\_\_\_\_  
1 3 | \_\_\_\_\_  
1 4 | \_\_\_\_\_

1 5 | FACILITY STATUS: E (28) % POWER: 1 0 0 (29) OTHER STATUS: NA (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Surveillance Test (32)

1 6 | ACTIVITY CONTENT: Z (33) Z (34) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES: 0 0 0 (37) Z (38) DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES: 0 0 0 (40) DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: Z (42) DESCRIPTION: NA (43)  
8210190745 821008  
PDR ADOCK 05000306  
R PDR

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: NA (45)

GPO #17-926