NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NCBEP2 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 050-0324 (7) | 092182 (8) | (9)
DOCKET NUMBER (61–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing an operability test of the Radwaste Building Fire Detection System,
03 fire protection group personnel discovered fire hose station RW-49, located on the
04 -3' elevation of the Radwaste Building, was inoperable due to a disconnected fire hose.
05 This event did not affect the health and safety of the public.
06 Technical Specifications 3.7.7.4, 6.9.1.9b
07
08

09 SYSTEM CODE AB (11) | CAUSE CODE A (12) | CAUSE SUBCODE X (13) | COMPONENT CODE XXXXXX (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 | — | SEQUENTIAL REPORT NO. 108 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER A167 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 It is not known why or by whom the fire hose was disconnected. The hose, Model No.
11 SYN149, was reconnected and the hose station returned to service within five minutes
12 of the event discovery. The plant general employee and annual retraining programs
13 will be revised by 1-1-83 instructing against utilizing plant fire fighting equipment
14 for any purpose other than fire fighting.

15 FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Plant Technical Surveillance

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41)

8210190759 821015
PDR ADOCK 05000324
S PDR

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926