

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

March 30, 1983

Mr. Ronald C. Haynes, Director
U. S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406

Docket No. 50-317
License No. DPR 53

SUBJECT: Cancellation of LER 83-12/1T (U-1 & U-2)

Dear Mr. Haynes:

This letter is to cancel LER 83-12 describing a design setting error discovered in Units 1 and 2 Main Feedwater Regulating Bypass Valves.

A detailed review of the Main Feedwater Regulating Bypass Valve setting commenced upon submission of LER 83-12/1T. An error in the calculation used to determine the flow through the Main Feedwater Regulating Bypass Valves was discovered during this review. The original Main Feedwater Regulating Bypass Valve settings would allow 5% feed flow, which is within the assumed flow for a Main Steam Line Break accident. Consequently, an LER is not warranted.

Very truly yours,

L B Russell
L. B. Russell
Plant Superintendent

LBR:MAJ:bsb

cc: Director, Office of Management Information
and Program Control

Messrs: A. E. Lundvall, Jr.
J. A. Tiernan
R. M. Douglas
L. B. Russell
J. M. Moreira
M. A. Junge
R. E. Architzel

8304120358 830330
PDR ADOCK 05000317
S PDR

IE 22