

DAVIS-BESSE, UNIT 1

3/4 3-30

Amendment No. 4, 43 46

TABLE 4.3-11

STEAM AND FEEDWATER RUPTURE CONTROL SYSTEM
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
1. Instrument Channel			
a. Steam Line Pressure - Low	S	R	H ⁺
b. Steam Generator Level - Low	S	R*	M
c. Steam Generator - Feedwater Differential Pressure-High	S	R	M
d. Reactor Coolant Pumps-Loss of	S	R	M
2. Manual Actuation	NA	NA	R

~~*Eighteen-month surveillance test due in March 1982 delayed until~~
~~March 31, 1982.~~

+ The surveillance period for Steam Line Pressure - low instrument is extended to 2400 hours, September 16, 1982.