



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

March 30, 1983

DJS Letter #83-343

James G. Keppler, Regional Adm.
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reportable Occurrence Report #83-09/03L-0, Docket #050249 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B..2(d), abnormal degradation of systems other than those specified in item B.1.e. above designed to contain radioactive material resulting from the fission process.

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC, Document Mgt. Branch
File/NRC

IE22

8304120377 830330
PDR ADOCK 05000249
S PDR

APR 6 1983



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 STA 3 UNIT 83 YEAR 16 NO.

PART 1 TITLE OF DEVIATION OCCURRED
Feedwater Heater 3C3-3104 Steam Leak 3-7-83 0745
DATE TIME

SYSTEM AFFECTED 3500 PLANT STATUS AT TIME OF EVENT TESTING
Low Pressure Feedwater Heaters MODE Run, PWR(MWT) 1528, LOAD(MWE) 477 YES NO

DESCRIPTION OF EVENT Heater 3C3-3104 has steam leak on shell side. Steam blowing thru insulation.

10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO

EQUIPMENT FAILURE D26234 WORK REQUEST NO. RESPONSIBLE SUPERVISOR M. Korchynsky DATE 3-7-83

PART 2 OPERATING ENGINEER'S COMMENTS The 3C3 feedwater heater was isolated and the shell leak will be repaired per approved station work package.

- EVENT OF PUBLIC INTEREST
TECH. SPEC. VIOLATION
NON REPORTABLE OCCURRENCE
14 DAY REPORTABLE/T.S.
30 DAY REPORTABLE/T.S. 6.B.2.d
ANNUAL/SPECL REPORT REQ'D

24-HOUR NRC NOTIFICATION REQ'D TELEPH REGION III DATE TIME
TELEGM/TELECOPY REGION III DATE TIME

CECO CORPORATE NOTIFICATION MADE IF ABOVE NOTIFICATION IS PER 10CFR21
5-DAY WRITTEN REPORT REQ'D PER 10CFR21
Telecopy Dennis P. Galle 3-9-83 1315
CECO CORPORATE OFFICER DATE TIME

PRELIMINARY REPORT COMPLETED AND REVIEWED T.A. Ciesla 3-9-83
OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW
4/4/83 4-5-83

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION
Douglas Dewitt 4/5/83
STATION SUPERINTENDENT DATE