

DAVIS-BESSE, UNIT 1

3/4 2-30

Amendment No. A, 43

TABLE 4.3-11

STEAM AND FEEDWATER MPTURE CONTROL SYSTEM  
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
1. Instrument Channel:			
a. Steam Line Pressure - Low	S	R	R <sup>+</sup>
b. Steam Generator Level - Low	S	R*	R
c. Steam Generator - Feedwater Differential Pressure-High	S	R	R
d. Reactor Coolant Pumps-Loss of	S	R	R
2. Manual Actuation	NA	NA	R*

\*Eighteen-month surveillance test due in March 1982 delayed until March 31, 1982.

+ The Surveillance Period for Steam Line Pressure - Low Switches is extended by 96 hours to end at 2400 hours on 9/16/82.

Attachment 1  
Docket No. 50-345  
License No. NPF-3