Docket Nos: 50-413 and 50-414

APPLICANT: Duke Power Company

FACILITY: Catawba Nuclear Station, Units 1 and 2

SUBJECT: SUMMARY OF MEETING ON INSTRUMENTATION AND CONTROL

CONCERNS AND OPEN ITEMS

A site visit and meetings to ciscuss the NRC Instrumentation and Control Systems Branch (ICSB) concerns were held from September 7, 1982, through September 9, 1982, between the NRC staff and representatives from Duke Power Company. Enclosures 1 and 2 provide the lists of attendees. Enclosure 3 provides a summary and status of ICSB concerns and open items.

At the conclusion of the meeting, Duke agreed to provide responses to these items on or about the end of October 1982, except where specifically noted otherwise.

Sincerely.

Kahtan N. Jabbour, Project Manager

Licensing Branch No. 4 Division of Licensing

Enclosures: As stated

cc: See next page

B210220026 B21015 PDR ADOCK 05000413 A PDR

OFFICE DL: LB #4 KNJ	LA:DLALB #4	DL: LB #4			
SI NAME KJabbour/hmc	MDuncan	EAdensam	 	*****************	
DATE \$ 0/14/82	19/14/82	19/14/82	 ***************************************	***************************************	
-					

Mr. H. B. Tucker, Vice President Nuclear Production Dept. Duke Power Company 422 South Church Street Charlette North Carolina 28242

cc: William L. Porter, Esq.
Duke Power Company
P.O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Debevoise & Liberman 1200 Seventeenth Street, N.W. Washington, D. C. 20036

North Carolina MPA-1 P.O. Box 95162 Raleigh, North Carolina 27625

Mr. F. J. Twogood Power Systems Division Westinghouse Electric Corp. P.O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. J. C. Plunkett, Jr. NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

Mr. Jesse L. Riley, President Carolina Environmental Study Group 854 Henley Place Charlotte, North Carolina 28208

Richard P. Wilson, Esq. Assistant Attorney General S.C. Attorney General's Office P.O. Box 11549 Columbia, South Carolina 29211

Mr. Henry Presler, Chairman Charlotte - Mecklenburg Environmental Coalition 943 Henly Place Charlotte, North Carolina 28207 North Carolina Electric Membership Corp. 3333 North Boulevard P.O. Box 27306 Raleigh, North Carolina 27611

Saluda River Electric Cooperative, Inc. 207 Sherwood Drive Laurens, South Carolina 29360

Mr. Peter K. VanDoorn Route 2, Box 179N York, South Carolina 29745

James P. O'Reilly, Regional Administrator
U.S. Nuclear Pegulatory Commission,
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Robert Guild, Esq. 314 Pall Mall Columbia, South Carolina 29201

Palmetto Alliance 2135 1/2 Devine Street Columbia, South Carolina 29205

Enclosure 1

List of Attendees

September 7, 1982

NRC

K. Jabbour

T. Dunning

F. Burrows

V. Elsbergas (ANL)

Duke Power Company

R. Sharpe

T. Ford

I. Moss

D. Murdock

C. Hartzell

M. Miller

W. Barfield

N. Jain

L. Reed

R. Spangler

T. McMeekin

R. Dickard

R. Misenheimer

G. Hedrick

C. Rolfe

OFFICE SURNAME DATE DATE

Enclosure 2

List of Attendees

September 8, 1982

NRC

T. Dunning

F. Burrows

V. Elsbergas (ANL)

Duke Power Company

R. Sharpe

T. Ford I. Moss

D. Murdock

C. Hartzell

J. Plummer

M. Efird

N. Jain

A. Current M. Miller

R. Dickard

-				
OFFICE		 	 	
SURNAME		 	 	
DATE	*************************	 ***************************************	 	

Enclosure 3

SUMMARY AND STATUS OF INSTRUMENTATION

& CONTROL CONCERNS AND OPEN ITEMS

FOR CATAWBA

SER OPEN ITEMS:

- Steam Generator Level Control and Protection Applicant is still looking at possible hardware changes. This item remains open.
- Auxiliary Feedwater System Applicant has been requested to provide written responses to our positions. This item is open.
- TMI-2 Action Plan Item II.E.1.2, Auxiliary Feedwater System Automatic Initiation and Flow Indication -
 - (a) Automatic Initiation Part of 2 above.
 - (b) Flow Indication Applicant's response (See 420.7) is acceptable. This part is closed.
- 4. Test of Engineered Safeguards P-4 Interlock Applicant's response (See 420.5) is acceptable. This item is closed and installation will be confirmatory.
- 5. Mon-Detectable Failure in Power Lockout Circuitry Applicant's design change is acceptable, but they should commit to test circuitry in the closure direction at least once per refueling outage. This item remains open.
- Main Feedwater Isolation on High Doghouse Level Applicant's response was acceptable. Technical Specifications should be developed to test this circuitry during refueling outages.

- Switchover from Injection to Recirculation Mode Applicant's response was acceptable. This item is closed.
- 8. Steam Generator PORV Isolation Part of 2 above.
- 9. Containment Pressure Control System Applicant's response was acceptable, but the staff is concerned about lack of indication for each containment pressure transmitter. Additionally, technical specifications should be developed by expanding "Functional Unit 2, Containment Spray" in Tables 3.3-4 and 4.3-2 of the Standard Westinghouse Technical Specifications to include all the Containment Pressure Control System (spray, air return, hydrogen skimmer, etc.) and the low pressure interlocks. The test frequencies for the low pressure interlocks should be:Channel Check Daily, Channel Calibration once per 18 months, Analog Channel Operational Test monthly. This item is open.
- 10. Remote Shutdown Instrumentation and Controls This item is open.
- 11. Instrumentation Used to Initiate Safety Functions Applicant has been requested to provide written responses to our positions. This item is open.
- 12. Upper Head Injection Automatic Termination Staff is still concerned about testing. Technical Specifications should be developed by adding Upper Head Injection Accumulator to Tables 3.3-4, 3.3-5 and 4.3-2 of the Standard Westinghouse Technical Specifications. The test frequency for manual actuation (see 13 below) should be "R" under "Trip Actuating Device Operational Test".

 The test frequencies for low level termination should be: Channel Calibration once per 18 months, Trip Actuating Device Operational Test Each train tested every 62 days on a staggered test basis.

- 13. Upper Head Injection Manual Control This item is open.
- 14. Upper Head Injection Level Indication This item is open.
- 15. TMI-2 Action Plan Item II.K.3.1, Installation and Testing of

 Automatic Power-Operated Relief Valve Isolation System This item is open.
- 16. High Energy Line Breaks and Consequential Control System Failures
 The applicant has been requested to look at the environmental impacts of high energy line breaks and will respond around November 15, 1982. This item is open.

CONCERNS/TECHNICAL SPECIFICATIONS:

- 1. Lockout of Manual Control by Load Sequencer Applicant's response was acceptable. However, the staff is concerned that some protective actions may not be initiated due to manual resetting of SI and the sequencer (after 30-120 sec. time delay). This concern is open for further discussions.
- 2. Key-Locked Switches Used to Override Isolation of HVAC Systems -Applicant will provide design change to insure these key-locked switches do not block safety action. This concern is open until design change write-up is provided. Installation will be confirmatory.
- Loss of Both Trains of RHR Due to Single Instrument Bus Failure This concern is open for further discussion.

- 4. Water Level Measurement Errors (SER Section 7.2.2.3) -Applicant is considering Westinghouse microprocessor based system in lieu of insulation on the reference legs. The staff will review the applicant's method during our review of setpoint methodology and technical specifications.
- 5. Response Time Testing (SER Section 7.2.2.5) Applicant intends to deviate from the Standard Westinghouse Technical Specifications. The staff has suggested that the applicant provide a formal presentation prior to cur review of the technical specifications.
- Testing of Reactor Trip Breakers and Manual Trip Switches (SER Section 7.2.2.1) - The applicant opposes testing of the shunt trip coils. This item is open for further discussion.
- 7. Testability of Circuitry for Transfer of NSW Suction from Lake Wylie to SNSWP (SER Section 7:4.2.4) - The applicant's response was unacceptable. This item remains open for further discussion.
- 8. NSW Pump Damage Due to a Single Failure A single failure may prevent an inlet valve from the SNSWP from opening while the normal inlet valves from Lake Wylie close on the SI/Low Level transfer. The staff is concerned that an NSW pump could be damaged due to lack of suction. This item is open for further discussions.

MEETING SUMMARY DISTRIBUTION

Docket No(s): 50-413/414

NRC/PDR Local PDR TIC/NSIC/TERA LB #4 r/f Attorney, OELD

OIE

E. Adensam

Project Manager K. Jabbour
Licensing Assistant M. Duncan

NRC Participants:

K. Jabbour

T. Dunning F. Burrows

V. Elsbergas (ANL)

bcc: Applicant & Service List

OCT 1 5 1982