



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 7, 1983

JAMES P. MCGAUGHY, JR.  
VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-014/0 - Fire  
Rated Penetration Opened  
AE 83/0209

83 APR 11 4 49  
REGION II  
ATLANTA

On March 1, 1983, fire rated penetration TE-14B (Elevation 113 feet, Turbine Building) was opened to install a raceway as instructed by a design change package. An hourly firewatch was established and will be maintained for the duration of the Limiting Condition for Operation in accordance with Technical Specification 3.7.7.

The penetration will be resealed upon completion of the work task. The estimated completion date for the task is May 15, 1983. This is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

*J.P. McGaughey, Jr.*  
FOR J.P. McGaughey, JR

JPM:sap

- cc: Mr. J. B. Richard  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

OFFICIAL COPY

8304130313 830407  
PDR ADDCK 05000416  
S PDR

IF 22