

TABLE 2 2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (S)	TRIP SETPOINT	ALLOWABLE VALUE
1. Manual Reactor Trip	N.A.	N.A.	N.A.	N.A.	N.A.
2. Power Range, Neutron Flux					
a. High Setpoint	7.5	4.56	0	≤109% of RTP*	≤112.3% of RTP*
b. Low Setpoint	8.3	4.56	0	≤25% of RTP*	≤28.3% of RTP*
3. Power Range, Neutron Flux, High Positive Rate	2.4	0.5	0	≤4% of RTP* with a time constant ≥2 seconds	6.3% of RTP* with a time constant ≥2 seconds
4. Power Range, Neutron Flux, High Negative Rate	2.4	0.5	0	≤4% of RTP* with a time constant ≥2 seconds	≤6.3% of RTP* with a time constant ≥2 seconds
5. Intermediate Range, Neutron Flux	17.0	8.41	0	≤25% of RTP*	≤35.3% of RTP*
6. Source Range, Neutron Flux	17.0	10.01	0	≤10 <sup>5</sup> cps	≤1.6 x 10 <sup>6</sup> cps
7. Overtemperature ΔT	7.0	5.39 4.86	1.67	See Note 1	See Note 2
8. Overpower ΔT	4.6	2.02	0.14	See Note 3	See Note 4
9. Pressurizer Pressure-Low	3.7	0.71	2.49	≥1915 psig	≥1906 psig
10. Pressurizer Pressure-High	7.5	0.71	2.49	≤2385 psig	≤2400 psig
11. Pressurizer Water Level-High	8.0	2.18	1.53	≤92% of instrument span	≤93.9% of instrument span

\*RTP = RATED THERMAL POWER

\*\*Loop design flow - 93,600 gpm

WOLF CREEK - UNIT 1  
 PDR ADDCK 05000482  
 PDR

2-4 Amendment No. 7, 23, 51, 52, 61, 69, 72,

## TABLE 2.2-1 (Continued)

## TABLE NOTATIONS (Continued)

## NOTE 1: (Continued)

$T$   $\leq$  586.5°F (Nominal  $T_{avg}$  at RATED THERMAL POWER);

$K_3$  = 0.000671;

$P$  = Pressurizer pressure, psig;

$P'$  = 2235 psig (Nominal RCS operating pressure);

$S$  = Laplace transform operator,  $s^{-1}$ ;

and  $f_1(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant STARTUP tests such that:

- (i) for  $q_t - q_b$  between ~~-2325%~~ and +5%,  $f_1(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent that the magnitude of  $q_t - q_b$  exceeds ~~-2325%~~, the  $\Delta T$  Trip Setpoint shall be automatically reduced by ~~2.2748%~~ of its value at RATED THERMAL POWER; and
- (iii) for each percent that the magnitude of  $q_t - q_b$  exceeds +5%, the  $\Delta T$  Trip Setpoint shall be automatically reduced by ~~1.841384%~~ of its value at RATED THERMAL POWER.

NOTE 2: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than ~~1.318%~~ of  $\Delta T$  span.