NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ILQADI (2) | 000-000-000 | 4 1 1 1 1 1 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L (6) | 0500025 4 (7) | 081682 (8) | 100782 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On August 16, 1982, a maintenance outage for the 1/2B Diesel Fire Pump exceeded
03 the seven day limit as specified in Technical Specification 3.12.B.2 Redundant
04 fire system water was supplied during this time by the 1/2A Diesel Fire Pump, the
05 Service Water System, and a 3160 gallon per minute portable Diesel Fire Pump.
06 Procedures are provided for operation of this equipment. Thus, there is no
07 significant affect on safe plant operation associated with this occurrence.
08

09 SYSTEM CODE AB (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE PUMPXX (14) | COMP SUBCODE B (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 022 / OCCURRENCE CODE 03 | REPORT TYPE L — | REVISION NO. 1

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER L095 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The 1/2B Diesel Fire Pump wear rings were replaced, and the pump was then assembled.
11 On September 14, 1982, the 1/2B pump was tested and was found to be operable. Thus,
12 the failure to pass surveillance criteria was apparently the result of worn wear
13 rings.
14

15 FACILITY STATUS E (28) | % POWER 05 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

8210250153 821007
PDR ADOCK 05000254
S PDR

NRC USE ONLY

NAME OF PREPARER H Lihou PHONE 309-654-2241, ext. 244

GPO 917-926