

GENERAL ELECTRIC

APPLICABLE TO:	
PUBLICATION NO.	<u>NEDO-24146A</u>
T. I. E. NO.	<u>79NED273</u>
TITLE	<u>LOCA ANALYSIS REPORT FOR</u> <u>DRESDEN UNITS 2, 3 AND QUAD</u> <u>CITIES 1,2 NUCLEAR POWER STATIONS</u>
ISSUE DATE	<u>April 1979</u>

ERRATA And ADDENDA SHEET

NO.	<u>8</u>
DATE	<u>September 1982</u>
<i>NOTE: Correct all copies of the applicable publication as specified below.</i>	

ITEM	REFERENCES (SECTION, PAGE PARAGRAPH, LINE)	INSTRUCTIONS (CORRECTIONS AND ADDITIONS)
1.	Page 4-10	Replace with new page 4-10. (Change brackets in right-hand margin indicate areas where report has been revised.)

Table 4E
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D250

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.2	2106	0.024
1,000	11.3	2109	0.024
5,000	11.9	2169	0.029
10,000	12.1	2179	0.029
15,000	12.2	2198	0.031
20,000	12.0	2199	0.031
25,000	11.5	2148	0.027
30,000	10.6	2020	0.017
35,000	9.6	1888	0.011
40,000	9.0	1808	0.008

Table 4F
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8D262

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.1	2104	0.024
1,000	11.3	2107	0.024
5,000	11.9	2166	0.029
10,000	12.1	2175	0.029
15,000	12.2	2199	0.031
20,000	12.0	2199	0.032
25,000	11.6	2157	0.028
30,000	10.7	2042	0.019
35,000	9.8	1915	0.012
40,000	9.2	1831	0.009

Table 4G
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Dresden 2,3/Quad Cities 1,2

FUEL TYPE: 8DRB265L

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.6	2189	0.035
1,000	11.6	2188	0.034
5,000	11.8	2198	0.034
10,000	11.9	2196	0.033
15,000	11.9	2198	0.034
20,000	11.7	2195	0.034
25,000	11.3	2154	0.030
30,000	10.7	2075	0.023
35,000	10.2	2002	0.018
40,000	9.6	1913	0.013

Table 4H
MAPLHGR VERSUS AVERAGE PLANAR EXPOSURE

PLANT: Quad Cities 1

FUEL TYPE: Barrier LTA

<u>Average Planar Exposure (MWd/t)</u>	<u>MAPLHGR (kW/ft)</u>	<u>PCT (°F)</u>	<u>Oxidation Fraction</u>
200	11.6	2171	0.032
1,000	11.6	2178	0.033
5,000	12.0	2198	0.034
10,000	12.1	2195	0.033
15,000	12.0	2200	0.033
20,000	11.7	2187	0.032
25,000	11.0	2115	0.056
30,000	10.5	2029	0.042
40,000	9.3	1913	0.013