

ORIGINAL

ACRST-2006

OFFICIAL TRANSCRIPT OF PROCEEDINGS

o/ TR04 (ACRS)
RETURN ORIGINAL TO
B.J.WHITE, ACRS-P-315

THANKS! BARBARA JO
#27288

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: 410th ACRS Meeting

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, June 9, 1994

PAGES: 1 - 132

ACRS Office Copy - Retain
for the Life of the Committee

150036

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9406150056 940609
PDR ACRS
T-2006 PDR

ORIGINAL

ACRST-2006

OFFICIAL TRANSCRIPT OF PROCEEDINGS

o/i
TR04 (ACRS)
RETURN ORIGINAL TO
B.J.WHITE, ACRS-P-315

THANKS! BARBARA JO
#27288

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: 410th ACRS Meeting

Docket No.

LOCATION: Bethesda, Maryland

DATE: Thursday, June 9, 1994

PAGES: 1 - 182

ACRS Office Copy - Retain
for the Life of the Committee

150086

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

9406150056 940609
PDR ACRS
T-2006 PDR

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: June 9, 1994

The contents of this transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards, (date) June 9, 1994, as Reported herein, are a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected or edited, and it may contain inaccuracies.

ANN RILEY & ASSOCIATES, Ltd.
Court Reporters
1612 K. Street, N.W., Suite 300
Washington, D. C. 20006
(202) 293-3950

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

410th ACRS Meeting

U.S. Nuclear Regulatory Commission
Conference Room P-110
7920 Norfolk Avenue
Bethesda, Maryland

Thursday, June 9, 1994

The above-entitled proceedings commenced at 8:30
a.m., pursuant to notice, T. Kress, Chairman, presiding.

ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1250 I Street, N.W., Suite 300
Washington, D.C. 20005
(202) 842-0034

1 PRESENT FOR THE ACRS:
2

3 T. Kress, Chairman

4 W. Lindblad, Vice Chairman

5 J. Carroll

6 C. Michelson

7 C. Wylie

8 I. Catton

9 R. Seale

10 P. Davis

11 W. Shack

12 D. Powers, Prospective Member

13 J. Larkins, Executive Director

14 S. Schofer, Technical Secretary
15
16
17
18
19
20
21
22
23
24
25

ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1250 I Street, N.W., Suite 300
Washington, D.C. 20005
(202) 842-0034

1 PRESENT FOR NRC/NRR:

2

3 F. Kantor

4 J. Lee

5 F. Congel

6 J. Wilson

7 J. O'Brien

8 M. Virgilio

9 C. McCracken

10 S. West

11 W. Travers

12 S. Reynolds

13 S. Newberry

14 P.T. Kuo

15 S. Lee

16 ALSO PRESENT:

17

18 A. Mohseni, NRC/AEOD

19 A. Marion, NEI

20 G. Wu, NEI

21

22

23

24

25

ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1250 I Street, N.W., Suite 300
Washington, D.C. 20005
(202) 842-0034

P-R-O-C-E-E-D-I-N-G-S

[8:30 a.m.]

1
2
3 MR. KRESS: The meeting will now come to order,
4 please.

5 This the first day of the 410th meeting of the
6 Advisory Committee on Reactor Safeguards. During today's
7 meeting, the committee will discuss or hear reports on the
8 following:

- 9 (1) Protective action guidelines;
10 (2) fire protection-related matters;
11 (3) proposed revisions to the license renewal
12 rule;
13 (4) report of the planning and procedures
14 subcommittee;
15 (5) proposed ACRS reports.

16 Portions of today's meeting may be closed to
17 discuss organizational and personnel matters that relate
18 solely to the internal personnel rules and practices of the
19 Advisory Committee and matters the release of which would
20 represent a clearly unwarranted invasion of personal
21 privacy.

22 This meeting is being conducted in accordance with
23 the provisions of the Federal Advisory Committee Act.

24 Dr. John T. Larkins is the Designated Federal
25 Official for the initial portion of the meeting.

1 We have received no written statements or requests
2 for time to make oral statements from members of the public
3 regarding today's sessions. A transcript of portions of the
4 meeting is being kept and it is requested that each speaker
5 use one of the microphones, identify himself and speak with
6 sufficient clarity and volume so that he can be readily
7 heard.

8 I will begin with some items of current interest.

9 First, I would like to introduce to the Committee
10 and others present our summer interns and co-op students.
11 We have Heather Richmond is our summer technical intern from
12 Carnegie Mellon University. She will be a senior there in
13 chemical and biomedical engineering this fall. And during
14 this first rotation, she will be assisting in the
15 development of the ZY Index system. Even I don't know what
16 that is. Maybe she can tell us. And the development of
17 instructions for the use of the Internet and the Mosaic
18 interface.

19 Heather.

20 MS. RICHMOND: This is only my first day and I am
21 still learning myself. But it is a retrieval and storage
22 package so we can cut down on the paperwork.

23 MR. KRESS: Wonderful. Thank you.

24 Amy Blandford is a junior in nuclear engineering
25 at Purdue and she has been here before. During her previous

1 rotation, she completed an informational high-level waste
2 canister design report.

3 For her fourth co-op rotation, she will be working
4 on a project dealing with the Thermo-Lag issues.

5 MR. CATTON: I need all the help I can get.

6 MR. KRESS: We know.

7 MR. CARROLL: I was going to say she's a lucky
8 lady.

9 [Laughter.]

10 MR. KRESS: Chad Little is a senior in electrical
11 engineering at the University of Pittsburgh. During his
12 previous rotation, Chad completed a study on the reliability
13 of microprocessors. For his fourth rotation, he will be
14 helping to further refine the computing needs of the
15 Committee through the use of Mosaic and video
16 teleconferencing.

17 Chad, we're glad to have you with us.

18 [Applause.]

19 MR. KRESS: I would like to also welcome back Dana
20 Powers. My understanding is you are very close but not
21 quite.

22 Yes, John?

23 MR. LARKINS: I think it is my understanding that
24 as of this -- yesterday afternoon, he has a Q clearance so
25 he can now officially vote as a member.

1 MR. KRESS: The most surprising thing about that
2 is that they could actually get him a Q clearance.

3 MR. SHACK: Put him to work.

4 MR. KRESS: I guess you can now vote, Dana,
5 officially vote.

6 There is a yellow thing I would like to call your
7 attention to. This is a farewell reception for Commissioner
8 Remick. It is on June 27, so if you are going to be in town
9 and wish to attend this at the Crowne Plaza, you will need
10 reservations. I just wanted to point that out for you.

11 We do plan on, if you recall, taking Commissioner
12 Remick to dinner tonight. So if you haven't signed up for
13 that and wish to go, please do so.

14 I also --

15 MR. CARROLL: How do I know if I signed up. I
16 sent something back to Barbara --

17 MR. KRESS: Just show up. You don't have to sign
18 up. We're going to O'Donnell's

19 [Discussion off the record.]

20 MR. KRESS: There is also a SECY somewhere at your
21 place which is SECY-94-117 which lays out some revised Staff
22 schedules for the design certification applications. I'll
23 just -- it shows some slippage in the schedules. You will
24 be interested in looking at those.

25 There are some of the Commissioners that have

1 differing views on the subject. You have a letter from
2 Commissioner Remick and I invite you to read it.

3 With that, I will ask if there are any other
4 members who wish to bring up anything before we start with
5 the technical portions?

6 [No response.]

7 MR. KRESS: Seeing none, I'll introduce the first
8 topic of the day, which is -- Oh, yes, thank you, Sam. I
9 forgot --

10 MR. CARROLL: He has fallen into bad habits
11 immediately.

12 MR. KRESS: It's easy to forget these.

13 This is our list of letters we have to get out
14 this time. You will notice there are six of these with four
15 of them priority A, one priority B and one priority C. If
16 you don't agree with those priorities, please let us no.

17 MR. MICHELSON: I would suggest that item 1 be
18 A-plus. If we wait until July, we have no choice.

19 MR. KRESS: You are absolutely right. We did plan
20 on meeting in July, by the way. I will talk about that in
21 the planning and procedure spec. Still, this is an A-plus.
22 We are more or less obligated to get that out this time. So
23 we want to get it before Ivan --

24 MR. CATTON: I have to leave.

25 MR. KRESS: You have to leave at 2:00 o'clock.

1 MR. CATTON: actually, 2:30.

2 MR. KRESS: You have some draft of this?

3 MR. CATTON: The second draft is in typing right
4 now.

5 MR. CARROLL: It's 2:00 o'clock today you leave,
6 right?

7 MR. CATTON: I am leaving at 2:30 today.

8 MR. KRESS: Okay. So we would like to have that
9 pretty far along.

10 MR. CATTON: I would hope so. And I have
11 rewritten it to meet with the subcommittee's views.

12 MR. CARROLL: Whatever they are.

13 MR. CATTON: There are lots of options in them and
14 I have already written my added remarks.

15 MR. KRESS: In case you need them.

16 MR. CATTON: In case I need them.

17 MR. KRESS: Are we to call you and ask you about
18 those when you come up with a final version?

19 MR. DAVIS: Mr. Chairman? I'm sorry. While we're
20 on the subject of letters, you may recall we received a
21 letter addressed to you from Commissioner Rogers on May 16
22 commenting on our letter of May 11 relative to PRA, use of
23 PRA in regulatory activities.

24 The letter -- the last paragraph of the letter
25 sort of indicates that Commissioner Rogers would like to

1 hear from us regarding PRA research needs. It doesn't
2 exactly say that as such, but it does indicate he's
3 interested in our suggestion that PRA research needs be
4 pursued further by NRC and he also states that he would find
5 our conclusions on this very helpful in considering the
6 agenda, research agenda for the future.

7 I am just wondering if we wish to put together
8 something in response to this, indicating what our thoughts
9 are regarding PRA research needs.

10 MR. KRESS: I think it is an opportunity that we
11 certainly would not want to let pass is my opinion.

12 MR. DAVIS: I agree with that.

13 MR. CARROLL: Sounds like you even have volunteer
14 for that.

15 MR. KRESS: That is what I was hoping.

16 MR. CATTON: Don't you need to have a subcommittee
17 meeting or do you know what they are doing in research, or
18 is that what you are suggesting?

19 MR. DAVIS: I think a subcommittee meeting may be
20 very helpful.

21 MR. CATTON: I think it is kind of necessary.

22 MR. KRESS: Unless you already know what research
23 they are doing.

24 MR. DAVIS: I generally know what they are doing,
25 but I don't know what they're planning to do.

1 MR. LINDBLAD: As I recall, we heard a
2 presentation on the PRA policy, and there was a reference to
3 an implementation plan that was not yet ready for us to see.
4 It would seem to me that the implementation plan would
5 include the NRR needs that were being communicated to
6 research.

7 MR. DAVIS: I agree.

8 MR. LINDBLAD: So I think the Chairman is going to
9 refer to Bill Russell being with us next month, and things
10 that we might raise with Bill Russell at the time. And some
11 of us thought that maybe we ought to ask him about the
12 status of the implementation plan.

13 MR. DAVIS: I agree.

14 MR. LINDBLAD: That would be an appropriate --

15 MR. CATTON: Pete, the Option 4 of this Thermo-
16 Lag business, which is a performance-based fire regulation
17 is really PRA. It is the mix. I think if we are going to
18 have subcommittee meeting, that ought to be a part of it
19 because that looks like the first heavy duty application.

20 MR. DAVIS: I'm beginning to feel sorry I brought
21 this up.

22 [Laughter.]

23 MR. CATTON: Why? Why are you sorry you brought
24 it up? I think it is an important issue. I think we should
25 find out what they are doing.

1 MR. SEALE: Are you taking notes, Dana.

2 MR. KRESS: Okay. Why don't we talk about that
3 during our planning meeting then. I think you ought to
4 seriously plan on having such a meeting.

5 MR. MICHELSON: Mr. Chairman, on the question of
6 the fire protection letter which I feel has a high degree of
7 urgency, it has been suggested that perhaps we could discuss
8 this during lunch hour by having lunch around the table. I
9 wonder how other members feel about that?

10 MR. SEALE: Willing.

11 MR. MICHELSON: Depending on how well it goes this
12 morning.

13 MR. CARROLL: When we talked yesterday -- or at
14 least my impression of what we concluded was we would have
15 only about an hour presentation and then devote the rest of
16 the time to looking at Ivan's letter.

17 MR. MICHELSON: Yes. If it goes well enough we
18 don't need to.

19 MR. CARROLL: But I have no problem with lunch
20 around the table.

21 MR. MICHELSON: We do have that contingency.

22 MR. KRESS: Ivan, I think we ought to seriously
23 consider that.

24 MR. MICHELSON: See how it goes.

25 MR. KRESS: We will see how it goes after the

1 presentation.

2 MR. MICHELSON: I would like to have Ivan here for
3 as much of it, if not all of it.

4 MR. CARROLL: He's got kind of a flimsy excuse for
5 leaving at 2:30.

6 MR. KRESS: I know it, but why don't we seriously
7 consider that and keep it as an option.

8 Were there other discussion?

9 MR. LINDBLAD: Yes. Mr. Chairman, in the list of
10 letters scheduled for consideration, I am responsible for
11 letters number 4 and 5. And I would suggest -- my personal
12 preference is to reverse the priority of those two and make
13 letter number 5 an A priority and letter number 4 a B
14 priority.

15 We may see -- we may want to do this or consider
16 this after we have heard the presentation on license renewal
17 rule. We have delayed in getting out letter number 5 for a
18 couple of weeks.

19 M... KRESS: I certainly would be agreeable to
20 that.

21 Was there any reason why Letter 4 had a priority
22 A? Do you recall, Sam?

23 MR. LINDBLAD: I believe the reason is that it
24 will now be going out for public comment. We will hear from
25 them and there will be opportunities later. But if there is

1 something we want to say before it goes out for public
2 comment, this will be the time to hear it.

3 MR. KRESS: Should we leave it as an A or drop it
4 to a D and just raise the other one to an A.

5 MR. LINDBLAD: Okay.

6 MR. KRESS: I think looking at this set of letters
7 and the status of most of them, there is a very good chance
8 we will finish up Friday night. Just for the information of
9 the members.

10 MR. CARROLL: I would have said the opposite.

11 MR. KRESS: We will see. You know, it could go
12 one way or the other.

13 MR. CARROLL: I guess the key is how well we do on
14 the fire letter.

15 MR. KRESS: Yes, that will probably be the key.
16 With Ivan gone, it will probably go a lot faster.

17 If there is no more discussion on that subject, I
18 will turn now to the first topic of the meeting. This looks
19 like my subject, Protective Action Guidelines.

20 You recall in our review of System 80+ that when
21 they used the new source terms, it turned out that they were
22 able to meet Protective Action Guidelines.

23 The question was what does that mean. Some of us
24 felt like it would be useful to us if the Staff could come
25 in and perhaps give us a discussion and tutorial on

1 Protective Action Guidelines, their perspective on it and
2 maybe some historical perspective. This is for our benefit,
3 for the Staff. We appreciate them coming in and doing this.

4 With that, I will turn it over.

5 MR. CONGEL: Thank you, Dr. Kress. This morning
6 we have an outline to hopefully accomplish exactly what you
7 just said. Falk Kantor from my Emergency Preparedness
8 Branch has a series of slides to accompany his presentation
9 and hopefully answer basic issue.

10 We talked the last couple of weeks about the
11 content of this. I believe that it should give an overview
12 of not only the Protective Action Guidelines but how they
13 fit in with our emergency planning current, our emergency
14 planning future plans and issues, and what meaning, if
15 anything, the CE 80+ analysis had when it referred to the
16 PAGs.

17 With that, I will have Falk begin his
18 presentation.

19 [Slide.]

20 MR. KANTOR: Good morning, ladies and gentlemen.
21 As Frank said, my name is Falk Kantor. I am a member of the
22 NRR Staff, the Emergency Preparedness Branch. As Frank has
23 indicated, I am here to provide an overview of emergency
24 planning and how it fits into our licensing process, in
25 particular for the advanced reactors, and perhaps to address

1 some questions which have arisen as a result of the review
2 of the CE System 80, in particular the accident analysis
3 section.

4 [Slide.]

5 MR. KANTOR: The topics I am going to be talking
6 about are the EPA Protective Action Guides themselves, what
7 they are and how they are used. The relationships of the
8 PAGs to emergency planning, and then a short discussion of
9 emergency planning under 10 CFR Part 52, how emergency
10 planning fits in the various phases of that regulation, and
11 then discuss a little bit about the -- reiterate the
12 licensing review that was done for CE System 80-plus, in
13 particular Chapter 15, and then talk a little bit about our
14 current ongoing examination of emergency planning for
15 passive reactors.

16 [Slide.]

17 MR. KANTOR: The Protective Action Guide itself is
18 defined as the projected dose from an unplanned release of
19 radioactive material at which a specific protective action
20 is recommended.

21 The PAGs have been developed and established by
22 the U.S. Environmental Protection Agency, and are found in
23 the Manual Protective Action Guides referred to as DPA-400.

24 [Slide.]

25 MR. KANTOR: The PAGs are pretty well established

1 by EPA and they are used in the emergency planning process.
2 There is no controversy or question about the PAGs
3 themselves. This is a table right from the EPA PAG Manual.
4 It shows the basic PAGs for the plume exposure pathway for
5 the early phase of an accident, the first couple of hours
6 and the first couple of days of an accident, and the basic
7 PAG is projected dose of 1 to 5 rem. At the lower level,
8 you begin taking protective actions, could be evacuation if
9 feasible, or sheltering and, as the projected dose increases
10 up to 5 rem, you try to take the most appropriate protective
11 action which we believe would be evacuation.

12 [Slide.]

13 MR. KANTOR: The way PAGs are included in the
14 emergency planning scheme of things is, we have a
15 regulation, 10 CFR 50.47(b)(10), this is one of the basic 16
16 emergency standards, and it states that emergency plans must
17 contain guidelines for the choice of protective actions that
18 are consistent with Federal guidance.

19 The primary guidance document we use for emergency
20 planning is NUREG-0654, and NUREG-0654 in one of its
21 criterion states the protective actions be in accord with
22 the recommendations of the EPA PAG Manual. So that is the
23 linkage between emergency planning regulations and guidance
24 and the EPA PAGs. All plans rely upon an incorporate the
25 EPA PAGs as the basis for taking protective actions.

1 EPA PAGs are also used in the development of the
2 ten-mile emergency planning zone which is described in
3 NUREG-0396.

4 MR. KRESS: Excuse me. Is it the role of the
5 States to have in place emergency procedures?

6 MR. KANTOR: Yes. We require an on-site plan
7 provided by an application or licensee and supporting off-
8 site plans usually provided by State and local governments.
9 Those are the required plans for licensing and approval. As
10 I indicated, both the on-site and off-site plans would
11 incorporate these protective action guides as the basis for
12 recommending protective actions.

13 MR. KRESS: Whose role is it to enforce those? Is
14 it NRC's role or is it --

15 MR. KANTOR: Well, the NRC reviews the on-site
16 plan. The off-site plans are reviewed by the Federal
17 Emergency Management Agency who provide their findings to
18 the NRC, and the NRC then makes the overall licensing
19 decision. Yes, the plans are reviewed to see that they do
20 incorporate these guidelines and exercises are then
21 conducted to demonstrate the use of the plans including the
22 guidelines.

23 MR. KRESS: Thank you.

24 MR. DAVIS: Excuse me. I have a question on the
25 previous slide. I am sorry I am a little behind. This

1 administration of stable iodine has been an issue that has
2 been around for a long time. I presume you are talking
3 about potassium iodine pills?

4 MR. KANTOR: It could be potassium iodine pills.
5 This is a guideline which would apply if the plans included
6 the use of stable iodine as a protective measure. Most
7 plans do not include that for members of the public. They
8 do include it for emergency workers and institutionalized
9 persons.

10 MR. DAVIS: That was going to be my question. You
11 say it requires approval of State medical officials. Is
12 this approval obtained at the time the license is granted
13 for the plant?

14 MR. KANTOR: Well, it is a recommendation by the
15 EPA primarily to States that might be using iodine in their
16 plans. They would have to incorporate in some way a medical
17 viewpoint or agreement to use this as a protective measure.
18 Right now, in the United States, there are only three States
19 that make use of stable iodine.

20 MR. KRESS: Thank you. That has helped.

21 MR. CARROLL: Who are those three States out of
22 curiosity?

23 MR. KANTOR: There is Tennessee which is the only
24 State who have attempted to predistribute it, and Alabama
25 and Arizona I believe are the other two States that

1 stockpiled in the vicinity of a site.

2 MR. CARROLL: Now the Commission recently took
3 some action on this subject I remember reading. What was
4 that about?

5 MR. KANTOR: Well, the Commission had an issue
6 before it concerning whether to recommend a change in the
7 Federal policy. The Federal policy was published in 1985,
8 which, in essence, recommends KI for emergency workers, and
9 institutionalized persons, but does not recommend or
10 encourage stockpiling for the public. So the Commission had
11 this issue before it, whether it should encourage the
12 stockpiling of the KI. As you know, the Commission decided
13 to not go forward with that and to stay with the current
14 Federal recommendation.

15 MR. CARROLL: Out of curiosity, why wasn't that
16 matter brought before the ACRS?

17 MR. KANTOR: I am not sure I could answer that
18 question, why it was not brought before the ACRS. It was in
19 the form of some staff Commission papers --

20 MR. CARROLL: Which I never saw.

21 MR. KANTOR: -- which are publicly available now.
22 I cannot answer why that was not brought before the ACRS.
23 It has been a long ongoing issue.

24 MR. CARROLL: I happen to have some views on it,
25 that is why I was interested to learn that it was a fait

1 accompli.

2 MR. KRESS: Did they administer KI during the
3 Chernobyl incident?

4 MR. KANTOR: Afterwards, yes. KI, I think, was
5 used extensively, and it has been studied extensively.

6 MR. KRESS: I wondered if we had looked at that.

7 MR. KANTOR: We have reviewed, as part of the
8 Chernobyl accident, the use of KI and whether and how it
9 might apply to the United States. We feel that the
10 Chernobyl situation is not applicable to NRC and U.S.-type
11 situations.

12 MR. CONGEL: Let me add a little bit to that, if I
13 could, please, because there are several aspects to the
14 Chernobyl experience and how they relate to the development
15 of our ultimate KI policy. There were KI tablets and maybe
16 even the solution form administered in a wide range around
17 Chernobyl immediately following the accident. Just
18 recently, within the past several weeks, our EDO had entered
19 into a formal agreement with the Russians and Ukraines and,
20 I guess, Byelorussia to follow up with a very detailed study
21 on the results and effectiveness of the KI administration
22 primarily on the children that were administered the drug
23 during that time.

24 There are a whole series of facts and, of course,
25 this could be a subject of a separate presentation itself,

1 but let me just hit a couple of high points. Falk just
2 mentioned it wasn't directly applicable to us. One of the
3 facts that has to be pointed out was, the principal reason
4 that the material was used, especially with children, was
5 the fact that they had to continue eating foods that were
6 grown in the area as well as drinking the milk that was
7 produced in the area and we know that it had iodine in it.
8 There were no choices involved in terms of disposing or
9 destroying that milk and getting a fresh supply.

10 Secondly, the population that was exposed in this
11 manner already had a history of potential problems and, in
12 fact, the sections of the exposed area were called the
13 goiter belt in the former Soviet Union. So the studies that
14 will be conducted are going to have to be lengthy and
15 detailed and, of course, they will be, I am sure, very
16 difficult.

17 So the applicability over the longer term to our
18 experience is not direct, but the information that can be
19 gathered is of useful purpose medically as well as for any
20 future decisionmaking. But the decision to embark on this
21 program was just made, just formally, I think, within the
22 past, I will say, a month, because that is what Jim Taylor
23 had mentioned to me just a week or so ago.

24 MR. KRESS: Thank you.

25 [Slide.]

1 MR. KANTOR: As I mentioned, PAGES can also be
2 found in the rationale for the 10-mile emergency planning
3 zone. In particular, one of the rationales is that the
4 projected doses from design basis accidents should not
5 exceed PAGES outside the emergency planning zone and the
6 projected doses for most core melt sequences would not
7 exceed PAGES outside the emergency planning zone, so that is
8 another way PAGES were used in the development of emergency
9 planning requirements.

10 [Slide.]

11 MR. KANTOR: About a year ago the Staff provided a
12 presentation to the ACRS on emergency planning under 10 CFR,
13 Part 52, and I thought I would just go over the high points
14 of that in order provide some perspective of where we are in
15 the review of CE System 80.

16 [Slide.]

17 MR. KANTOR: Under sub-part (a), early site
18 permits, an application must identify physical impediments
19 to emergency plans and describe contacts and arrangements
20 with offsite authorities.

21 The application may also propose major features of
22 emergency plans or complete integrated plans and the NRC in
23 consultation with FEMA would review the emergency plans that
24 are submitted as part of an early site permit.

25 Under sub-part (b) of Part 52, the standard design

1 certification, there really is not much in this area for
2 emergency planning. The application must contain
3 information on the design of the plant, of course, and it
4 has to demonstrate a compliance with TMI requirements in
5 50.34(f).

6 Two of those requirements refer to the technical
7 support center and the operational support center.

8 There is also some requirements for support
9 facilities, labs, and decon facilities so that is where
10 emergency planning comes into the standard design
11 certification review which we have done for both ABWR and CE
12 System 80. The applicants have developed ITAAC for these
13 facilities and we have reviewed and approved the ITAACs
14 during the course of our review.

15 [Slide.]

16 MR. KANTOR: It is in the combined license phase
17 that emergency planning has to -- the combination of
18 emergency planning. An application for combined license
19 must contain the emergency plans, the overall plans, the
20 onsite and offsite plans that we referred to.

21 The Applicant must propose ITAAC including those
22 applicable to emergency planning and prior to operation the
23 NRC in consultation with FEMA I might add must find that the
24 acceptance criteria are met.

25 I want to point out also the application in Part

1 52 states that the application will be reviewed according to
2 the standards in Part 50 and others.

3 The point I want to make is that there is no
4 change in emergency planning requirements for review done
5 under Part 52. The change really is when and how you go
6 about submitting the plans and the NRC reviews and approves
7 the plans, but the bottom line is that all our current
8 emergency planning requirements are still required to be met
9 by an Applicant under 10 CFR, Part 52.

10 [Slide.]

11 MR. KANTOR: Taking a look at CE System 80+ in
12 particular, I'd reiterate what I just said. We are
13 reviewing 80+ under Part 52. Emergency plans are not
14 required for issuance of a design certification and there
15 were no emergency plans submitted.

16 They were required to demonstrate compliance with
17 the requirements for 50.34(f), in particular the TSC and OSC
18 I mentioned.

19 The dose calculation that was done in Chapter 15,
20 the PAG dose calculation, Chapter 15 of the SER, does not
21 signal any change in the requirements of EP for advanced
22 reactors.

23 MR. KRESS: Are you going to expand on that
24 statement?

25 MR. KANTOR: Yes.

1 [Slide.]

2 MR. KANTOR: Under Chapter 15 the standard design
3 basis accidents were evaluated and the results were compared
4 to Part 100 guidelines.

5 There was a so-called EPA PAG dose calculation
6 done and it was done and perhaps some of the Staff can
7 provide some background on it. It was done at the request
8 of the Applicant and they provided an analysis. The Staff
9 evaluated that analysis and agreed that the approach and
10 models used were reasonable and acceptable but there was no
11 licensing finding made as a result of that calculation.

12 As I indicated, there is no change in our
13 emergency planning requirements, and certainly under design
14 certification there is no requirement that an EPA PAG dose
15 calculation be done but the Applicant felt it was to their
16 advantage or necessary for them to submit that calculation.
17 We reviewed it.

18 We caveated it, I think, in the SCR to indicate
19 that just this one sequence would not be sufficient for an
20 overall evaluation of emergency planning. Emergency
21 planning would take in much more than this PAG dose
22 calculation.

23 Now there is an initiative, an effort going on in
24 the Staff to review emergency requirements for passive
25 reactors and perhaps the Applicant felt that this was to

1 their advantage to make their case now upfront in advance of
2 the Staff reaching any decision on any change in emergency
3 planning requirements.

4 I'll talk a little bit more about that.

5 If you have any more questions on details about
6 the calculation itself or perhaps other questions on where
7 it fits into the scheme of things, there are some other
8 members here of the NRR staff that perhaps could --

9 MR. LINDBLAD: Yes. Was the calculation or the
10 modeling done more or less as boundary conditions,
11 enveloping conditions or just typical conditions?

12 MR. KANTOR: I will have to maybe defer to the
13 Staff. I think it was a conservative-based or a realistic
14 based calculation.

15 Aby, do you have any --

16 MR. MOHSENI: I am Aby Mohseni and I was involved
17 in the analysis of the Applicant's calculations.

18 We did not conclude that the Applicant's
19 calculations resulted in identifying the bounding of
20 conditions and therefore --

21 MR. LINDBLAD: And so you still don't today?

22 MR. MOHSENI: That is correct.

23 MR. LINDBLAD: All right, thank you.

24 MR. MOHSENI: We were not requested to do that by
25 the Applicant. We were requested to review if indeed that

1 sequence of accidents reflected an acceptable method of
2 calculating the offsite doses and compare them to the PAGs
3 and we did just that.

4 MR. LINDBLAD: Did the Applicant represent that he
5 thought it was a bounding condition?

6 MR. MOHSENI: Not to the extent that we would be
7 comfortable making that kind of a determination. While the
8 Applicant in an oral presentation said that it does appear
9 that indeed the sequence we have selected does represent
10 most of the severe core damage consequences, they did not go
11 far enough to indeed state that this is an envelope
12 calculation.

13 MR. LINDBLAD: Thank you.

14 MR. KRESS: Did they use the hypothetical site
15 that is in the Utilities Requirement document for that
16 calculation?

17 [Slide.]

18 MR. KANTOR: Well, here's some of the assumptions
19 up here that went into the calculation of that particular
20 sequence. We have the typical design basis accident
21 assumptions, and these were the assumptions that were used
22 in the PAG dose calculation.

23 And I believe it was a standard type of
24 meteorology that was used. Certainly, I don't think it was
25 site-specific in any way.

1 MR. KRESS: You wouldn't accept that in an actual
2 calculation. You'd want the 95 percentile, Chi over q.

3 MR. KANTOR: Right. For emergency planning, it
4 takes in a spectrum of accidents. The planning basis has
5 already been established for a spectrum of accidents.

6 MR. CONGEL: And, secondly, let's be a little
7 careful here because the requirements for meeting the
8 emergency preparedness regulations are not based on just a
9 PAG type of calculation.

10 There was a slide that Falk put up earlier that
11 indicated the overall considerations. But, the ultimate
12 decision and finding of an LPZ of 10 miles was based on a
13 number of considerations, this just one of them, and a very
14 heavy dose of judgment, as well.

15 MR. KANTOR: In fact, for review of emergency
16 planning, we do not really review accident dose
17 calculations. We review whether the application has met the
18 16 planning standards that are in the regulations.

19 The accident analysis has already gone into
20 establishing the 10-mile emergency planning zone. That's
21 where the accident analysis went in, and that took in what I
22 say was a spectrum of accidents, including design basis
23 accidents and severe accidents, or accidents beyond the
24 design basis.

25 But, we don't do individual dose calculations in

1 the review of emergency planning for a particular
2 application.

3 MR. KRESS: If a combined license holder were to
4 come in and propose a site and buy a System 80+ for it, and
5 they repeated the calculations, including the other design
6 basis accidents that you talk about, and they still met
7 PAGs, then what considerations do you use to decide?

8 Who decides then, at that point, whether they
9 actually didn't have to have an emergency plan, and what
10 consideration goes into that decision?

11 MR. KANTOR: Well, there's no question they'll
12 have to have an emergency plan under combined license. And
13 as I indicated earlier, all the current emergency planning
14 requirements would have to be met. Those are the
15 regulations 50.47 and appendix E, the Part 50.

16 MR. KRESS: Well, why do we have PAGs then?

17 MR. KANTOR: PAGs go into development of emergency
18 plans. They're the basis for taking protective actions. If
19 you get into an accident situation and you project that
20 you're going to exceed these PAGs, that's the basis for
21 recommending protective actions to the public.

22 It's go into the plans. But, like we don't --

23 MR. KRESS: But they're not a decision criteria
24 then?

25 MR. KANTOR: They are a decision criteria at the

1 time of event. They're not really a decision criteria as to
2 whether --

3 MR. KRESS: -- as to whether or not to have an
4 emergency action plan.

5 MR. KANTOR: Right, because they're already
6 established. They're already built into the plans. I mean,
7 during the course of the review, we would determine that the
8 plans do have the EPA PAGs in there as the guidelines for
9 taking protective actions. That would be where our review
10 would come in.

11 But we would not do a review of a dose calculation
12 against those PAGs under the current scheme of things to
13 determine whether plans are required or not required.

14 They are required. Plans are required under our
15 current regulations.

16 MR. CONGEL: Maybe, I can add a little bit. Could
17 we go back to slide 6, which was headed the Planning Basis
18 for the Current Requirements for Size.

19 [Slide.]

20 And I know that when we went over this slide, it
21 was rather quick. So I had anticipated more questions. But
22 I think that the questions that were asked and the
23 discussion that we're having, it may be put into a better
24 frame if we look back at this slide again.

25 As I mentioned earlier, the choice up to 10 miles

1 was not based on strictly a quantitative evaluation. Some
2 analysis that, after it was completed, popped out with a
3 number 9.88, or something of that sort, that we rounded off
4 to 10.

5 There were judgments made. Among them were
6 valuations that looked at a spectrum, a series of accidents,
7 and the off-site doses associated with those accidents.

8 And, in fact, the NUREG 3906 contains families of
9 curves that give dose versus distances for -- and the
10 probability of their occurrence.

11 And when one looks at those families of curves
12 just as one of the inputs for this decision-making process,
13 you'll see that the probability of exceeding a protective
14 action guideline dose at about 10 miles gets very small. It
15 doesn't go to zero, but at that point there is a judgment
16 made that distances of about 10 miles should provide a
17 sufficient protective boundary such that detailed planning
18 within that distance could be the basis for our reasonable
19 assurance finding.

20 MR. POWERS: What's very small, Frank?

21 MR. CONGEL: I picked very small because I don't
22 remember the number exactly. But it was something on the
23 order of 10 to the minus 6 or less.

24 And if you go down the bullets on this slide,
25 you'll also notice that even from this choice of 10 miles

1 that beyond this 10 mile EPZ, you don't exceed the PAGs.

2 And we also looked at very -- you know, borderline
3 incredible sequences. And you find that you don't exceed
4 doses that would result in prompt health effects beyond 10
5 miles.

6 Again, the probability, as we all know, doesn't go
7 to zero. The other statement that was made with a distance
8 as large as 10 miles and the detailed planning within that
9 distance, that you have a basis for if a need ever arose to
10 plan for actions beyond the 10 miles.

11 But I have to emphasize very heavily there are
12 judgment factors here. It was a policy matter that
13 ultimately decided it. And the fact that the newer designs
14 are claiming that they could possibly meet PAGs at the 10-
15 mile distance with a variable probability of that occurring
16 may be something that we would look at for an overall
17 potential policy change, but that's not in the works right
18 now.

19 And, in fact, Falk will get to in his later slides
20 just where we are on the Commission directive as to
21 reevaluate the 10-mile EPZ and, in fact, our overall
22 planning basis for emergencies for future reactors.

23 We'll discuss that in a few minutes. But, for
24 right now, any reactor that comes in for design
25 certification review is subject to the exact, same

1 regulations that we have for our operating plants.

2 MR. DAVIS: I had a question. How do you decide
3 what "most" is? Is this a probability cut-off? What is the
4 criteria for that?

5 MR. CONGEL: Yes. It is qualitative, but it is a
6 probability cut-off, and I refer back to those families of
7 curves that I mentioned a moment ago in 0396.

8 MR. KANTOR: There is a complete discussion of all
9 this in NUREG-0396 which is a joint NRC/EPA document on
10 development of the planning basis for nuclear power plants
11 that would have the details of all the information that went
12 into the development of the ten-mile emergency planning
13 zone.

14 As Frank indicated, the final selection of Ten
15 Miles as a policy decision.

16 MR. DAVIS: Thank you.

17 [Slide.]

18 MR. KANTOR: Now I am going to move on to what you
19 might say are some current activities that are going on in
20 reviewing emergency planning for advanced reactors.

21 There were a couple of Commission papers provided
22 back, I believe, in April of last year, one of which was
23 SECY-93-087. As you see, "Policy Technical and Licensing
24 Issues Pertaining to Evolutionary and Advanced Light Water
25 Reactor Designs."

1 And in that paper, the Staff made the following
2 points. Certain modification to EP requirements may be
3 appropriate for the passive designs; there is a need to
4 consider a plant's ability to prevent a release or to
5 provide very long delayed times for all but the most
6 unlikely events; more information is needed, particularly
7 concerning a source term and risk.

8 And then it was noted that EP requirements
9 following a TMI-2 accident were not based on strictly
10 technical factors, as you know. There were some policy and
11 public perception-type factors that went into emergency
12 planning requirements.

13 And it states as a policy matter, it may be that
14 even very low calculated probabilities may not be considered
15 a sufficient basis for changes to EP requirements.

16 [Slide.]

17 MR. KANTOR: The second Staff paper was SECY-93-
18 092, "Issues Pertaining to the Advanced Reactor and CANDU3
19 Designs and their Relationship to Current Regulatory
20 Requirements."

21 There was an issues list in that paper including
22 one on should advanced reactors with passive design safety
23 features be able to reduce emergency planning zones and
24 requirements.

25 The Staff indicated that -- proposed no change to

1 the existing regulations at this time. Information obtained
2 from ongoing evaluations will be factored into EP
3 requirements for advanced designs. Based in part on these
4 accident evaluations, the Staff will consider whether some
5 relaxation from the current requirements may be appropriate.

6 And then in response to the SECY papers, the
7 Commission routed a Staff requirements memorandum on July
8 30th, 93. The Commission agreed that it was premature at
9 this time to reach a conclusion at this time to reach a
10 conclusion for advanced reactors.

11 For ongoing review purposes, Staff should use
12 existing regulatory requirements. However, the Staff should
13 remain open to suggestions to simplify the EP requirements
14 for reactors that are designed with greater safety margins.

15 And Staff is requested to submit recommendations
16 for proposed technical criteria and methods to use to
17 justify simplifications of EP requirements, and that the
18 work on EP for advanced reactors should be correlated with
19 the work on accident evaluation and source term.

20 MR. KRESS: Is there anything ongoing on that
21 second from the bottom bullet?

22 MR. KANTOR: Yes. Next slide.

23 [Slide.]

24 MR. KANTOR: In response to the SRM in December of
25 '93, the Staff provided a response where it laid out a

1 preliminary program or method for advancing in response.

2 It proposed three technical factors as a possible
3 basis for simplifying EP requirements. It would have to
4 involve some reduction in source term, a reduction in
5 probability of release, and an increase in the delay time
6 preceding release. Some combination of factors involving
7 those would probably be necessary before Staff could
8 recommend any relaxation in current EP requirements.

9 MR. KRESS: This source term you are talking about
10 here is the release from containment source term?

11 MR. KANTOR: Yes. It would be the new -- what we
12 call the new source term.

13 MR. KRESS: But that is what it going into
14 containment.

15 MR. CONGEL: No, it is correct. His answer yes -
16 - simple answer was correct. What you are saying is
17 correct, Dr. Kress. It is what gets out.

18 MR. KRESS: Okay.

19 MR. KANTOR: Staff noted that in addition to the
20 technical criteria EP must consider other policy and public
21 perception factors also.

22 There have been several meetings by the Staff,
23 different branches of NRR that are involved in risk and
24 containment, also with our Office of Research to develop a
25 plan, a schedule, for reviewing the EP requirements for

1 passive reactors.

2 First of all, a decision was made to focus on
3 passive reactors because we had more information there on
4 design and risk assessment information, the level of
5 licensing interest is greater there than the advanced
6 reactors, and any insights we gain from review of the EP for
7 passive reactors could be factored into EP for advanced
8 reactors.

9 In addition, research has been initiated or
10 shortly will be initiating a contract to review the planning
11 basis for emergency planning using the new source term and
12 insights from NUREG-1150. In other words, we are going to
13 take a look in a fashion similar to what was done in NUREG-
14 0396 to establish the 10-mile current emergency planning
15 zone using new information that is available now to relook
16 at the planning basis for passive reactor designs.

17 The industry also has an effort in this regard.
18 EPRI has provided a technical report on simplification of
19 EP. NEI now has the lead in developing policy and other
20 issues in addition to the technical issues that would go
21 into a possible reduction of emergency planning
22 requirements.

23 We have met with NEI and we are going to be
24 meeting with them and coordinating with them as we proceed
25 in our review effort.

1 MR. CARROLL: In general, what is industry
2 proposing in terms of simplification?

3 MR. KANTOR: Industry proposes a range all the way
4 from emergency planning zone at the site boundary to --
5 which is almost tantamount to no emergency planning.

6 In effect, the industry would like to reduce
7 either the scope, the area of the emergency planning zone or
8 the requirements that go into the emergency planning zone,
9 such as sirens, prompt notification, advanced planning, the
10 need for off-site plans, those type of things the industry,
11 based on their studies, would like to provide a basis for,
12 either reducing or eliminating.

13 MR. CARROLL: I guess sirens would be at the top
14 of their list of things they would like to see.

15 MR. KANTOR: Certainly, I think they would like to
16 see -- if we can establish that the need for prompt measures
17 is much reduced, then of course you don't need the sirens or
18 maybe you don't need sirens out to 10 miles, maybe only two
19 miles or something like that. And also the requirement for
20 prompt notification of the public and quite sophisticated
21 and complicated off-site plans might be lessened or reduced.

22 MR. LINDBLAD: Sirens will be anachronistic in the
23 information highway age, won't it?

24 MR. CARROLL: I suppose that's right, Bill. As
25 long as you are --

1 MR. KANTOR: There are other factors involved,
2 too. As we indicate, on a technical basis you can establish
3 that you could reduce emergency planning. There are other
4 factors involved in emergency planning, public perception is
5 one of them.

6 MR. LINDBLAD: I was hoping you were going to
7 expand on that and an earlier --

8 MR. KANTOR: The public is not as familiar and
9 comfortable with emergency planning zones.

10 MR. LINDBLAD: Which public are we talking about
11 here? The local site-oriented public or the general
12 population of the United States?

13 MR. KANTOR: I'm referring to the general public,
14 I guess. But certainly the local population is certainly
15 much more familiar and aware of emergency plans if they are
16 in the vicinity of a site because of the exercises we
17 conduct once every two years. There is a full demonstration
18 of the off-site plans.

19 MR. CARROLL: And the sirens they drive by every
20 day that remind them of it.

21 MR. KANTOR: And those are periodically tested.
22 It might be monthly, it might be semi-annually. And there
23 is a warning given. There is a lot of interaction now
24 between licensees and the public on emergency planning and,
25 like I mentioned, there is a feeling like the public is

1 comfortable with emergency planning that's out there now.

2 MR. LINDBLAD: How do you measure that and how do
3 you gauge whether they are comfortable or not?

4 MR. KANTOR: Well, it's difficult. It's a
5 judgment, just by going out to various exercises and
6 meeting, you know, members of the public and the fact that
7 we don't have large numbers of intervenors coming in or
8 2.206 requests to eliminate emergency planning, that sort of
9 thing.

10 MR. LINDBLAD: So you count intervenors?

11 MR. KANTOR: No, I am just making some general,
12 overall statements.

13 MR. DAVIS: There was a case -- excuse me. Are
14 you finished?

15 MR. KANTOR: Yes.

16 MR. DAVIS: -- on the East Coast where the 10-
17 mile zone extended across a state boundary and the state
18 adjacent to the plant refused to participate in the
19 emergency planning exercise.

20 MR. KANTOR: Right.

21 MR. DAVIS: And that disturbed the licensing
22 process for the plant.

23 What do you do in that case, if the state refuses
24 to participate?

25 MR. KANTOR: As a result of that case, which is

1 the Seabrook case, I believe you're referring to, and there
2 was also the Shoreham case before that. And I happened to
3 be personally involved in both of those and it was a long
4 and difficult, torturous couple of years in emergency
5 planning.

6 As a result of those cases, the regulations were
7 changed. The so-called Realism Rule was put in place that
8 if state and locals refused to participate, a utility can
9 develop off-site plans and submit those.

10 After the rule was passed, there was also an
11 executive order from the presidential branch that
12 established a mechanism for the Federal Government, in
13 particular FEMA, to assist utilities if the utility makes a
14 declaration that the state and locals decline to participate
15 in emergency planning, they request assistance from the
16 federal government. That's never been done, but that is an
17 avenue open.

18 So there are options if state and locals don't
19 participate. But, from experience, a utility would be very
20 hesitant to get involved in any situation like that. And I
21 think the basis of emergency planning is really cooperation
22 between licensees, applicants and state and local
23 authorities.

24 That's one of the purposes of the early site
25 permit process would be to flush out any kind of potential

1 opposition to emergency planning on the part of those state
2 and locals. We would like to see these agreements up front
3 before we go far down the emergency planning course.

4 MR. CARROLL: Since the time that Pete was
5 referring to, Massachusetts has changed its position.

6 MR. KANTOR: That's correct. They have fully
7 joined into the emergency planning process and they have
8 provided a plan in support of the Seabrook plant.

9 Seabrook was licensed with a utility plan that was
10 developed for Massachusetts. But since it was licensed,
11 Massachusetts has come back into the planning process and
12 their plan has now replaced the utility plan.

13 MR. CARROLL: What did they ever do with their
14 siren trucks?

15 MR. KANTOR: The vans?

16 MR. CARROLL: Yes.

17 MR. KANTOR: They were used in some fashion.
18 There were about 100 of those vans or something with crews
19 that were on call for 24 hours a day. The trucks have been,
20 you know, used someplace else. The sirens were taken off
21 the trucks and have been used other places.

22 MR. CONGEL: Excuse me. I would like to make a
23 couple of points at this point and then continue the
24 discussion. But, first of all, the interactions that we
25 have had with industry, primarily EPRI and NEI, have

1 resulted in a lot of meaningful discussion. It is clearly
2 not a discussion where industry says, here are our proposals
3 and we would like the Staff to consider it. In fact,
4 industry itself had difficulty wrestling with this question
5 and in coming with a proposal for the Staff to consider.

6 I say this from several bases. We can focus in on
7 earlier problems like at Seabrook and Shoreham and even
8 Pilgrim. But the reality of the matter is that those are
9 success stories now and, in fact, EP has reached a level
10 where we get very, very few problems associated with
11 existing and emergency plans right now, very few.

12 There is a perception on the part of the locals in
13 particular, but it is a bigger picture than that. But the
14 locals in particular where they feel part of the system
15 contribute and overwhelming majority of science have as many
16 volunteers as they want to participate and help along.

17 So as Falk already mentioned, this part of the
18 overall operations of a power plant has an ingredient that
19 goes far beyond, I think, the safety perspective.

20 So before you make any requests or a utility would
21 make any requests to reduce it or even possibly eliminate
22 it, you have to consider the goodwill and things that are
23 the result of these programs.

24 Secondly, in terms of potential blocking of plants
25 to operate a plant at the last minute, Falk already pointed

1 out that this early site permit process is intended to flush
2 out any serious, very fundamental problems associated with
3 siting a plant in a particular area before large amounts of
4 funds are spent. But in terms of having a situation arise
5 where the utility itself has to come up with substitute
6 plans, that surely represents a major problem, regardless of
7 how successful it works out.

8 So looking toward the future, we certainly want to
9 minimize not eliminate such a thing like that happening
10 again. So we are going to go with lessons learned from our
11 earlier experiences.

12 Again, though, before you do anything with the
13 overall emergency planning programs, you have to see what it
14 is accomplishing not only from a perspective of safety, but
15 also from the perspective of community involvement. That
16 part, I think, has resulted in a lot of discussion, the
17 staff within ourselves, industry within itself, and cross
18 purposes, you know, just discussions of what we should do.
19 There appears to be a consensus on development where perhaps
20 we can relook at some of the details, the infrastructure
21 that is required now within the ten miles.

22 Then you mentioned sirens, we haven't even gotten
23 to a discussion at that level of detail with industry yet.
24 We are still wrestling with a bigger picture with them as to
25 what we should even do. The program that is being put

1 together by Research in response to the SRM is going to
2 focus on these kinds of questions, should you reconsider the
3 ten miles, should you make it smaller, or should you look at
4 potential changes within the ten miles, or what. We are
5 going to look at the whole spectrum of things. Overlying
6 this is the fact that we have a success story out there
7 right now and there is reluctance on anybody's part to rock
8 that boat.

9 MR. LINDBLAD: I believe there was an earlier
10 episode that we called Below Regulatory Concern in which the
11 Commission tried to be realistic on some risk and recognized
12 after a while that the Federal government wasn't the only
13 potential regulator in the world. If we decided on a
14 Federal basis that certain health requirements were not
15 necessary, other government agencies would move in and
16 impose them themselves as they have a right to. So the
17 experience on BRC might be a lesson to us as well.

18 MR. CONGEL: I think that is an excellent example.
19 You could surely undermine your own credibility if you come
20 up with a package that says that reactors are now so safe we
21 don't need anything like that, just as a hypothetical
22 situation. It just doesn't work that way. We have also
23 marketed and expressed in many, many public forums what role
24 we feel EP has, and it is like Level 4 of our defense in-
25 depth perspective and criteria that we apply to the safety

1 of every operating plant.

2 MR. CARROLL: I found it amusing that in the
3 aftermath of the Oleum release in Richmond, California, a
4 year ago or so that --

5 MR. LINDBLAD: Oleum is a small community in --

6 MR. CARROLL: No. Oleum is --

7 MR. LINDBLAD: Fuming sulfuric acid, yes.

8 MR. CARROLL: That there was a demand for sirens
9 downstream of the chemical plant, and they were pointing to
10 the fact, well, if nuclear plants, which everybody knows are
11 safe, need sirens, why doesn't something as unsafe as this
12 need them.

13 MR. LINDBLAD: The presence of chlorine, gaseous
14 chlorine on a site can also generate emergency requirements.

15 MR. CONGEL: There are many success stories for
16 it. Another one is in Louisiana, in that part of the
17 country there are a lot of chemical plants, and I have
18 talked with emergency planners in that area, and they are
19 thankful because the infrastructure that is provided by the
20 nuclear plants down there is used in the emergencies
21 associated with the chemical plants. In fact, thankfully
22 and fortunately, the only time they have had to exercise
23 that plan in order to assist the public is for accidents at
24 the chemical plant. So the point of the matter is, there is
25 a usefulness associated with this program.

1 MR. SEALE: It is an emergency utility and it has
2 a constituency, and I think we would have a real hard time
3 reducing that presence.

4 MR. CONGEL: Yes, sir. Like I said, I think it
5 would be worthwhile to reevaluate just some of the level of
6 detail within the ten miles, and where we have learned and
7 where you need 15 minutes, and where you don't need 15
8 minutes, but even that you don't do without a lot of
9 consideration and thought and having everything all fit
10 together.

11 MR. LINDBLAD: The other observation about the new
12 executive order which permits a utility to move forward in
13 the absence of off-site regulatory or governmental
14 collaboration, I don't think that only applies to siting new
15 plants, but it could also arise with the change of
16 administration in States or counties as time goes on, and it
17 could be that it will keep some operating plants continuing
18 to operate safely with a change of political atmosphere.

19 MR. CONGEL: That's correct. It applies,
20 actually, across the board, new and old.

21 MR. KRESS: I would like to get back to the minor
22 point on your slide there. At the top you have one of the
23 reasons for simplifying emergency planning requirements is
24 an increase in the delay time preceding the release.

25 Do you mind if I ask how that would -- what

1 simplifications would result from that?

2 MR. KANTOR: Well, that factor reverts to, if it
3 could be established that instead of release occurring on
4 the order of a half-hour, which is possible you might say
5 with current plants, that the release might be held up for
6 something on the order of 12 hours or 24 hours. If that was
7 the case, then it might be possible to factor that into your
8 emergency planning which would certainly reduce some of the
9 urgency from our current plan arrangements.

10 MR. KRESS: But you would still need an emergency
11 plan, and you may still have to evacuate and all those
12 things.

13 MR. KANTOR: That could be.

14 MR. KRESS: It would just give you more time to
15 think about it.

16 MR. KANTOR: It would give you more time and, as
17 Frank indicated, you could perhaps reduce some of your
18 infrastructure requirements. The prompt urgency aspect of
19 emergency planning would be somewhat lessened, but it could
20 be that emergency plans would still be required to some
21 extent, maybe not quite to the extent we now require.

22 MR. KRESS: Are there any more?

23 MR. DAVIS: I had one. Is sheltering an option
24 under this initiative as part of the emergency planning?

25 MR. KANTOR: Right. Sheltering is a protective

1 action recommendation. Depending on the situation that you
2 are in, you may recommend sheltering. The staff philosophy
3 is for severe accidents, severe core damage type accidents,
4 we believe evacuation, at least of the close-in population,
5 is the preferred protective action. However, there might be
6 situations such as severe weather where it might not be
7 possible to evacuate. You might then want to shelter, or
8 you might evacuate out to two miles and recommend sheltering
9 out to ten miles, and then do further evaluation and decide
10 you might want to expand your evacuation area. But
11 sheltering certainly is a principal protective action.

12 MR. DAVIS: I know of a plant that has a prison
13 within ten miles and the warden was very reluctant to
14 consider evacuating the prison population.

15 MR. KANTOR: That's true.

16 MR. DAVIS: Of course, he had a good shielding
17 situation there.

18 MR. KANTOR: That's true, but plans have been
19 developed for prisons to evacuate them if necessary, and not
20 just for nuclear power, but I am familiar with one prison in
21 the ten mile emergency planning zone that does have
22 extensive plans for evacuation. It might not be at the same
23 time scale as the public evacuation, but there are plans and
24 resources identified to evacuate the prison.

25 MR. KRESS: If there are no more questions, I

1 would like to thank the staff for the very nice
2 presentation. It has been very useful to us, and we
3 certainly appreciate it.

4 MR. KANTOR: Thank you.

5 MR. KANTOR: The next, Ivan, we need Ivan here.
6 We could let Carl Michelson introduce this next topic, which
7 is Fire Protection Related Matters. We did have a
8 subcommittee meeting yesterday. Do you feel comfortable
9 introducing this, Carl, in Ivan's absence.

10 MR. LARKINS: I will get him. I think he is in
11 the hall.

12 MR. MICHELSON: We need a change of the guard
13 anyway.

14 MR. DAVIS: Mr. Chairman, while we are waiting, I
15 am trying to determine what we have just heard and how it
16 relates to the letter that we have on this issue. Do you
17 have one --

18 MR. KRESS: I have a very much revised draft of
19 what you saw last time which I wrote in the absence of this
20 presentation, and I think it may still be pretty good. We
21 may not have to look at it in light of what we have heard,
22 but, in fact, I need to give that draft to get it typed up.
23 I am glad you reminded me.

24 Ivan, we have come to an early start of the fire
25 protection thing.

1 MR. CATTON: Five minutes ahead.

2 MR. KRESS: Yes. We're trying to get to your
3 letter is the reason and I am turning the introduction over
4 to you at this point.

5 MR. CATTON: Okay. I thought it was just
6 harassment.

7 MR. KRESS: Yes, but it is a little of both.

8 MR. DAVIS: It's coming.

9 MR. CATTON: I am going to get that after these
10 people are finished. Is there an agenda?

11 MR. COE: Item 3.

12 MR. CATTON: I will keep my introduction brief and
13 then I hope that the others can keep their presentations
14 brief and maybe we can finish the formal part of this in an
15 hour or so and we can address the letter, the draft of which
16 should be available pretty quick.

17 The question that we have to address is what to
18 recommend to the Commission as far as a method to resolve
19 the Thermo-Lag issue.

20 What we are going to hear about is four options.

21 One is business as usual.

22 Two is a permutation that probably would exist
23 through the exemption process anyway.

24 Three is actually somewhat different in that more
25 probabilistic viewpoints will be brought to bear.

1 Four is a full-blown performance-based fire
2 regulation process.

3 At present the Staff is recommending that Option 1
4 be followed, but I have just read through their presentation
5 to the Commission and it seems to me that Option 1 with
6 exemptions could be any one of the others, depending on how
7 the exemptions are treated.

8 MR. DAVIS: Except 4.

9 MR. CATTON: Except 4, except 4. That's correct.

10 So with that, let's get started. I believe the
11 first speaker is going to be --

12 MR. VIRGILIO: Steven West will be speaking for
13 the Staff this morning.

14 THE REPORTER: Can you identify yourself?

15 MR. VIRGILIO: Marty Virgilio, NRR staff.

16 MR. CATTON: There is Steve.

17 [Pause.]

18 MR. CATTON: And it looks like his package is
19 thin.

20 MR. WEST: The package is thin; the issues are
21 weighty.

22 [Pause.]

23 [Slide.]

24 MR. WEST: My name is Steven West. I am a Section
25 Chief in the Plant Systems Branch of the Office of Nuclear

1 Reactor Regulation.

2 My section is responsible for fire protection at
3 the operating reactors and we have been tasked with the
4 Staff effort to resolve the Thermo-Lag issues.

5 There are some collateral issues that other
6 divisions and branches are working on and we do the
7 coordination -- for example, the rating and seismic issues
8 and that kind of thing.

9 There were questions yesterday about Thermo-Lag
10 and some questions about what it was. I brought a piece and
11 I won't spend a lot of time on it but I'll pass it around.

12 This is a nominal, half-inch panel which comes in
13 a sheet like gypsum board and it is cut up to form boxes
14 around cable trays. That's the principal application and
15 this is the Thermo-Lag itself, the white, and the back is
16 the stress skin and we had a discussion yesterday about why
17 is the colors different in photographs and that kind of
18 thing and this will help, I think, explain that.

19 A three-hour barrier is thicker and it has a
20 screen on both sides. That is the only difference.

21 MR. MICHELSON: That screen is made of what
22 material?

23 MR. WEST: It is just a carbon steel, mild steel,
24 I believe.

25 [Slide.]

1 MR. WEST: Dr. Catton described the four options.
2 I am just going to move into our discussion, detailed
3 discussion of each of the four options.

4 [Slide.]

5 MR. WEST: This is basically the same presentation
6 that we gave to the Commission on May 20th.

7 We worked for probably two months on the options.
8 It was a concentrated, concerted effort by the Staff and our
9 management up through Jim Taylor, the Executive Director for
10 Operations.

11 There was an awful lot of debate and discussion.

12 Option 1 of the four was to continue with our
13 original plan of returning the plants to compliance with
14 Appendix R or whatever fire protection commitments they had
15 made which would require them to rely on these Thermo-Lag
16 fire barriers.

17 We felt that a couple of things were driving us
18 towards this option and recommending this as the preferred
19 Staff approach for the resolution of the issues.

20 One is when you look back at Appendix R there has
21 been a tremendous amount of industry and Staff effort over
22 the past 13 or 14 years to bring the plants into compliance
23 with Appendix R. We felt that until the Thermo-Lag issue
24 surfaced that plants were in nominal compliance with
25 Appendix R.

1 You find the odd problem occasionally. Usually
2 they are self-identified by the individual licensee and they
3 implement a fix and bring themselves back into full
4 compliance.

5 We haven't seen any significant, at least in the
6 past five years, any real significant problems in general
7 with Appendix R implementation so you have that and as a
8 result of that you have a lot of satisfaction by industry
9 and the Staff and the public that the plants are fire-safe.

10 Then Thermo-Lag came along and we had to deal with
11 that problem.

12 We have been working on it for about three years
13 internally and with industry and over those three years we
14 have gained an awful lot of information about Thermo-Lag
15 and Thermo-Lag fire barriers. We have re-looked at fire
16 safety in the plants.

17 We wanted to continue with this option because we
18 want to take advantage of all of that effort, a tremendous
19 amount of effort both in the original compliance with
20 Appendix R and with what we have learned about Thermo-Lag
21 fire barriers.

22 Now at least 22 units as of a month or so ago
23 have written us and told us that they have either already
24 fixed the problem in their plant by removing the barriers
25 and replacing them with something else or re-locating

1 components or doing an analysis that shows that it wasn't
2 really necessary, or they have made a commitment to do
3 something that will return them to compliance.

4 So we started out, I think when we first started
5 counting plants, to have 83 or 82 plants or units with
6 Thermo-Lag. Twenty-two have said everything is okay. A
7 couple have shut down and for other reasons we are down to
8 about 59 or 60 that have a problem yet to deal with.

9 Now what have we learned about Thermo-Lag?

10 We have done a lot of tests, full-scale fire
11 endurance tests and small scale fire tests, to understand
12 the thermal performance of the system. We have done
13 combustibility tests.

14 Industry has done an awful lot of tests. I am
15 talking about NUMARC or NEI now, TVA -- one of the licensees
16 that kind of took the lead for this issue.

17 MR. CARROLL: Their incentive now is because Watts
18 Bar licensing is coming up, is that right?

19 MR. WEST: Watts Bar has a -- Comanche Peak, Texas
20 Utilities had an incentive to license Comanche Peak Unit II
21 because they had a commitment to Thermo-Lag. TVA now has an
22 incentive to license Watts Bar and they have a certain
23 commitment to Thermo-Lag, so those two licensees have done a
24 lot of work, particularly with the one-hour barriers, which
25 is what they used.

1 What we have learned about the one-hour barriers
2 is the one-hour barriers that are installed in the plants
3 today won't last one hour, they will last maybe 20 or 30
4 minutes. However they can be updated, we believe, using
5 additional Thermo-Lag materials.

6 The failures have principally been at seams and
7 joints where the material has been put together. Under fire
8 exposure, the seams and joints weaken. Where they burn
9 through, you have an opening in the barrier, the fire gets
10 into the cables and you have a problem. It won't last for
11 one hour. In 20 minutes that may happen.

12 But by reinforcing the seams and joints with
13 additional stress skin and Thermo-Lag, you can get the one-
14 hour barrier to last one hour.

15 MR. CATTON: Is this material the stress skin?

16 MR. WEST: Yes. And you can buy that just as
17 screen without the Thermo-Lag attached and you can wrap it
18 around joints and put some trowel-grade material over it and
19 reinforce the joint, for example.

20 MR. CATTON: What is it, fiberglass?

21 MR. WEST: Steel, just mild carbon steel.

22 MR. MICHELSON: Clarification. Are there any one-
23 hour barriers made of Thermo-Lag that do last one hour?

24 MR. WEST: Based on testing that TU Electric did,
25 I would say there are some barriers in the mid-sizes of

1 conduits, maybe three, four inches.

2 MR. MICHELSON: So it's not all one-hour barriers,
3 but it's fairly a large number.

4 MR. WEST: Most.

5 MR. MICHELSON: Same statement for three hours.
6 Are there any that will last three hours?

7 MR. WEST: The tests that NEI did, it looks like
8 there were very -- maybe one or two of the three hour
9 barriers that last close to three hours.

10 MR. MICHELSON: One can't say that none of the
11 three-hour barriers last three hours?

12 MR. WEST: No. You can't say that.

13 But we have found that three-hour barriers are a
14 challenge. They still continue to be a challenge. They'll
15 last, in the base line, in other words non-upgraded, for
16 about one hour.

17 The NRC -- I didn't mention this to the
18 subcommittee yesterday -- when you are meeting with NEI
19 talking about criteria in December, I was at UL,
20 Underwriters Laboratories in Chicago running some tests for
21 the Staff. We did some three-hour fire endurance tests. We
22 tested three assemblies and we found that they'll last about
23 an hour. NEI did some tests and tried to upgrade it using
24 additional Thermo-Lag materials and they found that in
25 general the upgrade is so substantive, the amount of work

1 and material and effort that would be involved to upgrade a
2 three-hour barrier to really last three hours, it is so
3 significant that it really does not appear to be practical
4 to do that in a plant.

5 I think one of the examples they mentioned
6 yesterday is you could take a 3/4-inch conduit and before
7 you could get it to last three hours, the thing would be
8 eight inches in diameter with Thermo-Lag material and that's
9 just not practical.

10 You introduce a lot of problems if you try to go
11 with that fix and the costs would be significant. You can
12 get into problems with clearances in the plant and that kind
13 of thing.

14 However, we feel there are a number of
15 alternatives that still exist for three-hour barriers. You
16 can do some of the things that are already being done,
17 continue to look for areas where you could relocate
18 components, reroute cables to come back into compliance, you
19 could reclassify the three-hour barriers as a one-hour
20 barrier and then maybe install a suppression system. Then
21 you would meet the rule. No exemption would be required or
22 Staff review for that matter. You could replace the
23 barriers with other materials. There are vendors out there
24 that tell us they have materials that will work. But then
25 you get into those costs of replacement.

1 I think in the SECY paper, 94-128, we had five or
2 six or eight options.

3 MR. CARROLL: That's a point that probably ought
4 to be amplified on for people that weren't here yesterday.
5 You said there are vendors who claim they can provide a
6 three-hour fire barrier. But, as I understood you yesterday
7 in response to questions, you have not conducted any
8 extensive testing to demonstrate that claim; is that right?

9 MR. WEST: This is an are, this area of upgrading
10 a Thermo-Lag barrier with another material or using another
11 material to replace Thermo-Lag, that has not really, in my
12 view, been fleshed out. There could be a lot more work done
13 in that area.

14 NEI had planned to do some work which they
15 deferred in that area. We are working with licensees. We
16 are working with Commonwealth Edison Company. They have
17 proposed to use another material to upgrade Thermo-Lag.
18 It's a material that is not currently used. But we are
19 working with them. There are licensees pursuing this course
20 of action.

21 MR. MICHELSON: Maybe I need a clarification. I
22 thought you told us yesterday that three-hour barriers made
23 out of other material have passed the three-hour test. Did
24 I misunderstand that?

25 This is not a new problem and the testing has been

1 going on for many years. Did I misunderstand that the
2 three-hour barriers not made out of Thermo-Lag have been
3 verified to be three-hour --

4 MR. WEST: I think what I said yesterday is that
5 there are vendors, a number of vendors who have submitted to
6 the NRC test reports and in those reports they claim that
7 their barriers would last one and three hours.

8 MR. MICHELSON: These barriers have been used for
9 15 years or 10 years at least. What did you look at for
10 test verification 10 years ago when they came in and said
11 this is how they are going to do it?

12 MR. WEST: Well, we looked at the -- we did a
13 similar review for those barriers that we did for Thermo-
14 Lag.

15 MR. MICHELSON: And you had --

16 MR. WEST: And we concluded 10 years ago or
17 whenever we got those submittals that we looked at, that
18 those barrier systems were adequate to meet our
19 requirements.

20 MR. MICHELSON: That was based on test results,
21 including Thermo-Lag?

22 MR. WEST: Including Thermo-Lag.

23 MR. MICHELSON: Thermo-Lag was found later to have
24 a problem. But the other barriers, at least in the past,
25 were thought not to have a problem. And until they're

1 reevaluated, they don't have a problem.

2 MR. WEST: If I gave you the test that we looked
3 at for Thermo-Lag 10 years ago today and you looked at those
4 tests, you may conclude that those barriers are acceptable.
5 There are circumstances surrounding the Thermo-Lag barriers
6 that, you know, we can't discuss, allegations that led us to
7 go back and look at those.

8 MR. CATTON: I don't think you're addressing the
9 question that has been put before you.

10 If you reevaluate the other materials, will they
11 pass?

12 MR. WEST: As I said yesterday, we are in the
13 process of reevaluating all those other barrier systems. We
14 have asked the vendors for materials to resubstantiate their
15 claims --

16 MR. CATTON: That's enough.

17 MR. WEST: I can't answer your question today. We
18 are doing the review.

19 MR. CATTON: You did. You said we're
20 reevaluating. That's fine.

21 MR. WEST: We have not completed that evaluation.

22 MR. CATTON: We have a time problem, so could you
23 continue.

24 MR. WEST: We will be happy to report to the
25 Committee the results of that review when it's done. We

1 have done small-scale testing at NIST. That testing has not
2 produced any show-stoppers. We believe the materials, at
3 least their thermal performance, is adequate to meet our
4 requirements. Until we complete the review, I don't think
5 anyone on the Staff is going to say this is an adequate
6 barrier.

7 MR. CARROLL: We are happy with your answer.

8 MR. WEST: I'm unhappy.

9 MR. MICHELSON: One clarification on your question
10 and statement, though. For the NIST test, did the Thermo-
11 Lag pass the NIST test?

12 MR. WEST: No, the Thermo-Lag did not pass the
13 NIST test.

14 MR. MICHELSON: It showed in -- but the other
15 materials did?

16 MR. WEST: Right.

17 MR. MICHELSON: Right.

18 MR. WEST: Yes, the NIST test we did with Thermo-
19 Lag, that was one of the first things we did and we said, we
20 have a problem here.

21 MR. MICHELSON: That was the statement I was
22 looking for and we got it.

23 MR. WEST: Is that resolved?

24 MR. DAVIS: Excuse me. I think it's worth
25 emphasizing that under the fourth item, the alternatives,

1 that's not a complete list.

2 MR. WEST: No, that's not a complete list. To fit
3 everything on a slide, we identified a couple. I believe in
4 the SECY paper, we may have identified seven or eight.

5 MR. DAVIS: Is one of them posting fire watches,
6 because I understood that was being used?

7 MR. WEST: The posting of fire watches is an
8 acceptable compensatory measure until a permanent corrective
9 action can be taken to bring whatever the degraded condition
10 is back into compliance with the regulations.

11 MR. DAVIS: Is there a time limit on how long that
12 can be used?

13 MR. WEST: There is no time limit. It's --

14 MR. DAVIS: For the life of the plant?

15 MR. WEST: Well, it's a Staff expectation that
16 they are temporary, whatever temporary means. And we are
17 expecting licensees with problems to take a corrective
18 action.

19 MR. DAVIS: But there is not a definitive
20 requirement for that?

21 MR. WEST: No. In our 50.54(f) letter that we
22 sent out in December, we did state our expectation and I
23 think it was that things would be fixed by '96 or something
24 like that. So we are not looking for these things to be in
25 place for the life of the plant.

1 MR. CARROLL: I would also comment for the benefit
2 of those who weren't here yesterday that we did see some
3 colored slides of some of these tests.

4 And a three-hour fire barrier is a pretty
5 remarkable device, something that will keep the cables cool
6 enough for three hours in a 2,000 degree furnace is a pretty
7 good trick, believe me.

8 Those things come out looking pretty warm to me.

9 MR. WEST: You're right.

10 And these barriers, just as an aside, present a
11 real fire protection challenge because any other barrier,
12 like a wall or a floor or a ceiling, generally, you have one
13 side is exposed to ambient air in the laboratory. And these
14 are not. It's an enclosed system.

15 And you're measuring temperatures inside a fairly
16 small and closed system. And, once the temperatures start
17 rising, it's a real challenge for the barrier.

18 Okay. So, in closing, I just want to emphasize
19 it. As you know, this was a staff-recommended approach. We
20 felt that we should stay the course on trying to return
21 plants to compliance. It was the action plan we had laid
22 out and had been working towards with industry.

23 And we wanted to -- we haven't come up with a real
24 good, or any reason, really, to alter our course at this
25 point.

1 MR. WYLIE: Let me ask on your limited exemptions.
2 Does that include elements of the other options?

3 MR. CATTON: It doesn't preclude them.

4 MR. WEST: A licensee could, if they were so
5 inclined, pursue option 2 or 3 on its own and submit it to
6 the staff as an exemption from the requirement.

7 MR. WYLIE: So that would be an acceptable
8 approach.

9 MR. WEST: But what we're saying, the message
10 we're trying to deliver in the Commission paper is we don't
11 think those approaches should be considered at this point an
12 acceptable technical basis for giving exemption, because,
13 number one, it deviates -- those approaches deviate
14 significantly from what the regulation says.

15 And if you're going to exempt a lot of plants from
16 the regulation on a common basis, you really should change
17 the rule.

18 I mean, you should get the public involved in the
19 process of reviewing it. It shouldn't be something that's
20 done by the staff and industry in isolation.

21 MR. WYLIE: Was that what the staff feels? It
22 should change the rule?

23 MR. WEST: Well, I think the general staff -- I'm
24 not sure exactly what the policy is, but once you start
25 making so many changes it becomes a generic change, you

1 should do -- if there is a rule involved, you should do
2 rulemaking.

3 MR. CATTON: Fifteen hundred exemptions are not
4 enough?

5 MR. WEST: Well, those exemptions run the board of
6 all the requirements for appendix R, scheduler exemptions,
7 emergency lighting, associate circuits analysis.

8 They're not focused on one specific thing like
9 this would be, you know, one or three-hour barriers.

10 I mean, if you're basically going to tell half the
11 industry out there that you don't need a one or three-hour
12 barrier like the regulation requires, you can come up with
13 some model or some other approach to show that what you have
14 is okay.

15 MR. CATTON: Option 2 doesn't change one or three
16 hours, it just changes the insult to the barrier.

17 MR. WEST: Right. That's a good --

18 MR. CATTON: Option three allows you to change the
19 time, doesn't it?

20 MR. WEST: Option three allows -- I'm sorry?

21 MR. CATTON: With Option 3, you could argue that I
22 don't need one hour. Twenty minutes is enough.

23 MR. WEST: Right.

24 MR. CATTON: Option 2, you still have to have the
25 one hour and three-hour. It's just the insult is such that,

1 although it will not survive E119, it would survive the
2 particular environment.

3 MR. WEST: Right. That's right. That's a good
4 lead-in to option 2. We should move into it.

5 But, let me just say the reason we mention
6 exemptions here is we wanted to -- what we're looking to do
7 is business as usual. The regulation allows exemptions.
8 The Commission recognized when it promulgated the regulation
9 that exemptions should be allowed. It's built into it.

10 And we in industry have taken advantage of it
11 where there's a sound technical basis for an exemption.

12 And all we're saying here is we're going to
13 require compliance. We're going to continue with what the
14 current regulation says, and we're going to continue to
15 grant exemptions where they're technically justified.

16 MR. MICHELSON: I think I was a little puzzled by
17 some statements you made earlier. I think you indicated
18 that option 2 could not be used as an exemption under option
19 1. And I fully agree.

20 However, the information might have been developed
21 if one were following option 2, such as a new time
22 temperature curve, and so forth, could very well be used in
23 a basis for an exemption under option 1.

24 It's just that the whole approach, per se, cannot
25 be said: I'm going to do option 2 as my solution.

1 And I think, no, you can't do that. The
2 regulations spell out what you have to do, but you use the
3 information you might have developed in showing that your
4 approach is equally safe to what one normally requires.

5 And I didn't quite hear those same kind of words
6 coming out, but maybe I just didn't listen too well.

7 MR. WEST: Well, as we said yesterday, we're not
8 trying -- if we stick with option 1 and we agree that we can
9 grant exemptions, we're looking back at all the exemptions
10 we granted in trying to establish what the boundaries were.
11 And we're not trying to shut the door on any particular
12 exemption, or type of exemption.

13 We have an open mind to look at things, and look
14 at the technical bases. At this point, we can't rule out
15 anything.

16 I'm telling you what our expectation was with the
17 option.

18 MR. MICHELSON: And I'm assuming there's some new
19 potential boundaries for exemption, such as a new time
20 temperature curve, which you might never have run into under
21 your old exemption process. Nobody ever came in with a new
22 curve.

23 Now I think it would be legitimate to come in with
24 a new curve if you can show that you have an equally safe
25 situation.

1 And that curve would have to be based on what's
2 really burning and not what's hypothetically burning.

3 MR. VIRGILIO: Carl, it's not clear to me that you
4 even need an exemption to use option 2. We talked about
5 yesterday with the subcommittee clearly going through the
6 public review process. The statements of consideration to
7 the rule clearly call out the E119 as the basis that we used
8 in establishing the three-hour and one-hour barrier rating.

9 MR. MICHELSON: You're blowing my mind again
10 because I thought it was very clear. Option 1 is the
11 regulation.

12 MR. VIRGILIO: Right.

13 MR. MICHELSON: We have to follow it, not any
14 other option.

15 MR. VIRGILIO: Right. But, option 2 --

16 MR. MICHELSON: But we could use the information
17 developed in option 2 to justify our actions under --

18 MR. VIRGILIO: Right. And all I'm saying is the
19 information in option 2 may, in fact, be compliance. And
20 the way we talked about yesterday proceeding with option 2
21 was going through the public review process.

22 We would, for example, we might want to choose, if
23 we were to adopt option 2, revise our generic letter 86-10,
24 supplement 1, go with the supplement 2, which would explain
25 how one would go about doing a test program that would

1 satisfy the regulations.

2 If we were to adopt option 2, it would clearly go
3 through the public review process. But it doesn't
4 necessarily mean that there is an exemption associated with
5 option 2. That's not clear to me. There may be. But, in
6 my mind, your E119 is in the statements of consideration,
7 not a hard and fast requirement of the rule.

8 MR. CATTON: And I guess FMRC -- Karydas yesterday
9 how you could do that without having your curves like option
10 2.

11 MR. VIRGILIO: Right.

12 MR. CATTON: Or, you could relate the load in a
13 given room to the present testing program under ASTM E119.
14 A nice, clean, almost a nomograph for accomplishing it.

15 MR. VIRGILIO: But, clearly, we would want to
16 invite public comment in the process. Clearly, we would go
17 through the review process that we've established. And I
18 don't see that you would gain any time through that
19 mechanism. You would just not have to go through the
20 exemption process.

21 [Slide.]

22 MR. WEST: Maybe we should just go to Option 3 --
23 but there were a couple of things I wanted to say about
24 Option 2, so let me just say for the benefit for those who
25 weren't here for the presentation yesterday, there are some

1 feeling and there are, you know, really disagreements among
2 fire protection professionals on what all this means, but
3 there is some feeling that the ASTM E119 standard time
4 temperature curve that is used to do fire endurance testing
5 may be a more severe fire than that which you would expect
6 in a nuclear power plants in many areas, not all areas.

7 Clearly, the diesel generating room is going to
8 have a higher fuel load if you have the release of fuel and
9 that kind of thing.

10 [Slide.]

11 MR. WEST: This is the curve that is used when you
12 test an assembly. Just briefly, this is one-hour and three
13 hours, and you put something in the furnace and you turn on
14 the burners, and you follow this time temperature profile,
15 and you run this thing for the duration of the rating you
16 are looking for, and you reach 1000 degrees in five minutes,
17 and then you taper off.

18 For a one-hour test, at the end of one hour you
19 should be at 1700 degrees, and at three hours, 1925.

20 MR. LINDBLAD: What is measured there, gas
21 temperature or radiant --

22 MR. WEST: Gas temperature, thermocouple. Well,
23 the environment with thermocouple in the furnace.

24 Now, what this option says is that there -- I have
25 given this presentation several times formally and to a lot

1 of people who are interested, Commissioner's assistants that
2 are trying to help the Commissioners make up their minds.
3 Sometimes you hear, well, doesn't this lead you into Option
4 4 which is a performance-oriented, risk-based rule,
5 something that addresses these concerns of fire barrier
6 performance? And my answer to that is, no, it doesn't.

7 It is possible that some of the results of this
8 work may be used in that rule, but right now we have a clean
9 slate and what the option says is maybe you can replace this
10 curve and do your testing with another curve.

11 So what we said in our paper was maybe we can have
12 a lower curve where the fuel load is lower, use this curve
13 for some fire areas where the fuel load is higher, and then
14 in the diesel room you may even need a higher curve.

15 MR. DAVIS: Excuse me. Maybe you mentioned this
16 before, but do you recall what hypothetical fire this curve
17 is supposed to represent?

18 MR. WEST: This curve is based on fire testing
19 that was done at the turn of the century using typical
20 building construction and occupancy from the late 1800s and
21 early 1900s.

22 MR. DAVIS: So it would be like wood fires?

23 MR. MICHELSON: I thought it was a hardwood fire.

24 MR. WEST: Ordinary combustibles, principally
25 wood.

1 MR. MICHELSON: Hardwood.

2 MR. WEST: And between the turn of the century and
3 now people still work on this curve and try to see if it is
4 valid, what it means for this building, that building and
5 all that kind of stuff.

6 So what we are saying is we will look at some
7 different curves. I am going to spend some time on this
8 because this is a really interesting option.

9 So we may end up with three curves, okay? What we
10 are saying is it is not a performance-based approach. It is
11 an approach of looking at the individual areas, yes. But as
12 Marty was saying, the real purpose is to redefine what you
13 mean by a one and a three-hour barrier so that you can live
14 within the existing regulation that specifies in the
15 regulation that you need a one-hour or a three-hour barrier,
16 but it doesn't specify in the body of the regulation that
17 you need to use E119.

18 It does say in the statement of considerations
19 that when you want to put in a one and three-hour barrier,
20 it may mean it is a barrier tested in accordance with this.
21 And that is not Appendix R; that goes back to the original
22 NRC Staff Guidance before Appendix R that said you will use
23 E119.

24 Now, when you talk about coming up with these
25 curves, we had some discussion yesterday about, what do you

1 mean you are going to look at the feasibility of this?

2 Well, what I mean is we don't know if this is practical, we
3 don't know what these curves would look like.

4 Let me give you an example. Every time we come
5 down here, we make a big show of saying, gee, you go in
6 these areas and the fuel load is low; it is 5 minutes, it is
7 10 minutes; it is 20 minutes. Well, what the heck does that
8 mean?

9 What it means is if you take all the combustibles
10 that are in some area of the plant and you add them up, add
11 up the weight of all the cable installation, the lube oil
12 and everything else, and then you spread it across the area
13 uniformly and you burn it, you can say in that area we have
14 a 15 minute fuel load.

15 Now, 80,000 Btus equates to a one-hour fire
16 severity on this curve, so when we say there is a 15-minute
17 fuel load, we do that Btu calculation, and we say there is
18 the fuel load. That's your fire severity for that room.
19 Okay?

20 So you just do the math. You figure out what will
21 burn, how much you got, you burn it, and you say, oh, 15-
22 minute fuel load; there's my fire severity.

23 Now, if you are going to take that fire severity -
24 - say you do -- you find out one-third of the areas of the
25 nuclear power plant have this 15-minute or 20 or 30-minute

1 fuel load. Now, you are going to convert that into another
2 curve that is going to give you a one-hour fire rating.

3 So what are you going to do? Are you going to
4 take the area under that curve, come up with a new curve
5 that looks like that and gives you the same area? Well, if
6 you do that, your fire protection is going to be -- you
7 increase your ventilation rates to get rid of that nuisance
8 heat.

9 MR. MICHELSON: And this is all under the
10 assumption that uniformed distribution of the combustibles
11 is a valid model and it clearly is not.

12 MR. WEST: Exactly. What I am saying is why we
13 want to study this is -- we have some questions that need to
14 be answered. Are you going to do this? Are you going to
15 take the fuel in the room and say we are going to burn that
16 fuel for three hours and it is going to be like standing in
17 your kitchen when you turn the oven on and it gets a little
18 uncomfortable?

19 Or, are we going to say we are going to take that
20 fuel, we are going to do some fire tests, we are going to do
21 a free burn and come up with the curve for the free burn
22 where you may get the curve that goes like this?

23 It is a little exaggerated but the point is when
24 you do that free burn experiment you may come up with a
25 curve based on that little bit of fuel, which is more severe

1 earlier and decays faster. It may never get to an hour.
2 You may have to do some kind of fancy-shmancy math and say,
3 oh, I'll take this part of the curve and add it here and
4 come up with a curve.

5 You will find, and research has been done, a
6 little bit -- we haven't found a whole lot yet -- but when
7 you take assemblies that are rated at this curve and subject
8 them to a more severe fire severity earlier, they won't last
9 as long so a small fuel load can be more of a problem than
10 you think based on this fuel load business.

11 This work or work along these lines has been done
12 by Sandia --

13 MR. MICHELSON: But it's totally dependent on
14 where the target is relative to where the fire is. That
15 becomes very -- that's case by case.

16 MR. WEST: Exactly. Exactly.

17 MR. MICHELSON: These curves are almost
18 meaningless except as some way of at least starting but
19 changing these curves and playing around is not giving you
20 the answer.

21 MR. CONNELL: -- relative comparisons.

22 THE REPORTER: I'm sorry, I can't hear.

23 MR. CONNELL: This is Ed Connell.

24 The curves are only useful for relative
25 comparisons.

1 MR. MICHELSON: That's correct.

2 MR. CONNELL: Everybody knows that a one-hour
3 barrier -- knows what that means. It doesn't mean it is
4 going to last one hour but they know that a one-hour barrier
5 isn't as good as a three-hour barrier. It is all relative.

6 MR. WEST: Okay, so what we meant in the
7 Commission paper when we said we want to study this, we
8 meant we have a lot of questions and we don't feel
9 comfortable now saying to the Commission we should proceed
10 with developing curves. We don't know if it will be three
11 curves. It may be four curves.

12 The Chairman says why don't you have a different
13 curve for each area, and then there may be 5,000 curves.
14 Maybe if you model every area you will come up --

15 MR. MICHELSON: You have to have a curve to reach
16 a target in each area depending on where the fuel is
17 relative to where the target is that you are trying to
18 protect. We want lots of curves.

19 MR. WEST: We want to make sure that when we study
20 this thing that we are not building in an oversimplification
21 that could take away margin or cause a worse problem just
22 because of the tests you are doing than you actually have in
23 the plant, and that is why we say we want to study this.

24 We want to look at it. We want to think about it.
25 We want to -- if the Commission wants us to study it we may

1 be back down here asking you when we develop these
2 questions, what do you think?

3 But the point is the way the option is structured
4 is we were saying by doing something like this, if it is
5 feasible we will redefine what a one hour and a three hour
6 barrier is, period, so instead of having, as somebody said
7 yesterday, one prescription that you can follow to meet the
8 rule, you will have three prescriptions you can follow and
9 hopefully you will have the engineering expertise to decide
10 which one you should follow.

11 Hopefully the Staff will agree with you when they
12 come out and do their inspection.

13 I think I am on my soap box.

14 MR. MICHELSON: Could you clarify one thing on
15 your Option 2 slide that I have in my hand in Tab 3?

16 MR. WEST: Yes.

17 MR. MICHELSON: It says if approved, the Staff
18 will report results within six months. "If approved" means
19 if the Commission tells you to proceed, is that what it
20 means?

21 MR. WEST: If the Commission says we think you
22 should do this study, we see merit in this approach, we
23 would like you to study it and tell us, answer these
24 questions, we would study it and hopefully get back to the
25 Commission.

1 MR. MICHELSON: You think it would take about six
2 months to come back with your appraisal of the situation?
3 That's what it means?

4 MR. WEST: Well, that would be our plan.

5 MR. MICHELSON: That's all I wanted to know.

6 MR. WEST: I love this option, to talk about it
7 anyway.

8 MR. CATTON: That was for my benefit, I'm sure.

9 MR. WEST: I will talk about this to anybody that
10 will listen.

11 [Slide.]

12 MR. WEST: Option 3, one thing we found -- you
13 know, we were concerned ourselves but then the Commission
14 became concerned and we got more concerned.

15 It didn't look like these test programs and things
16 were going to result in a timely resolution of the issues so
17 we went back out to every plant that uses Thermo-Lag and we
18 said give us some information about what you have and what
19 you are doing about it and if you have any options you are
20 considering for resolving this issue that we haven't thought
21 about yet, why don't you tell us what they are so we can
22 start thinking about them too and let you know if they are
23 okay.

24 When we did that what we got back was 35 plants at
25 22 sites were planning to use something that they called a

1 performance-based approach or solution. In other words they
2 were going to try and justify their existing Thermo-Lag
3 barriers using fire modeling and PRA or PSA insights and
4 results.

5 We looked at that and in fact actually one
6 licensee came in with -- most of them just said we are going
7 to do this and they didn't tell us a whole lot about what
8 they meant -- but one licensee did come in, Florida Power &
9 Light, with kind of a outline of what they meant by this
10 approach.

11 We looked at it. They wanted to meet with us. We
12 met with them. We met with them again and we had, you know,
13 frankly, we had some problems technically with what they
14 were doing but we also had a problem with the other people
15 we were talking to on the phone said, well we are going to
16 do it but we are not doing exactly what Florida Power &
17 Light is doing -- we have this twist or we have that twist.

18 We started saying are we going to get into this
19 cycle of reviewing all these things that we don't have a
20 high level of competence in right now?

21 We have a plan before the Commission to develop a
22 performance-based rule; wouldn't it be better to do that,
23 where we're looking at the rule in its entirety across the
24 fire protection program and not just looking at Thermo-Lag
25 fire barriers.

1 MR. CARROLL: Now when you say across the fire
2 protection realm --

3 MR. WEST: Realm? Or program

4 MR. CARROLL: Or program -- you do include in that
5 fires during shutdown?

6 MR. WEST: Yes.

7 MR. CARROLL: Good.

8 MR. WEST: It will be handled by one regulation or
9 another.

10 [Laughter.]

11 MR. WEST: We plan to handle that by regulation.
12 I'll leave it that way.

13 We worked with Florida Power and Light for a
14 while, and we got concerned. And the Commission was saying,
15 you know, there was a feeling that this really departs from
16 appendix R. It's nothing that we have not used fire models
17 and PRAs or PSAs to assess, or ensure regulatory compliance.

18 So we felt that we needed to go back to the
19 Commission and say, We're getting a lot of -- there's a lot
20 of industry interest in this. We don't really like this
21 approach. And, in fact, we're not planning to do anything
22 else with these approaches unless you want us to.

23 And that's what our Secy 94-127 says about option
24 3. We stopped all work on this activity, and we're not
25 doing anything. And, unless the Commission comes back to

1 us, we're not going to use it.

2 MR. MICHELSON: On the little discussion we had on
3 option 2, of course, we began to appreciate the importance
4 of knowing where the target is, as well as knowing what kind
5 of fire we had and its location.

6 If you're doing the PRA approach versus the pure,
7 simple, deterministic approach, the PRA has to reflect what
8 the failure of probability is dependent upon where the fire
9 is, exactly relative to the target, and what its combustible
10 content is -- and, man, that's a very extensive PRA. I
11 haven't seen one like that so far.

12 MR. WEST: Now, remember, we're talking about
13 solutions for thermo-lag fire barriers. We're not against
14 using an approach like that. But we said we already have
15 the vehicle to do that. We're, you know, the agency is
16 looking at a performance --

17 MR. MICHELSON: You have the methodology by which
18 you could do such a PRA. I doubt anybody in their right
19 mind would try to undertake justification by that route. It
20 would just be insurmountable -- it would be much more
21 expensive than fixing the thermo-lag.

22 MR. WEST: You may be surprised.

23 MR. MICHELSON: I might be, pleasantly.

24 MR. WEST: There's at least one licensee that
25 tells us they can do that.

1 MR. MICHELSON: Yes. I'd like to see the product.

2 MR. WEST: Well, we don't want to see it because
3 we don't want to do this review.

4 [Laughter.]

5 At least, not for this purpose, we don't want to
6 see it. We are interested in it, of course.

7 So, anyway, we said, you know, there's a lot of
8 technical challenge in this. We have a plan to develop a
9 performance-based rule. Industry is interested in that.
10 They're preparing a petition. They know what they want.
11 Let's get that. Let's look at it.

12 And that's really option 4.

13 So, option 4, in and of itself, with respect to
14 the performance-oriented risk-based rulemaking, is not
15 really an option. It's something the agency is doing. It's
16 something industry is working on. And it's something we
17 actually have a schedule to do, which was provided in Secy
18 94-090.

19 The Office of Research is leading that effort, and
20 NRR is providing quite a bit of technical support,
21 obviously.

22 So, we told the Commission that, you know, we'll
23 continue down this path. This is where we should be looking
24 at these other things, looking at curves, looking at PRAs,
25 looking at fire models. We're not afraid of fire models.

1 We like fire models.

2 But, we're not sure there's a fire model out there
3 that we can use to make regulatory decisions. And it goes
4 without saying in this room that we're taught, you know,
5 that these fires can have serious consequences.

6 Society will accept the fire in this room and a
7 couple of us dying in it. Society won't accept a fire in
8 the nuclear power plant that results in an inability to shut
9 down the plant.

10 And we need to be careful at trying to fine-tune
11 fire protection so fine, looking at these risks, that we
12 lose sight of that. Appendix R in the statement of
13 considerations says:

14 This agency will not accept a design basis fire.
15 Fire is unpredictable. Things change. Conditions change.
16 You run your fire model today, and everything looks great.
17 Two weeks later, somebody brings a drum of oil in your area.

18 Sure, you have administrative control to prevent
19 that, but it happens. So we're saying let's do it, but
20 let's use this approach when we do that. Let's go through
21 the rulemaking. Let's get all the interested parties
22 involved.

23 And if, as a result of this, a licensee can use
24 the results to help resolve the thermo-lag issue, that's
25 fine.

1 MR. CATTON: I think here we agree with you.

2 MR. CARROLL: Oh, whoa, whoa, whoa. No, no.

3 That's what we said in the Commission paper. The Secy 94-
4 127. This Secy paper says something different.

5 MR. WEST: Because you're not going to have option
6 4 employees in the time frame you want to resolve thermo-
7 lag.

8 MR. WEST: If we meet the schedule that Research
9 has set up with the NEI input, this rule will be in place in
10 August of 1996. If you look at some of these other options,
11 2 and 3, we haven't spent a lot of time talking about
12 schedules. It was mentioned yesterday, and maybe I'll
13 mention it again to emphasize it.

14 These are not short-term projects. You could get
15 into internal arguments on some of this stuff.

16 MR. CARROLL: Whoa, whoa, whoa. What I'm saying
17 is I don't see your statement that licensees could use the
18 results of this to solve their present thermo-lag problem.

19 MR. WEST: That's something that's before the
20 Commission. I'm not saying that -- I'm not saying that's a
21 given. That's before the Commission. That's why it's an
22 option here.

23 It's not an option. We're doing it. The option
24 is will this be useful as a way of resolving the thermo-lag
25 problem down the road.

1 And we don't know what the rule is going to look
2 like, so I don't know if it's going to help anybody or not.

3 MR. CARROLL: Okay. And your best estimate of
4 when this would be in place would be what?

5 MR. WEST: The schedule we put in the Secy paper
6 says this will be in place in August of 1996.

7 MR. DAVIS: When does that assume the NEI petition
8 will be submitted?

9 MR. WEST: By early fall.

10 MR. DAVIS: This fall?

11 MR. WEST: Right.

12 The Secy paper assumed it would be here in July.
13 There has been a delay. We've checked with Research, and a
14 couple of months slipped there. They say it doesn't impact
15 the schedule. It's an ambitious schedule.

16 MR. VIRGILIO Let me just add to that.

17 What you're recalling is the schedule, our current
18 schedule. If you go back to that Commission paper, it was
19 based on an assumption that the NEI petition would come in,
20 in May.

21 And at that time, we believed we could publish the
22 final rule in August. Now, the last time we spoke to NEI,
23 we were told that that was going to be delayed and we didn't
24 expect their petition until July.

25 Now, yesterday, we heard that it's more like

1 September or the fall time frame. So I think that August
2 '96 date that Steve is talking about is getting into -- it's
3 jeopardy now.

4 MR. CARROLL: Okay. That's fine.

5 MR. SHACK: But it just seems like an incredibly
6 ambitious schedule to me. Does that really include a
7 validated fire model? Or, is this just an outline of a
8 rule? Or, do you really think you'll have the tools in
9 place by then?

10 MR. WEST: Personally?

11 MR. CATTON: Nobody's seen the rule yet.

12 MR. WEST: We haven't seen the rule so we don't
13 know -- so I can't give you --

14 MR. SHACK: Is that a schedule for having the rule
15 in place, or is it somebody saying that they're going to
16 have the rule and tools in place by then?

17 MR. VIRGILIO: It's the publication of the final
18 rule, is August '96.

19 MR. SHACK: Publication of the final rule.

20 MR. WEST: But we would be working in parallel and
21 implementing guidance.

22 MR. SHACK: If you look at the dates here on the
23 building and construction people, and, you know, they're
24 working five-six years and they're still not there, just --

25 MR. WEST: Yes, I wanted you to see that paper. I

1 brought it down here. I'm not convinced you can go to K-
2 Mart and buy a fire model.

3 MR. CARROLL: Well, on top of that, I guess we'll
4 hear from NEI. I'm not even convinced they're -- how
5 serious they are about proceeding with this.

6 MR. WEST: That's another thing that's a
7 possibility. I think there have been proposed rules in the
8 past that have never made it to 10 CFR.

9 MR. CATTON: I understand that there is a -- and
10 this is aside from the Thermo-Lag issue because I think we
11 all agree this is not the place to deal with Thermo-Lag.
12 But when it comes to performance-based rules, my
13 understanding that Australia has one in place, Canada has
14 one in place and the English are about to have one in place
15 and are having some sort of hearings on June 23.

16 This is general fire regulation.

17 MR. MICHELSON: This is PRA and so forth.

18 MR. CATTON: It's risk based.

19 MR. MICHELSON: You have got to look and see what
20 kind of risk analysis is required to follow their particular
21 rule versus what we have made.

22 MR. CATTON: All I am trying to do is to make the
23 point that there are three countries -- two countries that I
24 know of that have them in place, one that is considering it
25 and having hearings soon. And I understand EDF also uses

1 the fire -- the performance-based fire regulation in their
2 plants.

3 The possibility is putting it a little bit far
4 out, I think.

5 MR. DAVIS: Do any of them use COMBURN as the
6 basis?

7 MR. CATTON: we heard yesterday that COMBURN is --
8 I can't quite remember the words that went along with it,
9 but George Apostolakis who is its father reacted as I
10 expected he would when I told him.

11 MR. WEST: He said that COMBURN III, I think he
12 said, totally inadequate.

13 MR. CATTON: That's right.

14 MR. WEST: And the fire model that FM was working
15 on was -- you could use it now off the shelf and two years
16 from now somebody will be in here telling you the FM thing
17 was great in its time --

18 MR. CATTON: Not only FM. There was also the
19 mention of others and that apparently there are a number of
20 these kinds of tools around the world.

21 MR. WEST: I suspect these may be some of the
22 issues that NEI is grappling with as they work on their
23 petition. I am not going to kid you, the Staff has a lot of
24 questions about fire models. Is the state of the art there
25 that we feel comfortable using them for regulation? There

1 are a lot of good models out there for using for
2 assessments. They give you an idea.

3 My personal opinion is the state of the art for
4 nuclear power plant fire model is not fully developed.
5 That's not to say it could not be.

6 MR. CATTON: I don't think this is the place to
7 discuss that, but I really look forward to the opportunity
8 when we meet to hammer it out.

9 MR. WEST: I do, too.

10 I think we would like -- I don't know if it was
11 mentioned yesterday -- we would like to come back and meet
12 with the subcommittee and discuss other fire protection
13 issues that we are working on because there are a lot of
14 interesting things going on.

15 MR. DAVIS: Yes. And at one time,
16 Mr. Subcommittee Chairman, we were going to discuss the FIVE
17 methodology and I would still like to keep that on the
18 agenda for the future.

19 MR. CATTON: In particular because the FIVE
20 methodology is based on COMBURN III. And after what we
21 heard yesterday, I am sort of eager to hear what EPRI would
22 have to say about such a statement.

23 MR. CARROLL: We did go into FIVE in great detail
24 a couple of years ago before you were on the committee.

25 MR. CATTON: We had questions about it then, Jay.

1 MR. CARROLL: I am sure you can, if you really
2 want to get up to speed, you can get the minutes and the
3 handouts --

4 MR. DAVIS: I believe that FIVE has been augmented
5 and upgraded since then, quite a bit. And I know COMBURN
6 has changed since then. I think it's time to revisit it.

7 MR. MICHELSON: You are talking about the current
8 version of COMBURN in these statements?

9 MR. DAVIS: COMBURN III, yes.

10 MR. CATTON: COMBURN III is what's supposedly now
11 used with the FIVE methodology and it was not at the time we
12 heard about it.

13 MR. CARROLL: Maybe it is a good idea then.

14 MR. CATTON: I'm going to move this along.

15 MR. WEST: I was going to say, Dr. Larkins asked
16 me to hand over the microphone.

17 So just in closing, just very briefly, the Staff-
18 proposed approach was Option 1. We would do the study under
19 Option 2 if the Commission thinks it's a meritorious option.
20 Option 3, we don't want to be rehearing plant-specific
21 performance-based approaches. And Option 4, the rulemaking,
22 we would continue to support that and work with industry to
23 implement.

24 MR. CATTON: For a few adventuresome utilities,
25 there is no way to preclude them from exercising Option 2

1 anyway, as near as I can tell. If they come in and present
2 a good case.

3 MR. CARROLL: The whole issue revolves around what
4 the Staff will accept for requests for exemptions under
5 Option 1.

6 MR. DAVIS: I understood yesterday that what they
7 would accept is what has already been accepted but not much
8 beyond that. Whereas, Option 2 would allow more latitude in
9 what --

10 MR. VIRGILIO: We agree. I mean, what we are
11 talking about is limited exemptions. And although that's
12 sort of a subjective word that has not yet been defined, I
13 don't think we are constrained to doing exactly what we did
14 in the past. But we are not looking forward to PRA models
15 or fire models or any exotic --

16 MR. CATTON: Option 2 does not require PRA models.
17 It just requires analysis of a given fire.

18 MR. BRADLEY: We proposed that as Option 2, not as
19 Option 1. Not as what we would look at as a limited
20 exemption.

21 MR. MICHELSON: That's where you keep giving me
22 two different signals. I thought earlier somebody could
23 justify a new time temperature curve that you would
24 entertain it under Option 1 for an exemption.

25 MR. McCracken: Conrad McCracken, Staff.

1 I will say, again -- I think I said it the same
2 way yesterday -- all the options that we've approved in the
3 past under Option 1 that we talked about as preliminary
4 exemptions, to the best of my knowledge, we have never
5 approved an exemption for something less than an one-hour
6 barrier or for a different -- I know we have never approved
7 it for a different fire curve. Under limited exemptions
8 under Option 1, we are not proposing to do that.

9 That doesn't prohibit somebody from submitting it,
10 but it is not my intention under Option 1 to approve it.

11 MR. MICHELSON: You are prejudging already that
12 you don't want to see a new time temperature curve. Isn't
13 that what you're saying?

14 MR. McCracken: I didn't say that. What I said
15 is, under Option 1 I am not proposing to approve it. If the
16 Commission tells us to go ahead and we look at that and we
17 see that it is a viable option, then that's something that
18 we would be discussing again with you before we implemented
19 it and probably with the Commission before we implemented
20 it. At that point, it could be done.

21 But as far as what I would approve as our normal
22 routine way of doing work, I consider that a broad enough
23 expansion beyond where we currently exist that I would not
24 do that without making sure everybody knew what I was up to.

25 MR. MICHELSON: It's a little different than I

1 thought I understood yesterday.

2 MR. CATTON: I just finished reading the
3 Commission -- the minutes from the meeting you people had
4 with the Commission and I sort of got the flavor out of it
5 that you agreed that there was a spectrum from 1 to 4 and
6 that you could probably slide a little bit into Option 2
7 through the exemption process. At least that's -- I'm not
8 sure if I interpreted it right.

9 I was probably looking for that when I read it.

10 MR. McCRACKEN: It's not our intent to do that.
11 We are trying to make them four distinct options and we have
12 heard a lot of comments, yeah, but they all flow together.
13 And technically, sure, you can make them all flow together.

14 But our intent to Option 1 is to process out,
15 process exemptions the same as we have in the past on the
16 same basis. I am not going to use Option 1, based on what
17 we have presented, to downgrade fire barriers or to go to a
18 less than one-hour barrier. It's our intent for one-hour
19 barriers that they upgrade the barriers. For the three-
20 hour barriers, we would look at ways of addressing it within
21 the regulations or, as I said yesterday, perhaps something
22 in addition to suppression.

23 We are open for how you could address three-hour
24 barriers and make them equivalent to what we thought was in
25 the regulation.

1 MR. CATTON: Well, that's just a different slant
2 on Option 2, isn't it? I didn't hear you -- let me --

3 MR. MICHELSON: He's not saying that.

4 MR. CATTON: If you would say it's a three-hour
5 barrier according to ASTM E119, period, now you've separated
6 clearly 1 and 2.

7 If you allow me to come in and tell you my fuel
8 loading is less here, I've done calculations that show this
9 is the insult and I put up a Karydas-kind of curve that
10 shows you how the E119 barrier that lasted one hour has an
11 equivalent rating of three hours under this fire loading,
12 would you allow that?

13 MR. McCRACKEN: If you did it exactly the way you
14 said, I would probably not allow it because he was trying to
15 develop a new curve.

16 MR. CATTON: I'm saying it is the same curve.

17 MR. McCRACKEN: If you came in and told me that it
18 was a three-hour barrier, you thought, and then you came
19 back and reviewed the design and it was really a one and a
20 half hour barrier, that based on fuel loading, fire brigade
21 response time, other suppression capabilities, that that
22 barrier would be adequate to protect public health and
23 safety, that's the basis that we've always granted
24 exemptions on.

25 And I would grant it on that basis.

1 MR. CATTON: Then I basically see no difference
2 between 1 and 2 other than the formalism associated with
3 different curves.

4 MR. McCracken: But the formalism of that curve is
5 the only basis that we've used up until now is ASTM E119.

6 If I'm going to back off of 119 as my basis for
7 the rating for fire barriers, that I don't think I should be
8 doing by sticking it under option 1 and sneaking a few of
9 them in.

10 That should be a conscious process that we as a
11 regulatory agency have agreed to, the Commission's agreed
12 to, and then we're going to start doing it.

13 MR. CATTON: The only thing that I said that's any
14 different than what you're saying is that I offered a
15 calculation that showed you that, indeed, this was the case.

16 And as soon as I say that, you say no. That
17 should be a good indication for the industry on how to deal
18 with it. Just argue about it long enough, and they will
19 agree.

20 And I think that's kind of silly, frankly. That
21 if you want it to be one and one alone, then you should say
22 so. Three hours, according to ASTM E119, period.

23 MR. McCracken: That's what it is as of today.

24 MR. CATTON: Period. Because as soon as you know
25 exemptions of the kind you're talking about, it seems to me

1 it's easy enough for me to demonstrate that this thing that
2 you have, that you call a barrier, using an ASTM E119 curve
3 can be shown to survive for three hours. We saw how it
4 should be done, yesterday.

5 MR. McCRACKEN: Right, we saw how it should be
6 done. But, the argument you're making is that I shouldn't
7 be granting exemptions on the basis I'm granting them. We
8 put those in the rule.

9 MR. CATTON: So I think there's --

10 MR. McCRACKEN: The rule was there and it said
11 right in the rule.

12 MR. CATTON: No, I understand.

13 MR. McCRACKEN: Exemptions are a way of addressing
14 this issue. If I'm going to come off E119, which I think is
15 a substantial change from the position we're in, then that's
16 one that we should have approval. You people should have
17 reviewed it and agree that's how we should do it. The
18 Commission should have reviewed it.

19 We should say we as an agency are going to do
20 this.

21 I'm not saying it's technically the wrong way to
22 go. I'm just saying it's enough of a change in the way we
23 handle policy.

24 MR. CATTON: No. I just was trying to understand
25 how you would deal with the exemptions. I think I

1 understand now. And I think I wouldn't know how to deal
2 with you as a utility now.

3 MR. McCracken: Well, they do know how to deal
4 with them. That's why we granted 1,600 exemptions.

5 MR. Carroll: Let me ask a question to help
6 clarify. You mentioned yesterday, Conrad, that you got
7 requests for exemptions for a utility in trying to bullet-
8 proof themselves to get a license, slathered thermo-lag all
9 over the joint. And then came in and said, well, this
10 particular application is ridiculous. There isn't any fire
11 source in this area.

12 And you granted them an exemption. And they just
13 abandoned the stuff in place.

14 Now your rationale in that case was that they
15 didn't need it in the first place. Is that it?

16 MR. McCracken: I don't think you're quoting what
17 I said yesterday. You may be embellishing something. I
18 think the --

19 MR. Catton: I think the slathering was a misuse.
20 [Laughter.]

21 MR. McCracken: I don't remember using slathering
22 at all.

23 What I said was there was one licensee who came in
24 requesting an exemption for thermo-lag. And he had it
25 applied on a safe shut-down cable that was all by itself

1 running out alone in an area; that if he had asked me for
2 that exemption with no thermo-lag on it, I would have said
3 yes.

4 That was consistent with my previous-based. But,
5 because he --

6 MR. CATTON: Yes, I've got you.

7 MR. McCRACKEN: But, because he had thermo-lag on
8 it, thermo-lag was indeterminate, I said, no, I'm not going
9 to review it now, until we resolve the issue of how we
10 intend to address thermo-lag, I'm not going to do that. I
11 won't grant that exemption.

12 But there was no slathering involved.

13 [Laughter.]

14 MR. CATTON: But, if you took it off, it would be
15 okay.

16 MR. McCRACKEN: If it had not been on when he came
17 in and asked for the exemption, I would have granted the
18 exemption.

19 MR. SHACK: And if option 1 was in place, if you
20 decided how to handle the thermo-lag problem, you would have
21 approved it.

22 MR. McCRACKEN: Absolutely. Under option 1,
23 they'd come in and I'd say, Yep, you've got your exemption.

24 MR. WEST: I'm going to sit down, but one of the
25 things I brought for you this morning is a letter we wrote

1 to NIST last year, where they had the feeling one of their
2 scientists, that we were basing exemptions and doing reviews
3 based just on fire load. The concept I discussed up here.

4 And that letter describes what the exemption
5 process is, how we look at exemptions, the things we look
6 for, and just -- that may give you a good understanding of
7 what we go through. It's probably the best documentation of
8 what exists conceptually of what we do.

9 MR. MICHELSON: I have a somewhat different
10 question I'd like to ask, since I'm still puzzled by it.
11 And that is you do a three-hour test, and let's assume that
12 it passes the three-hour test. That's one test.

13 How many more three-hour tests of a similar nature
14 must I perform to say that I really have passed it?

15 I only got a sample of one. Now the statisticians
16 and the PRA people go through all of this. I think we'd be
17 hard-pressed to say a sample of one is adequate for PRA
18 reliability purposes.

19 MR. McCracken: I do not disagree at all with your
20 statement. What you have to do is you have to look at the
21 entire body of tests that have been conducted, not just any
22 one test.

23 The entire body of tests as of now is around 50
24 tests have been conducted, say, on thermo-lag.

25 MR. MICHELSON: Of similar geometry, and so forth?

1 MR. McCracken: Yes, over the last --

2 MR. MICHELSON: The same similar geometry, and so
3 forth?

4 MR. McCracken: over various geometries, but the
5 intent was to get all the geometries you could get.

6 MR. MICHELSON: But you don't have 50 of a given
7 geometry. You have got 50 of a --

8 MR. McCracken: Oh, no.

9 MR. MICHELSON: -- variety. Maybe, only one of a
10 given geometry --

11 MR. McCracken: Right.

12 MR. MICHELSON: -- depending on what --

13 MR. McCracken: I believe there are sufficient to
14 draw conclusions from most configurations. However, there
15 are still some configurations that we know have not been
16 tested.

17 You were talking about some of them yesterday.
18 Some of the wall enclosures.

19 MR. MICHELSON: Even, say, good statisticians
20 might question 50 as an adequate sample of this kind of a
21 problem with that kind of diverse --

22 MR. McCracken: We're not trying to do it
23 statistically. I mean, obviously, you can't.

24 MR. MICHELSON: No. No way.

25 MR. McCracken: If you're trying to do it

1 statistically, you never get done.

2 MR. MICHELSON: If you're going to do a
3 performance base, you've got to go back to PRA and
4 statistical, and all the other things. And you're going to
5 do that --

6 MR. DAVIS: They're not recommending the
7 performance-based option.

8 MR. MICHELSON: No, no. I say option 4. Their
9 option 3 is getting to performance base, as will the rule be
10 a performance-based option 4.

11 And if you go to option 4, all of these questions
12 have got to be raised. They're a lot of issues that -- no
13 matter which way we go, there are a lot of issues to
14 resolve.

15 MR. WEST: Is Alex going to come up?

16 MR. CATTON: Yes, but I think, Mr. Chairman, could
17 we have a 12-minute break?

18 MR. KRESS: Let's see. We have a presentation by
19 NEI? And we're scheduled for a break at this point right
20 now.

21 Why don't we go ahead and have the 12-minute
22 break, and come back here at 11 o'clock.

23 MR. CATTON: Good.

24 [Recess.]

25 MR. LINDBLAD: Let's get started again. Ivan,

1 would you introduce the next topic?

2 MR. DAVIS: I just want to remind members that
3 they have in front of them a trip report that I prepared
4 from the Manchester meeting on thermal reactor safety.
5 That's all I wanted to say.

6 MR. LINDBLAD: Okay. Thank you.

7 Ivan.

8 MR. CATTON: Alex.

9 [Slide.]

10 MR. MARION: Good morning. My name is Alex
11 Marion. I am a manager in the Technical Regulatory Division
12 of the Nuclear Energy Institute.

13 The material that is being passed out to you is
14 essentially the same as was presented to the subcommittee
15 yesterday. I don't intend to go through every slide, but
16 the information is there for your use and understanding.

17 If you have any questions, please feel free to
18 ask. But I will blow through this material quickly to get
19 to the resolution strategy that we have developed.

20 I think it is important to stress the fundamental
21 objective of the test program the industry had undertaken
22 originally through NUMARC and continues to pursue through
23 NEI.

24 With the NRC declaring Thermo-Lag test reports
25 indeterminate, utilities cannot essentially take credit for

1 those reports to demonstrate a one- or a three-hour fire
2 rating to comply with the regulation. So, consequently, we
3 had to reestablish the performance capability of the
4 material in a fire environment and we used the ASTM E119
5 curve that was discussed this morning.

6 From the standpoint of plant safety, with the
7 utilities implementing compensatory actions in the form of
8 fire watches or enhanced detection that are acceptable to
9 the NRC. That essentially addresses any potential safety
10 concern.

11 [Slide.]

12 MR. MARION: I am going to skip on to slide number
13 6, which essentially touches on the results of our Phase I
14 testing. We had two phases in our program. Phase I
15 essentially tried to demonstrate acceptable performance
16 using designs developed by the manufacturer of the Thermo-
17 Lag material. And the results are summarized in slides 2
18 through 5.

19 Essentially, the bottom line results from that
20 phase of the test program was that a reasonably good
21 understanding of what contributed to the failures or from
22 the standpoint of the construction attributes of the test
23 assemblies. But you need to keep in mind that when we refer
24 to a base line configuration, that base line is established
25 on -- as a result of a survey we had undertaken of utility

1 installation techniques. And we essentially captured the
2 worst case installation technique in our test program to be
3 conservative in that regard.

4 So we effectively minimal material thicknesses as
5 well as some of these other construction attributes, which
6 are identified in that package of material.

7 The lessons learned from the exercise we
8 integrated into the Phase II testing program that I am going
9 to get into a little more detail on in a few seconds.

10 [Slide.]

11 MR. MARION: Going on to slide 7, this captures
12 the results of the one-hour nonupgraded or base line fire
13 barriers, if you will. And you can see clearly a number of
14 these installations exceeded 20 minutes. Many of them in
15 the range of 39, 48 and 50 minutes and even an hour for
16 boxed conduits. This is the worst case installation base
17 line.

18 [Slide.]

19 MR. MARION: For a three-hour base line, this is
20 the -- this slide which is number 8 represents the duration
21 in terms of thermal performance and you can see clearly
22 exceed the one-hour from 63 minutes on to 102 minutes in
23 some cases.

24 MR. CARROLL: What happened at 63 minutes?

25 MR. MARION: The temperature --

1 MR. CARROLL: The thermocouples had the --

2 MR. MARION: Yes, the single point temperature
3 reading.

4 MR. CARROLL: Had reached what?

5 MR. MARION: The 325 degrees plus ambient.

6 Whatever it was specifically for that test, I don't know off
7 the top of my head.

8 MR. DAVIS: At the cable surface?

9 MR. MARION: I would have to check the test report
10 to specify which thermocouple was.

11 But the reports have been developed and sent --
12 forwarded to the NRC as well as to industry.

13 And I might want to add during our discussion
14 yesterday, there was a request for a couple reports of ours.
15 There were some questions raised relative to the
16 combustibility testing and the results of that testing on
17 the Thermo-Lag material. And I have provided to Doug Coe a
18 copy of that combustibility report with an addenda as well
19 as representative a test report on a 36-inch aluminum tray
20 as well as a test report on a range of conduit sizes.

21 [Slide.]

22 MR. MARION: Other results of Phase II, one-hour
23 configurations that were upgraded. We were able to
24 demonstrate acceptable performance for these types of
25 assemblies, essentially building on what Steve West

1 indicated this morning by the addition of stress skin and
2 trowel-grade material on the joints because it was clear
3 that failures at the joints were extremely significant. But
4 the simple addition of stress skin with trowel grade appears
5 to be a reasonable fix for that sensitive area.

6 MR. CARROLL: So in general, Alex, when a 3/4-inch
7 conduit failed, at 63 minutes reached this magic
8 temperature, you could correlate that with a joint failure?

9 MR. MARION: No. With a conduit, the
10 thermocouples are inside the conduit and the application of
11 Thermo-Lag around the conduit is with two C-sections or
12 half-round sections. Where this material is preformed into
13 a C.

14 MR. CARROLL: All right.

15 MR. MARION: Was that a baseline? I don't recall.

16 MR. CARROLL: Yes, it was a baseline. I was just
17 picking an example but yes, it was a baseline.

18 MR. MARION: But I encourage you to look at the
19 test report that we have because for the conduit assemblies
20 that are in that one that goes through all that particular
21 detail.

22 MR. CARROLL: Well, how about a cable tray then?
23 Was in general the thermocouple location, was it --

24 MR. MARION: Let me -- I'm trying to go through
25 this quickly and there were things I mentioned yesterday

1 that I am trying to blow through today for the sake of time,
2 but let me touch on it.

3 Last time we spoke before this committee was in
4 December and one of the points of contention between
5 industry and the Staff was the location of the thermocouple
6 underneath the cable tray rungs.

7 We agreed to install the thermocouple right below
8 the cable tray rungs for the purposes of developing
9 engineering data, just to ascertain whether or not it makes
10 sense to make your go/no go decision relative to pass-
11 failure criteria of the assembly on the bottom thermocouple
12 or other thermocouples.

13 For our test assemblies we found in Phase 2 that
14 absent a structural failure or an opening underneath the
15 cable tray to recognize the fire source in the oven is
16 coming in from the bottom and again it is recognized the
17 joints and the way you protect the joints is very critical
18 and if you develop an opening during the course of the tests
19 then that bottom thermocouple will pick up that opening
20 immediately.

21 On the order of six to eight minutes afterwards,
22 based upon our data, the side rail temperatures, the
23 thermocouples on the side rails of the cable tray, will pick
24 that up. As long as the structural integrity at the bottom
25 is maintained, the side rail thermocouples dominated the

1 thermal performance.

2 MR. CARROLL: No, no. That wasn't what I was
3 getting at.

4 MR. MARION: Oh, okay. I'm sorry.

5 MR. CARROLL: What I am really getting at was in
6 general is the fact that you reach an early magic
7 temperature limit the result of a structural failure?

8 MR. MARION: It's a combination. In some of the
9 installations where you have a broad tray span, you get the
10 material under its own weight is going to sag and stress the
11 joints because this material on the fire exposure is going
12 through a changing state.

13 MR. CARROLL: And is that where the --

14 MR. MARION: Yes, for large installations. Now if
15 you can reinforce that joint, you can have a successful test
16 but not in all cases were they structural failures.

17 MR. CARROLL: All right, thank you.

18 MR. MARION: All right, now this --

19 [Slide.]

20 MR. MARION: -- this Slide Number 10 lists some of
21 the key construction attributes that we have learned quite a
22 bit about and have been able to develop configurations that
23 will effectively survive the one-hour rating, et cetera, but
24 just keep in mind that our baselines are the most
25 conservative case.

1 All of these attributes are adequately addressed
2 to a level of detail in the application guide. Now the
3 application guide is a key document relative to capturing
4 the essence of the test program results and communicating
5 that to the utilities so that the utilities can begin to do
6 their assessment of the test program results to their
7 installations and conclude whether or not they are bounded
8 and if they are not bounded, exercise some other options and
9 I will get into that in a little more detail later on.

10 [Slide.]

11 MR. MARION: The next couple of slides just
12 basically capture the content and the schedule of activity
13 relative to the application guide, but let me just take a
14 moment and indicate that the application guide will include
15 all the testing that has been conducted under our program as
16 well as the testing of TU and TVA and other utilities as
17 well, should utilities decide to progress with that testing.

18 MR. SHACK: Question -- on the one-hour barriers
19 which everybody seems to agree that you can upgrade if you
20 find the joints, you mentioned yesterday that sometimes it
21 wasn't too easy to find the joints. Do you have any idea of
22 what fraction of the time it will be possible to identify
23 the joint and what fraction of the time it's going to be
24 impossible?

25 MR. MARION: No. I don't have that information

1 and the position that we are taking with the utilities is if
2 through a sampling process at a minimum you cannot establish
3 definitively what your baseline configuration is, then
4 assume the worst case, okay?

5 In other words, if you can't demonstrate what you
6 did to the joints, then put on some stress skin and trowel
7 grade material. Go conservative.

8 That is what basically the position that we are
9 taking --

10 MR. CARROLL: Is anybody looking at nondestructive
11 techniques to find the joints?

12 MR. MARION: There are no nondestructive
13 techniques that we are aware of to assess the joints or any
14 configurational aspects of this material.

15 You will recall from that picture yesterday, and I
16 think I have an overhead here that captures it, that this
17 material --

18 MR. CARROLL: If there is a discontinuity at the
19 joint it would seem to me ultrasonics might --

20 [Slide.]

21 MR. MARION: Yes, that's basically what it looks
22 like and you have to recognize that in utility installations
23 at these corners and joints and even in the panel sections
24 going horizontally here in this graphic, the utilities apply
25 trowel grade material and if they don't have some kind of

1 construction detail that indicates there was stress skin or
2 they pre-buttered the joint or what have you, they have no
3 way of knowing.

4 What we are suggesting is you may want to do a
5 sample if you don't know. Just open up some of these and
6 see what is there and draw your own conclusion and absent
7 that, go worst case.

8 MR. MICHELSON: Didn't the procedures generally
9 call for field installation though?

10 MR. MARION: They vary. They vary. In some
11 cases --

12 MR. MICHELSON: I'm surprised there was an
13 engineering drawing of exactly where to put the joint and so
14 forth on something like this.

15 MR. MARION: In some cases utilities know exactly
16 what they did and in other cases they just had a general
17 installation diagram that was used to cross the spectrum of
18 installations.

19 [Slide.]

20 MR. MARION: Let me just indicate very briefly
21 that in December of last year we formed a working group to
22 address some of the policy level questions that were before
23 us in terms of the extent of coverage across the industry
24 for all installations or some percentage that is reasonably
25 close, and how much value you are going to get by expanding

1 the program to pick up another two or three utilities, et
2 cetera.

3 We felt that we needed some executive level
4 leadership and guidance, so we formed a working group in
5 December chaired by Bill Cavanagh, Carolina Power and Light.
6 Co-chair persons are Don Hince from Entergy and Oliver
7 Kingsley from TVA.

8 The fundamental objective of the working group is
9 to help us with the resolution, short-term and long-term, of
10 three issues, if you will, all within the umbrella of fire
11 protection, the first being Thermo-Lag. The second being
12 similar concerns with other manufacturers and materials.
13 That's the point I couldn't recall yesterday. Lastly is the
14 petition for rulemaking effort in terms of the more broader
15 improvement in the entire fire protection arena.

16 Now, that working group has reviewed this
17 flowchart from the conceptual point of view and trying to
18 rationalize what are the decision-making elements that one
19 would proceed as they go through evaluating the need for
20 fire barriers. This can be applied to, more obviously,
21 directly to Thermo-Lag installation, but also installations
22 of fire barrier systems of other manufacturers.

23 Now, briefly, this broad bold darkened arrow
24 represents entry points into the process here, and there are
25 multiple entry points for here and there is one here.

1 Utility can conclude that the barriers that they
2 identified in their Appendix R program that have been
3 reviewed by the NRC, et cetera -- their fire protection
4 program, I should say -- that they are not going to go back
5 and revisit the basis for installing that barrier.

6 So they would come into, yes, a barrier is
7 required at this particular point. One option is to reroute
8 the safe shutdown circuits. If they don't want to mess with
9 or apply resources to evaluate the application guide and run
10 through the rest of the process, they can get kicked out at
11 this particular point.

12 Now, this flowchart represents a number of
13 activities that are being pursued by utilities. For
14 example, the FP&L approach that you heard about this morning
15 and yesterday is basically picking up on a combination of
16 these elements right here.

17 Quite frankly, this represents in our thinking a
18 combination of Options 1 and 3. The output of this could be
19 adequately demonstrated to support Option 2 in terms of
20 modeling techniques of the actual hazard, et cetera, as well
21 as supporting Option 4.

22 MR. MICHELSON: You heard our discussion this
23 morning about the kind of tool required to do this kind of
24 performance-based examination. Do you think you will have
25 available in a timely fashion the tools it takes to do all

1 of this?

2 MR. WEST: Yes.

3 MR. MICHELSON: You are working on the tools now?

4 MR. WEST: Well, for example, the tools that are
5 currently available for modeling techniques, there is an FPA
6 methodology, there is COMBURN and FIVE.

7 MR. MICHELSON: Are you proposing to change the
8 time temperature curve of E119?

9 MR. MARION: If Option 2 is recommended by the
10 Commission I think we will seriously consider industry
11 taking the lead on doing that.

12 MR. MICHELSON: But for this methodology you are
13 trying to demonstrate, are you trying to come up with new
14 time temperature curves?

15 MR. MARION: Yes, this would support it.

16 MR. MICHELSON: You are working on that right now?

17 MR. MARION: No. We are waiting for the
18 Commission guidance to come out clearly on Option 2.

19 MR. MICHELSON: You think you can clearly come up
20 with what you need?

21 MR. MARION: If it does -- yes, I personally
22 believe that we will take the lead.

23 MR. MICHELSON: And in terms of the PRA tools, the
24 statistical tools, and all the other things it takes to do
25 this?

1 MR. MARION: And a PRA -- you brought up an
2 excellent point earlier in the discussion about failure
3 rates, which is clearly the purity that you want to achieve
4 --

5 MR. MICHELSON: Got to get it.

6 MR. MARION: -- but as I understand it with PRA
7 space today, the utilities, in their analyses, want to
8 achieve a mission that takes credit for some of these safe
9 shutdown capabilities and circuitry. They assume that the
10 barrier is functional. They assume that's an adequate
11 barrier.

12 Now, they can go back to the model and now
13 conclude that the barrier is not there, so that circuit is
14 compromised: what alternate path or capabilities do they
15 have. That's the extent of that analytical tool right now.

16 MR. MICHELSON: So you would use a failure rate of
17 1 --

18 MR. MARION: Yes.

19 MR. MICHELSON: -- at a certain point in the
20 analysis, and if you show you are still okay, fine. I mean,
21 that's a good way to do it. If you aren't, it is kind of
22 hard to decide where you are at.

23 MR. MARION: Absolutely. Absolutely. Anyway,
24 through a combination of these efforts, some utilities are
25 revisiting their fundamental Appendix R basis in terms of

1 their safe shutdown analysis and fire hazards analysis.

2 These are new techniques that have been developed
3 since the rule was promulgated, but they are techniques that
4 can be used nonetheless, and it feeds into this decision
5 element relative to whether or not you need that fire
6 barrier.

7 There are some other considerations which we refer
8 to as "soft," if you will, for areas and specific barriers
9 within areas.

10 For example, you don't need a sophisticated
11 analysis to tell you that if you have Thermo-Lag fire
12 barriers in your cable spreading room, that's important.
13 You have to deal with it. You don't need a model, you don't
14 need a PRA to tell you that. I mean, that should be clear.
15 So these*types of considerations would come into this
16 particular block.

17 Now, the application guide fits in at this
18 particular point, and the position that we are taking with
19 the industry is that the utilities are going to have to
20 conduct this evaluation, and they are going to have to apply
21 resources. Our goal and objective is to make that
22 application guide as useful and friendly from a user point
23 of view as we possibly can so that the utilities can
24 evaluate it technically and draw a conclusion relative to
25 whether or not the test results apply to their particular

1 installations or not.

2 If they don't apply, they can go back and sharpen
3 the pencil. We have already identified a couple of
4 instances in our generic program that require additional
5 testing. As we mentioned yesterday, there are two areas.
6 One is a group of five or six utilities that have Thermo-
7 Lag and wall applications, and we are coordinating that
8 testing program.

9 On a more generic level, there is a group that
10 comes under what we refer to as boxed applications that
11 represents, I believe, on the order of 22 utilities. The
12 working group has recommended that we consider what we can
13 do for that.

14 From the standpoint of the other elements here, we
15 are looking at the various blocks and trying to reach a
16 consensus on what additional guidance may be necessary for
17 utilities.

18 But before I elaborate on that further, this
19 represents the resolution alternatives. Let me just go
20 through this briefly. If you are enveloped by the test
21 program in terms of your evaluation of our results, and your
22 conclusion that it indeed is representative of your
23 installation, then you can conclude that the install
24 configuration is acceptable for the one or three-hour basis.

25 If your fire hazard is relatively low, as we

1 mentioned this morning, 20 minutes, then -- you see in that
2 slide that we had earlier that if it is one of the
3 installations, let's say, where we attempted to achieve a
4 one-hour success on baseline and it came up 40 minutes, for
5 example, that gives you a two to one ratio relative to the
6 hazard.

7 The record as we understand it from what utilities
8 has been telling us -- and this is something we need to
9 follow up with the NRC on when they evaluate the exemptions
10 -- but the record indicates that if you got a two or one
11 margin, that may or may not be acceptable and that is one of
12 the things we want to clear up.

13 MR. CARROLL: I thought Conrad made that clear
14 this morning.

15 MR. MARION: That's what I just said, I think we
16 need to clear that up and have some further discussion on it
17 because one of the things that has happened in our working
18 group, one of the action items that we have is to consider a
19 framework for exemption activities because what we need to
20 realize is that the rule allows for exemptions, and we
21 cannot discount that element. That is one of the areas we
22 are going to entertain further discussion with the NRC
23 Staff.

24 Another element is enhanced defense and depth
25 measures. For example, if you have a three-hour barrier

1 installation -- and we already know that we don't have any
2 data that shows that a three-hour Thermo-Lag installation
3 will meet that rating, but our reports indicate that
4 performances are in excess of an hour. So utility can, in
5 effect, change the rating, if you will, to one hour and the
6 rule allows detection and suppression.

7 And as we understand it from the discussion
8 yesterday, Conrad McCracken identified some considerations
9 relative to defense and depth and we intend to capture these
10 as well.

11 From the standpoint of an existing installation
12 and doing a modification, we prepared to try to work on that
13 but we not aware of any other manufacturer that has a
14 material that meets the three-hour rating based on the
15 current acceptance criteria.

16 There are a couple manufacturers who are
17 conducting tests right now.

18 In terms of the more vintage acceptance criteria
19 or the more vintage tests, I think you heard correctly from
20 Steve this morning that the Staff is evaluating some of
21 these and I don't know to what extent the utilities can take
22 credit for some of those older tests because we are going
23 back 10, 15 years in time in some cases.

24 MR. CARROLL: Now you are talking about tests of
25 other materials?

1 MR. MARION: Yes, that were done years ago.

2 For example, there are three materials that are
3 predominantly used. The greatest is Thermo-Lag. The second
4 runner is 3M material and the third is Promatec -- if I have
5 that -- Promatec or somebody like that. There were three
6 that are used throughout the industry.

7 All of them -- 3M has a wide spectrum of test
8 reports and they are reviewing those reports with their
9 customers to see if they have any misgivings or weaknesses
10 in their documentation path in trying to improve it.

11 MR. CARROLL: So it is at least conceivable that
12 the plants that do not have Thermo-Lag do have a problem
13 with three-hour barriers?

14 MR. MARION: There is a potential, yes. The
15 action that's been suggested by the NRC Staff in
16 communicating their concerns on Thermo-Lag, they have
17 also -- the Staff -- and please help me out if I misspeak,
18 they sent letters to the other manufacturers posing very
19 similar questions, et cetera, and received some responses
20 and that is part of the evaluation that is ongoing.

21 We have communicated to utilities that this may be
22 more than just a Thermo-Lag issue; look at your test reports
23 and make sure everything is in order because the NRC is
24 going to come in and ask and that is the position that we
25 have taken.

1 MR. CARROLL: What is the timeframe for getting
2 that issue resolved?

3 MR. MARION: Ah -- good question.

4 The second piece of the mission statement of the
5 working group is to develop a position on other
6 manufacturers' materials and we have a report and
7 recommendation in-house right now that evaluates the
8 performance of Thermo-Lag relative to performance of the
9 other materials and there are differences in terms of the
10 failure mechanisms, et cetera, and that recommendation will
11 be considered by the working group at the next meeting which
12 I am expecting we will have at the end of this month or
13 July.

14 We will have a position on that in terms of what
15 else we need to do.

16 We have advised the manufacturers as well as the
17 utilities to ensure to their satisfaction that the test
18 reports that they are talking credit for in regulatory space
19 can withstand today's scrutiny and these are reports that
20 were found to be acceptable 10, 12 years ago or whatever,
21 but people are going to come in and look at them today and
22 just make sure they are solid and you can establish a
23 reasonable basis for the adequacy of those materials.

24 3M is doing a lot of work in that regard.

25 MR. CARROLL: Is the protection principle of the

1 other two vendors different from Thermo-Lag? Thermo-Lag
2 relies on an ablation sort of technique.

3 MR. MARION: I don't know. I think the NRC can
4 probably answer that question best. It is different, yes.

5 MR. McCracken: Yes. Thermo-Lag is the only one
6 that is relying on the ablation technique. The others are
7 thermal barriers basically.

8 MR. CARROLL: Thank you.

9 MR. McCracken: I would like to make a statement,
10 though, based on what you said earlier.

11 The reason we feel comfortable in not going at a
12 faster pace on the other materials is we did run some small-
13 scale scoping tests at NIST that we talked a little bit
14 about yesterday. We have seen nothing that tells us that we
15 have a major problem with those barriers so far as the basic
16 barrier material, so we are focusing our resources first
17 where we know there is a problem, and then we will get down
18 to looking at the other barriers.

19 MR. MARION: Well, anyway, just to quickly
20 conclude, these are the key elements of a resolution
21 strategy to address fire barrier concerns.

22 We have gone through two iterations with our
23 working group. Second iteration some changes were suggested
24 for adding additional elements in configuring this a little
25 bit differently.

1 We have had discussions with NRC management on
2 this and we will continue to have discussions with them as
3 we finalize the strategy and this is what we will
4 communicate to utilities for the process thinking if you
5 will in evaluating the adequacy of their barriers.

6 That concludes my presentation and for those of
7 you who heard it yesterday, please bear with me for being so
8 expeditious but there are a couple points I would like to
9 make.

10 MR. CARROLL: Do you happen to have in your bag of
11 tricks a picture of one of those assemblies as it came out
12 of the furnace, just for the benefit of those that weren't
13 there?

14 MR. MARION: There were outstanding pictures in
15 the test reports but I do have a graphic that we have used
16 before and let me show that. I don't know how clear that is
17 going to be.

18 MR. CATTON: But they are not colored in the
19 report --

20 [Slide.]

21 MR. MARION: This is the one -- you remember that
22 one picture yesterday that showed the separation? All
23 right, this is from a cable tray. This is underneath the
24 tray and here is the separation and in that photograph you
25 could see the cable in this general area.

1 MR. CARROLL: Icicles hanging down --

2 MR. CATTON: This is the slathering you were
3 talking about.

4 MR. CARROLL: Those icicles hanging down are
5 melted fiberglass.

6 MR. MARION: Yes, for those of you -- and possibly
7 some water, too -- for those of you who are Alien fans, that
8 may look familiar if you orient it the other way -- from the
9 movies?

10 But in the test reports there are very good
11 photographs that have been reproduced and I urge you to look
12 at those.

13 MR. MICHELSON: Now this stress skin was carbon
14 steel. What happened to the stress skin on the outside?

15 MR. MARION: On that one this was a baseline test
16 if I am not mistaken.

17 MR. MICHELSON: It was not stress skin on it?

18 MR. MARION: Right.

19 MR. MICHELSON: What happens when you do have a
20 stress skin on the outside?

21 MR. MARION: That doesn't occur.

22 MR. MICHELSON: No, but what happens to the stress
23 skin? Is it all intact? Is that what you are saying?

24 MR. MARION: Oh -- if it was on this one and it
25 separated?

1 MR. MICHELSON: No, no -- a typical, time and
2 temperature curve exposure. Is it still there at the end of
3 the test?

4 MR. WEST: Steven West. It is still there but it
5 is significantly -- remember, the stress skin is on the
6 outside of the three-hour barrier and at the end of three
7 hours they are significantly degraded.

8 It can come apart through the development of the
9 char layer, which would put stresses on it and it weakens in
10 the heat and it can come apart, but it pretty much still
11 maintains the shape of the barrier.

12 MR. MICHELSON: It gives you some indication of
13 temperatures in that region because of the material you
14 have -- carbon steel, I think you said.

15 MR. WEST: Well, the temperature there is going to
16 be the temperature of the furnace. That is going to be at
17 the three-hour test almost 2000 degrees.

18 MR. MICHELSON: I just wanted to make sure what it
19 was.

20 MR. CATTON: What is the sublimation temperature
21 of the material?

22 MR. MARION: It is in that report.

23 MR. DAVIS: I thought it was 600 degrees C from
24 yesterday.

25 MR. MARION: Somewhere, 500 -- 600 degrees F.

1 [Slide.]

2 MR. MARION: This is a representation of some of
3 the thermocouples. What we did on Phase II is we maintained
4 these two thermocouples, bare copper conductor coming at you
5 this way. And every six inches you have a thermocouple. On
6 top of the cable, underneath the cable, we also added that
7 bottom thermocouple underneath the tray rung. And there was
8 also a thermocouple located on the side rail here and here.
9 And as I indicated earlier, this is where the leading
10 thermal indicator occurred absent a breach at the bottom.
11 If you had a breach at the bottom, of course, the bottom
12 thermocouple would kick in.

13 Just quickly, a point of clarification on the NIST
14 tests. As Conrad just indicated a few minutes ago, there
15 were small-scale investigatory tests of other manufactured
16 materials but there was also a full scale test of Thermo-
17 Lag in trying to replicate some of their vintage test
18 reports. I just wanted to clear that up, because they are
19 kind of apples and oranges.

20 Also, the only other point I want to make is we
21 are going to submit the petition for rulemaking. One of the
22 questions that we will consider is the overall benefit given
23 the institutional nature of the fire protection programs at
24 utilities, but we are going to submit that rulemaking. And
25 as that SECY indicated, the approach is to allow utilities

1 to voluntarily commit, if you will, to the new rule of
2 whatever form that's going to take.

3 So that option will exist to stay with the status
4 quo in terms of the regulations if you're comfortable with
5 it, or move on to a new regulation.

6 MR. CATTON: Yesterday, you were a little bit
7 indecisive when we asked the question about the rule.
8 Today, you are positive.

9 MR. MARION: I was focusing on the concern about
10 the benefit to be had by --

11 MR. CATTON: That was a separate question.

12 MR. MARION: That's what I was reacting to.

13 MR. CATTON: But you will -- you are going to go
14 forward?

15 MR. MARION: I have two people working on it right
16 now.

17 MR. DAVIS: What is your schedule for submittal?

18 MR. MARION: September.

19 MR. CARROLL: You are going to submit the rule.
20 Good. There is no possibility that when your working group
21 looks at the implications of having such a rule in terms of
22 what's needed to support it that they may not find it meets
23 the benefit cost?

24 MR. MARION: Let me just take a second. We used
25 an ad hoc advisory committee in the fall of last year to

1 develop the general framework of the structure of the new
2 rule. And that's what we have been working with and
3 building upon. We had some discussions with RES staff on it
4 as well.

5 We had provided a copy of that to our working
6 group and had there been any serious concerns, they would
7 have been identified by now. But, as we finalize the
8 package before we submit it, we will review it thoroughly
9 with the working group and I don't have a sense that they
10 will suggest that we not submit it.

11 MR. CATTON: And shutdown fire is not included in
12 it?

13 MR. MARION: At this particular time, we are not
14 including it because --

15 MR. CARROLL: But it will be when you submit it?

16 MR. MARION: Let me just explain.

17 MR. CATTON: It may be when we get through with
18 it.

19 MR. MARION: It's our understanding -- it was our
20 understanding that the NRC was pursuing a separate
21 rulemaking. And that, of course, complicates the situation.
22 But up until these recent discussions on shutdown, we
23 haven't -- we were not addressing it and will seriously
24 consider it at this point.

25 MR. CARROLL: Have you talked to Tony about all of

1 this?

2 MR. MARION: Yes, Tony's -- Tony used to work for
3 me. Yes. I have. I talked to him this morning, as a
4 matter of fact.

5 MR. CARROLL: I guess I would say that the
6 rulemaking, in the words of our departed colleague, David
7 Ward, sounds good when you say it fast. It may not be as
8 good when you try to carry it out.

9 MR. MARION: Based on what we've done, without
10 getting into a whole lot of specifics, there is a lot of
11 benefit and areas for improvement from the current
12 regulation because a lot of resources are being applied on
13 the technological aspects of fire protection as it existed
14 when the rule was promulgated and technologies have
15 advanced. So as a very minimum, if we can bring that
16 regulation up to current approaches, I think that will give
17 a tremendous benefit to everyone, not only the regulators
18 but the utilities as well.

19 MR. CATTON: It should make the whole process more
20 scrutable, too, and I think that is worth something, at
21 least to me.

22 [Laughter.]

23 MR. CATTON: Thank you, Alex. I would like to
24 thank the Staff also for their participation and I turn the
25 meeting back to the Chair.

1 MR. KRESS: At this point then, I propose to do a
2 first reading. So we can close the meeting -- close the
3 record, I mean. We don't require the reporter for this.

4 [Whereupon, at 11:40 a.m. the hearing was
5 recessed, to reconvene at 1:00 p.m. this same day.]
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 AFTERNOON SESSION

2 [1:03 p.m.]

3 MR. KRESS: We are now moving to the part of our
4 agenda which is after lunch, and it is the proposed
5 revisions to the license renewal rule. The subcommittee
6 chairman is William Lindblad. I will turn it over to you.

7 MR. LINDBLAD: Thank you.

8 I am quickly going to look back and see if we have
9 staff support for this.

10 MR. CARROLL: We do.

11 MR. LINDBLAD: Good. As we segue into -- this is
12 Tab 4 on your binder reference material, and it deals with
13 the license renewal rule which is Part 54 of the agency's
14 regulations, and you will recall that we had meetings on
15 this about a year ago, and part of the meetings reflected on
16 the new vocabulary that came out of the rule, and new
17 programmatic considerations.

18 You will recall that former Commissioner Curtiss,
19 or at the time Commissioner Curtiss, wrote a letter about
20 some of his views just before leaving the Commission which
21 seemed to reflect some of the committee members ideas as
22 well.

23 The staff has undertaken to look at all these
24 thoughts and considerations and is now preparing to invite
25 public comment on some revised views of this, and Mr.

1 Newberry is going to present this.

2 Mr. Travers, are you going to make the
3 presentation?

4 MR. TRAVERS: Yes.

5 MR. LINDBLAD: Thank you.

6 [Slide.]

7 MR. TRAVERS: Good afternoon. My name is Bill
8 Travers of the staff. As Mr. Lindblad said, what we have
9 recently done in the license renewal area is to submit to
10 the Commission several proposed revisions to the existing
11 Part 54 rule in SECY 94-140.

12 I have given you a set of handouts. Basically we
13 want to cover what is on this table of contents, and I am
14 going to cover through principal changes, and then Steve
15 Reynolds is going to talk to you in a little bit more detail
16 about how the integrated plan assessment under the proposed
17 revisions would work. Also discuss any time limit and aging
18 analyses, and the standards for issuance of a renewed
19 license, and lastly I give you a feel for the schedule that
20 we are on for completing these proposals to the Commission.

21 [Slide.]

22 MR. TRAVERS: By way of background, we have had a
23 chance to brief the committee in the past. Most recently, I
24 think it is last January we were down here after having had
25 a public workshop and after having provided the Commission

1 with staff views and recommendations that we thought
2 proposed revisions to the rule were warranted given some of
3 the interactions we have had with industry and some
4 difficulties they perceived in connection with the existing
5 rule.

6 In February of this year, the Commission agreed
7 with our recommendations ostensibly and directed the staff
8 to go forward and develop a proposed rule. So we have had
9 about four months to do this. It has been a very tight
10 schedule. We have based what we have done in this package
11 on Commission directives, on our recommendations, and we
12 have had to institute a fairly unique process in getting it
13 done in four months. We have utilized a team effort made up
14 of senior staff people from the Office of Nuclear Reactor
15 Regulation, from the Office of General Counsel, and from the
16 Office of Research in connection with the line management
17 and NRR and, lastly, directed by a group of senior managers
18 who we had opportunities every week or two weeks to go
19 before and present issues.

20 The principal reason for this was to get them
21 resolved quickly. We didn't have the time and luxury to
22 take months or even multiple weeks to resolve key issues.

23 This senior steering group was headed by Bill
24 Russell, Director of NRR, and included Jim Milhoan as a
25 Deputy Executive Director for Operations, Jack Heltemes from

1 the Office of Research, and Marty Malsch as the Deputy
2 General Counsel.

3 I think it worked well, frankly. We succeeded in
4 meeting a very tight schedule, and we are going to be
5 briefing the Commission tomorrow.

6 MR. SEALE: Mr. Travers, could I ask a somewhat
7 related question?

8 MR. TRAVERS: Yes.

9 MR. SEALE: A little later on we are going to talk
10 about a letter having to do with the proposed modification
11 in the rulemaking process that talks about the use of this
12 senior steering group approach. Is that what you have tried
13 to embody here?

14 MR. TRAVERS: I haven't seen that, so I can't
15 comment on it, but I have heard some discuss the approach we
16 took in connection with this effort. I, myself, am not
17 familiar with it.

18 MR. SEALE: Have you found that to be very
19 helpful?

20 MR. TRAVERS: Certainly, in my view is, in this
21 case it worked very well. A key to the success was our
22 ability to resolve issues among Research, NRR, OCG, by
23 having senior managers committed to the effort and our
24 access to them was fairly frequent.

25 In other words, we drove a schedule for meeting

1 with them depending on whether or not we had issues and when
2 we had them. So it worked very well.

3 MR. SEALE: Thank you.

4 [Slide.]

5 MR. TRAVERS: Our general objectives in talking
6 revisions to the license renewal rule are stated here. I
7 won't go over them, but basically after having gotten a
8 direction from the Commission to make certain changes, we
9 looked to see if we couldn't optimize in the sense of making
10 the rule more clear and simple and providing flexibility in
11 it, certainly greater flexibility, and we think we have
12 achieved that.

13 The bottom line to all this is, we think that what
14 we will have by virtue of the first three objectives being
15 met, or if they are met, is a more stable and predictable
16 process under which the industry can judge whether or not
17 and what circumstances would drive their application for
18 renewal.

19 [Slide.]

20 MR. TRAVERS: We have made a lot of changes to the
21 rule, but what I would like to touch on first is areas where
22 we think the rule has not changed, and our view is that
23 although we have made a lot of changes that certainly the
24 fundamental and underlying regulatory principles, as they
25 are delineated in the existing two principles of license

1 renewal have not be changed.

2 Most importantly, we think that the first
3 principle which essentially states that aging, aging in the
4 extended period of operation, was the issue in Part 54. We
5 believe that is still the issue, the exclusive issue for the
6 proposed revisions that we have submitted to the Commission.

7 Except for the possible detrimental effects of
8 aging in the extended period of operation, we believe that
9 the regulatory process continues to ensure that a plant-
10 specific licensing basis will continue to provide an
11 adequate measure of safety for a plant.

12 So this was the fundamental principle that the
13 existing rule was founded on, and we think we have retained
14 that concept. As a result, we think the license renewal
15 process needs to be and must be focused on ensuring that the
16 effects of aging will be managed for plant equipment which
17 may not be adequately addressed by current programs and
18 activities for the extended period of operation.

19 Maintaining the current licensing basis in the
20 face of aging effects is really what we are going to be
21 tackling in license renewal. And it is the second principal
22 license renewal, and it's retained again in this revision.

23 MR. LINDBLAD: I'm not so sure I understand what
24 that statement means and why it becomes a principle.

25 Is that a new principle are you saying?

1 MR. TRAVERS: It is not, no. We think -- well, it
2 is. These two principles are the principles that were the
3 underlying regulatory foundation for the way that part 54
4 rule is crafted.

5 In other words, the Commission, in promulgating
6 that rule, established aging, aging unique to the period of
7 extended operation, as the issue that needed to be evaluated
8 in connection with the renewal review application, staff
9 review, hearing and the findings the Commission would make.

10 All other issues, issues that are normally
11 addressed when we initially license a plant -- whether it be
12 emergency planning, operating license, what-have-you, design
13 of the plant -- would have been addressed at the time the
14 plant was initially licensed.

15 And that the continuing regulatory process, which
16 is dynamic to CLB's continuing as a living and evolving
17 thing through 40 years of operation will continue to
18 maintain an adequate measure of safety.

19 So the Commission used this argument in
20 establishing an exclusive focus on managing aging in the
21 extended period of operation.

22 This exclusive focus on the effects of aging only
23 in the extended period of operation was the conceptual basis
24 for the existing -- the current rule's use of the term "age-
25 related degradation in license renewal."

1 And that term has been deleted in our revised
2 rule.

3 ARDUTLR, which is the acronym for age-related
4 degradation -- license renewal, was intended in part 54 to
5 focus the review -- focus it on aging, unique aging in the
6 period of extended operation.

7 And what we found through some experience of
8 course was that it didn't work very well. In fact, this
9 term, as it was used in the rule when we went to implement
10 it in some of our work with some of the industry groups,
11 created a great deal of confusion.

12 And as a result, in addition to approving the
13 staff recommendations that were contained in Secy 93-311 --
14 I'm sorry -- 331 -- the Commission directed that this term,
15 ARDUTLR, be eliminated from the rule.

16 And we've done that. We've made a number of other
17 conforming changes along with it. And we think that we've
18 done it in a way that removes the confusion that has
19 surrounded the use of this term in the rule.

20 The next slide lists some additional things that
21 have been retained in our revisions, some of the provisions
22 that are currently applicable in the current part 54 rule.

23 And, fundamentally, the rule is centered around
24 the conduct of an integrated plant assessment. We've talked
25 about that in briefings of the Committee before.

1 It's really the heart of the rule. The rule
2 remains a process rule rather than one that specifies
3 technical criteria within it. It requires in the context of
4 carrying out an integrated plant assessment a rather broad,
5 at least a beginning broad, evaluation of plant equipment.

6 But, it provides mechanisms which quickly focus.
7 And we think, as a result of these revisions, even more
8 quickly focuses the review to a very select set of equipment
9 for which we think the renewal review should focus.

10 The initial scope of the renewal review is
11 essentially identical to part 54. It includes safety-
12 related equipment, equipment whose failure could affect the
13 function of safety-related equipment, equipment required for
14 compliance with certain regulations, such as fire
15 protection, EQ, PTS, ATWS -- station blackout, and equipment
16 subject to technical specification limiting conditions for
17 operation.

18 So the same scope of equipment that would have
19 been the initial starting point for the conduct of the
20 integrated plant assessment is retained in this revision.

21 Additionally, the revision includes and requires a
22 review of certain time-limited aging analyses. In addition
23 to the integrated plant assessment, the revision requires
24 that where time-limited aging analyses were relied on for
25 safety conclusions by the licensees, particularly time-

1 limited aging analyses that were bounded by 40 years -- the
2 current operating term -- that these be revisited,
3 reevaluated and rejustified for the additional period of the
4 requested extension.

5 Together with the results of the environmental
6 review under part 51, the basis for the issuance of license
7 would continue under this revision and be focused on both
8 the results of the integrated plant assessments and the
9 results of the conduct of the review of the time-limited
10 aging analyses.

11 [Slide.]

12 So those are the principal elements of the current
13 rule that have been retained by virtue of what we've done in
14 preparing this revision.

15 I'd like to touch now on the principal changes
16 that we've made. The first change is an important one. I
17 had a chance to discuss it with the Committee the last time
18 I was here. And it's meant to clarify and to correct some
19 inconsistent language that exists today in the statement of
20 considerations, which emphasizes the review based on a
21 mechanistic approach.

22 That is, the identification of specific aging
23 mechanisms versus an approach for review that would focus on
24 aging effects, and the assurance of performance or condition
25 of important plant equipment is retained in the extended

1 period of operation.

2 So what we've done in this revision is to clarify
3 and emphasize that performance and condition monitoring, the
4 kind of programs that are actively in place for most plants
5 today, would be an acceptable basis for determining that the
6 function of equipment in extended period of operation would
7 be reasonably assured -- versus a specific requirement for
8 detailed identification of aging mechanisms, and a mechanism
9 by mechanism evaluation of why those mechanisms would be
10 managed in any extended period.

11 The second bullet lists another item that we've
12 addressed before, and that is the question of whether or not
13 a license renewal review which focuses exclusively on
14 assuring functionality of equipment is sufficient in itself
15 to come to a conclusion that the current licensing basis
16 would, in fact, be maintained.

17 Maintaining the current licensing basis is again
18 the principal finding the Commission makes in the issuance
19 of a license. So it's an important concept. And we have
20 had some discussion about the breadth of the current
21 licensing basis and maintaining it.

22 Certainly, there are aspects of the current
23 licensing basis which go beyond functionality, operability
24 requirements and quality assurance requirements, and so on.

25 But, recognizing that all aspects of the COB carry

1 over into the extended period of operation, and recognizing
2 that our review which would focus on functionality is
3 designed to assure that plant equipment which is needed for
4 safe operation of the plant would be retained functional.

5 We think that a license renewal review which
6 exclusively -- exclusively -- focuses on this issue of
7 functionality in combination with the recognition that all
8 other aspects of the COB carryover should be a sufficient
9 basis for a Commission conclusion that the COB would be
10 maintained in any extended period.

11 So we've emphasized that in the statement of
12 considerations.

13 As I said before, we've eliminated the term, "Age-
14 Related Degradation Unique To License Renewal," and we've
15 eliminated a number of other terms that are in your handout,
16 and which I won't flash out.

17 But we think, in combination, eliminating a number
18 of these terms should help to simplify an understanding of
19 the rule and how it might be implemented.

20 [Slide.]

21 MR. TRAVERS: The most significant change by far
22 that we have made is related to the principal concern
23 industry had with the existing rule and that is that because
24 of the definition of age-related degradation unique to
25 license renewal a great deal of plant equipment would be

1 brought into the review under Part 54.

2 A great deal of plant equipment would have to be
3 submitted or at least a discussion of how aging would be
4 managed for lots of equipment would have to be contained in
5 an application.

6 The Staff would have to review it. The Commission
7 would have to make a finding on it.

8 As I said before, this has been the biggest
9 concern that we have experienced in our dealings with
10 industry, most recently in the workshop we had late last
11 year or early this year.

12 The current rule or rather our current revision to
13 the rule proposes to narrow the focus of the renewal review
14 by recognizing that for certain equipment existing
15 activities and the regulatory process, including the
16 maintenance rule, can be relied upon to continue to manage
17 the detrimental effects of aging.

18 Where in Part 54 we would have expected fairly
19 easy justifications based on existing programs this rule
20 establishes generic credit for certain equipment which is
21 currently covered by programs which, when you think about
22 it, should be as applicable and as effective in any extended
23 period.

24 So we are taking on a burden in this rulemaking of
25 establishing that for certain equipment, namely equipment

1 that is active, long-lived -- I'm sorry -- active, short-
2 lived, relatively short-lived, and redundant, that that
3 equipment is already covered or it need not be the subject
4 of the license renewal review and the equipment that is
5 passive, long-lived, and nonredundant really ought to be the
6 focus of our attention, our review for license renewal.

7 One thing I should mention is that the statement
8 of considerations recognizes that as we get additional
9 experience with aging and its management for passive, long-
10 lived equipment, and as we possibly develop regulations that
11 may address requirements for managing aging that the scope
12 of the license renewal review could be further reduced.

13 Right now this is a fairly conservative approach
14 that recognizes for certain equipment that the effects of
15 aging are less readily observable, that our experience is
16 relatively minimal for long-lived passive equipment, so it
17 focus the review down to that rather small set of
18 equipment at least relative to what the original rule would
19 have required.

20 [Slide.]

21 MR. TRAVERS: That narrowing of the focus is
22 really the key issue that is addressed in this rule.

23 Once you establish a rule that provides
24 categorical exclusion for all active, relatively short-
25 lived and redundant equipment, you have managed to reduce

1 the set of equipment that is subject to the license renewal
2 review.

3 The benefit of that of course is it allows you to
4 focus on the equipment and put your resources on the review
5 of that equipment that gives you the most pay-back in terms
6 of establishing for any extended period of operation that
7 the functionality of that equipment can be reasonably
8 maintained.

9 Some other aspects of the rule that we have
10 changed is that we have simplified the integrated plant
11 assessment.

12 Steve Reynolds is going to be talking about this
13 in some more detail but a simple measure of how we have
14 simplified it is once it was six steps and now it is three,
15 but that is too simple.

16 Fundamentally what we have done in the integrated
17 plant assessment is to allow for flexibility on the part of
18 an Applicant to assess how they are going to quickly focus,
19 how they are going to identify the passive, long-lived, and
20 nonredundant equipment.

21 Previously the integrated plant assessment was
22 very prescriptive. It laid out a step by step, ordered
23 procedure that had to be followed rather prescriptively and
24 the changes that we have made within this process are to
25 provide flexibility to arrive at a rather significantly

1 smaller set of equipment that becomes the focus for license
2 renewal.

3 [Slide.]

4 MR. TRAVERS: One example of what is not required
5 in carrying out the integrated plant assessment is a listing
6 of all structures and components that are within the scope
7 of the renewal review, so previously you would have had to
8 establish a great detailed list of equipment that ultimately
9 might get screened out. Right now the integrated plant
10 assessment would have you focus and identify what becomes
11 the set of long-lived passive, nonredundant as opposed to
12 going through a lot of intermediate steps which are labor
13 intensive.

14 Another thing we have done is to reduce the amount
15 of information that would be compiled and submitted as part
16 of the FSAR supplement.

17 Previously, under Part 54, the entire application
18 would be submitted as part of an FSAR supplement. The
19 proposed revision however would only establish the
20 requirement for a summary description of the results of the
21 integrated plant assessment and time limited aging analysis.
22 We think this is more consistent with the kind of
23 information that is in FSARs today.

24 It does vary, certainly, but we think that the
25 current rule's requirement to have all of this information

1 provided in an FSAR supplement creates a number of burdens.

2 One of them is on the periodic updates that would
3 be required. Any changes would have to be run through a
4 process that probably isn't justified under the -- it would
5 be inconsistent with the current processes and the type of
6 information that is contained in FSAR supplements.

7 We think it is more consistent with current
8 practice to reduce this information considerably and we have
9 done that.

10 [Slide.]

11 MR. TRAVERS: The last thing I want to touch on
12 before Steve goes through in some more detail the integrated
13 plant assessment is that we have greatly reduced,
14 essentially eliminated special reporting and the control
15 requirements associated with the information submitted in
16 the application.

17 Part 54 establishes its own reporting and control
18 administrative mechanism for the information that would have
19 been submitted and rather than create a new set of
20 administrative requirements, what we are going to do within
21 this revision is rely on the existing regulatory process to
22 control this level of information.

23 We have the capability where we judge a piece of
24 information so significant to make it a license condition or
25 a technical specification and we would do that in any case

1 where a particular commitment relative to managing aging in
2 the expended period is so significant and we think that the
3 current process affords us enough control that we need not
4 establish a separate and new one within the confines of Part
5 54.

6 With that I am going to turn it over to Steve
7 Reynolds, who is going to give you a little bit more detail
8 on the integrated plant assessment and time limited aging
9 analysis.

10 MR. DAVIS: Excuse me. I have a question.

11 I was in a conference recently and learned that
12 the United Kingdom is doing quite a bit of work on aging
13 research and they are now getting some age on their
14 reactors. Exactly.

15 I realize the designs are quite a bit different,
16 but one of the things they are looking at in quite a bit of
17 detail is concrete aging.

18 Are you aware of that work and taking advantage of
19 it?

20 MR. TRAVERS: Yes. We have been interacting with
21 NII on the work they are doing in both this process realm
22 and in some of the technical realms as well.

23 I will be available throughout the briefing. So
24 if it is convenient, we will go through Steve Reynolds's
25 presentation.

1 MR. WYLIE: I believe as part of the NPAR program,
2 concrete was looked at and there are some NUREGs out and
3 some DOE documents out on concrete aging.

4 MR. REYNOLDS: I guess I will introduce myself a
5 little bit. I am Steve Reynolds, but more importantly I
6 was -- I guess I still am -- I am the leader of the licence
7 renewal working group. We were the staff that actually
8 wrote the rule and the statement considerations and the
9 commission paper that you see before you.

10 [Slide.]

11 MR. REYNOLDS: What I plan to do now is to talk
12 about some of the specific changes that we made to what we
13 think is the heart of the rule. What we consider the heart
14 of the rule in our case is integrated plan assessment which
15 I'll talk about, this slide and a couple others.

16 We also have a section, the rule on time-limited
17 aging analysis. And then, to follow that up to be
18 consistent with these changes, also talk about the finding,
19 how we changed the finding to be consistent with these
20 changes.

21 Bill talked about simplifying the rule. This
22 first step here used to be three steps and it was very
23 prescriptive. You had to do step one and then step two and
24 then step three. We simplified it. We think we can lead in
25 it with just one step and this one step is just what we need

1 to review. And that is those systems and structures that we
2 feel need to be -- excuse me, those structures and
3 components that need to be reviewed for aging for the period
4 of extended operation or for license renewal.

5 Giving credit for the maintenance rule and
6 existing maintenance activities and programs we've got going
7 on, we decided -- determined what needs to be reviewed for
8 license renewal are structures and components that are
9 passive and long-lived and nonredundant.

10 MR. KRESS: You are using that "and" and it is
11 that it has to meet all three of these?

12 MR. REYNOLDS: Yes. Those are the ones that we
13 think need to be reviewed.

14 MR. KRESS: Not just passive. But it has to be
15 passive and long-lived and nonredundant?

16 MR. REYNOLDS: Those are the things that we need
17 to look at. One of the flexibilities that I was going to
18 talk about earlier but I'm glad I can go ahead and talk
19 about right now is if the licensee only wants to determine
20 what's passive and describe all that, that's fine. Or if
21 they want to tell us what's passive and long-lived, that's
22 fine. Or if they want to screen and tell us what's passive,
23 long-lived and nonredundant. As you keep adding those ands,
24 the scope gets smaller and smaller. With our language, the
25 way you interpret it, we allow you some flexibility.

1 For some licensees, it may be easier to not go
2 through the process of determining what's redundant and
3 what's nonredundant. So that's one of the flexibilities
4 we've added.

5 Again, we think we've added some simplicity here.
6 Like Bill said, it would require three different lists. In
7 the old rule here, it just says one list of what's passive,
8 long-lived and nonredundant.

9 [Slide.]

10 MR. REYNOLDS: The next couple of pages, I try to
11 describe what we consider as passive, long-lived and
12 nonredundant. Again, you know, realizing where we came from
13 and processes and experience we've learned, we decided to
14 give maximum credit to the maintenance rule and the existing
15 maintenance activities. So we can exclude from our review,
16 plant-specific review, active equipment. But we need to
17 focus on passive.

18 The reason we think we need to focus on passive is
19 that passive equipment, they don't readily reveal the
20 effects of aging based on the current condition of
21 monitoring programs that currently exist out in the plant.

22 One of the things we decided to do with the terms
23 "passive", long-lived and nonredundant is not use them in
24 the rule. And "passive" is one of the best examples for why
25 we didn't use the term "passive" in the rule.

1 We did some research, literature research, and
2 came up with 40 existing definitions of "passive." That's
3 various codes, committee standards, committees,
4 international definitions have. And they're all slightly
5 different.

6 We have reviewed all of them and said, will any of
7 them capture what we really want. And it seemed a lot of
8 them would capture a lot of mechanical equipment but they
9 would miss electrical. Or it would be a good electrical
10 definition but it would miss mechanical.

11 What we ended up settling on is we used a
12 definition from ANS and we modified it slightly and what we
13 mean now is the equipment that performs its function or its
14 attendant function without moving parts, without a changing
15 configuration or properties. We still recognize that that
16 wasn't maybe as crisp or as clear as we would like it so we
17 actually stuck examples in the rule language to make it even
18 clearer exactly what we're going after. And we also
19 included in the rule language examples of what we are not
20 going after.

21 In addition to what's up here on the slide, some
22 additional examples of what we consider as passive would be
23 like accumulators, spent fuel racks, equipment hatch, cable
24 trays.

25 Some examples of what would be excluded or not

1 passive would be like cooling fans, switch gears, diesel
2 generators snubbers.

3 MR. MICHELSON: How about electrical cabling?

4 MR. REYNOLDS: Generally we would consider those
5 passive.

6 MR. MICHELSON: You are not excluding them?

7 MR. REYNOLDS: Right. That's passive.

8 But normally or generally they will get exclusion
9 on the redundant/nonredundant part.

10 So what I was going to end up here, which is a
11 good point you pointed out, just because it's passive it
12 doesn't mean it has to be subject to aging management
13 review. Again, like I said earlier, if it's passive, long-
14 lived and nonredundant it is subject to review.

15 MR. MICHELSON: But if you have a nonredundant,
16 then you consider the electrical cabling and wiring and so
17 forth required to support that system are all passive and
18 are considered so under this rule; is that correct?

19 MR. REYNOLDS: Right.

20 MR. DAVIS: I need some clarification if you don't
21 mind.

22 The nonredundant part confuses me because it seems
23 to me like aging effects can be detrimental to redundant
24 equipment also and if you are only looking at nonredundant
25 equipment that seems to me would exclude safety-related

1 equipment which is redundant; is that correct?

2 MR. REYNOLDS: Right. In fact, to take it a step
3 farther, aging affects active, it affects short-lived
4 components.

5 Basically, we think for license renewal, in
6 addition to the current requirements going on today, the
7 current regulatory process we have --

8 MR. DAVIS: That will pick up the safety-related
9 stuff, the current requirements.

10 MR. REYNOLDS: Yes. License renewal -- I'm
11 getting a little ahead of my --

12 MR. DAVIS: I'm sorry. I can wait.

13 MR. LINDBLAD: It occurs to me that two slides he
14 describes nonredundant. Why don't we hold your question
15 until then.

16 MR. MICHELSON: My concern is that redundant
17 electrical equipment is not considered for this, and that
18 bothers me a little bit. It's not under the normal things
19 that, you know, those are not actuating every day and moving
20 and everything.

21 You do, of course, if it faults, you know, but it
22 can be highly-degraded before it finally faults. And then
23 you might even get multiple faults from it.

24 But, yet, that's not considered. Yes.

25 MR. NEWBERRY: Scott Newberry is my name.

1 I might as well comment on that now. It will come
2 up again. Pete asked a very good question, and we'll talk
3 about it some more. But I think what we considered in
4 looking at the experience we had with this rule is that the
5 license renewal rule is not the only place we look at aging
6 in nuclear power plants.

7 And that the way to get at concerns of aging cable
8 or aging equipment is not solely through the license renewal
9 rule. Discussions with the Committee on EQ and fatigue
10 identified --

11 MR. MICHELSON: How do you get it on cabling with
12 your present programs?

13 MR. NEWBERRY: Currently, there's an action plan
14 looking at the environmental qualification of equipment for
15 operating reactors as it ages, prior to reaching 40 years.

16 MR. MICHELSON: Now, what does redundant versus
17 non-redundant have -- how does that have anything to do with
18 the issue, then? You just simply say we don't work with
19 cable, whether it's a redundant system, or not.

20 MR. NEWBERRY: During the current term, it
21 doesn't. What we're talking about here are elements of a
22 methodology to focus for license renewal, which is above, I
23 would say, the current requirements.

24 MR. MICHELSON: Now, what is the rationale why a
25 non-redundant cable is considered to age, but not the

1 redundant?

2 MR. NEWBERRY: We aren't saying that it's not
3 considered to age.

4 MR. MICHELSON: Well, I mean, considered to age in
5 the sense of your program. You will look at the non-
6 redundant, apparently, but will not look at the redundant.

7 MR. NEWBERRY: For license renewal, that's
8 correct.

9 MR. MICHELSON: For license renewal.

10 MR. NEWBERRY: That's correct.

11 MR. MICHELSON: And what's the logic for that?

12 MR. NEWBERRY: The logic is largely the importance
13 in that it is not backed up by redundant cable, and that
14 realization that the rest of the current licensing basis
15 will be carrying over into the extended period.

16 If the programs need to be improved for cable,
17 monitoring of cabling, as they age, we need to get on to
18 that now, rather than making it a license renewal issue.

19 MR. DAVIS: But, it seems to me like non-redundant
20 cabling, it can't be safety-related, or it would have to be
21 redundant.

22 MR. MICHELSON: Well, I think they're dealing now
23 with these single trains of river water systems that we
24 might flood the reactor with, or something.

25 That's the only non-redundant ones I know of.

1 MR. DAVIS: I guess I'm confused.

2 MR. MICHELSON: I think this is some kind of a
3 system which is only single-train and, therefore, must be a
4 tertiary backup for something.

5 MR. WYLIE: Have you got an example for it?

6 MR. NEWBERRY: Yes. The reactor vessel in the
7 containment. I think it was that approach that really was
8 the birth of this requirement.

9 MR. MICHELSON: We're talking about systems that
10 require wires. What would be an example of a non-redundant
11 system that's safety-related?

12 MR. NEWBERRY: With respect to the electrical
13 aspects?

14 MR. MICHELSON: Yes.

15 MR. NEWBERRY: I don't have good examples for it.

16 MR. MICHELSON: Well, unless we --

17 MR. LINDBLAD: Why don't you proceed with your
18 presentation? We may need to revisit this following your
19 presentation.

20 MR. REYNOLDS: Next thing I want to talk about
21 what we have in our rulemaking is long-lived. Again, here,
22 we're not going to use the term in the rule. We want to be
23 clear exactly what we're going after. We're going to go
24 after the equipment that's not subject to replacement based
25 on qualified, certified or specified time or period.

1 Specified time period would be before 40 years,
2 and it's based on plant experience, qualified service life,
3 and it's based on some sort of analysis for evaluation that
4 say it's going to be replaced.

5 Here, again, we're given a generic exclusion, per
6 se, for equipment that is not long-lived. The applicant
7 won't have to describe that to us. They just have to screen
8 in or focus on equipment that is long-lived.

9 One of the things we considered and we thought not
10 to give a generic exclusion for was equipment that was
11 replaced based on a performance or condition.

12 And if you go back the reason we're concerned
13 about passive is that passive equipment doesn't readily
14 reveal the effects of aging through existing condition and
15 performance monitoring programs. The logic flows we then
16 can't screen it out based on condition of performance
17 monitoring.

18 So we said, generically, we can't give you that
19 exclusion if it's replaced on condition with monitoring.
20 However, plant-specific or component-specific applicants
21 will be able to use that. We just aren't comfortable enough
22 today to give you that exclusion.

23 However, we are comfortable enough today with the
24 process that if you replace it on a fixed interval base,
25 unqualified life, service life, specified time period, you

1 don't have to consider it.

2 But, things that are not replaced are within the
3 scope of what we're going to review.

4 Again, some examples here would be like the
5 vessel, steam generator, pressurizer. And for these types
6 of replacements, we're talking life for life replacements.

7 Now we'll go back to redundant and non-redundant.

8 Again, one more time, we're not going to use the
9 term "non-redundant" in the rule. Again, we think using the
10 term would add some confusion, and so not using it would
11 have some clarity.

12 I want to reiterate here, as I said earlier, that
13 license renewal requirements that we're having in addition
14 to the current requirements that licensee has to meet,
15 remember the second principle -- to maintain the current
16 licensing basis, whatever requirements they have to meet
17 today during the term, first 40 term, they have to continue
18 to meet that.

19 So we're focusing on those pieces of equipment,
20 those structures and components that we feel need an
21 additional review for an extended period of operation.

22 MR. DAVIS: Do these have to have anything to do
23 with safety? I can think of a lot of known redundant
24 structures that have nothing to do with safety.

25 Would they still be included under this

1 definition?

2 MR. REYNOLDS: If it comes in the initial scope of
3 license renewal, and we may get some non-safety-related
4 structures and components that could adversely affect
5 safety, those pieces of equipment will come in the initial
6 scope. And those may end up being non-redundant.

7 Fire protection may be an example you're thinking
8 of. Fire protection we have an explicit requirement as
9 within the scope of license renewal.

10 So if we have a passive long-lived non-redundant
11 piece of fire equipment, that will be subject to an aging
12 management review for license renewal.

13 MR. NEWBERRY: I thought of an answer to Mr.
14 Michelson's question perhaps on electrical. The question on
15 the scope prompted me thinking about them.

16 The third criterion for the scope includes
17 regulations that are judged to be important. And they
18 include not only fire protection, but station blackout and
19 ATWS, where we don't always have safety-related
20 requirements.

21 And I would think it would pick up perhaps some
22 electrical systems that are not always redundant.

23 But, the other part perhaps on cable, maybe we can
24 keep it in mind. I think Steve's going to talk about time-
25 limited analysis, environmental qualification for many

1 plants, although it makes you consider the aging of
2 equipment. Some plants would have to do that for cable.

3 I suspect they used a 40-year limit in their
4 analysis. That's going to have to be looked at explicitly
5 for license renewal, whether it's redundant or not.

6 MR. LINDBLAD: Well, I would suppose, if we were
7 stretching to find one, that we could answer Karl's question
8 by referring to the grounding network in the station.

9 The station grounding network is typically non-
10 redundant, passive, long-lived system. And you could --

11 MR. MICHELSON: And those grounding lugs have been
12 known to corrode as reported in LERs and cause the whole
13 building to lift a bolt or so --

14 MR. LINDBLAD: I think I was talking about the
15 buried part rather than the attachments to.

16 MR. MICHELSON: Oh, I know. Where -- it's where
17 you connect to the buried part they've been having the
18 trouble. Those corroded off, and that is --

19 MR. LINDBLAD: Well, then they would be called
20 short-lived, wouldn't they?

21 MR. MICHELSON: Yes, indeed. They did have a
22 short life. Didn't even last four years.

23 MR. CARROLL: But a bolt or so raises havoc with
24 solid state control systems.

25 [Slide.]

1 MR. REYNOLDS: The last two steps are the
2 methodology stuff and then the step where they actually
3 describe their aging management activities.

4 Again, I think the way wrote the methodology
5 stuff, they just have to describe and justify the methods
6 they used to identify those structures and components that
7 are passive along with nonredundant structures and
8 components that are subject to aging management review. We
9 have added a lot of flexibility there.

10 The Licensee can choose or develop their own
11 method of how they get from the initial plant, go through a
12 scope of license renewal to that final list which is subject
13 to aging management review. We didn't dictate it in the
14 rule. We weren't prescriptive. We were just interested in
15 the bottom line and the methodology of how they got there to
16 make sure that they captured all the right equipment, so we
17 gave them some flexibility there.

18 We think in general with these three steps, as
19 Bill Travers said earlier we went from six steps to three
20 steps, adds some simplicity.

21 We also added some other flexibility like I spoke
22 of earlier. When you are doing your determination of
23 structures and components that are subject to aging
24 management review you can screen on passive first, then
25 long-lived, and then nonredundant or what suits the

1 Applicant better would be to screen on long-lived first, and
2 then passive, then nonredundant -- whichever way you want to
3 do that.

4 Leave it up to the Licensee. One way may work
5 better for one Licensee than the other. We are just
6 interested in what the final list is.

7 Another way we added some flexibility is in the
8 current rule the Licensee will have to describe the
9 equipment that is not subject to further review in addition
10 to the equipment that is subject to further review.

11 Here we are giving maximum credit for existing
12 programs and the maintenance rule to the point where we are
13 going to give you a generic exclusion per se so that you
14 don't even have to tell us in the application what those
15 pieces of equipment are and what are you doing with them.

16 We're saying all we want to know about is those
17 passive long-lived, nonredundant pieces of equipment.

18 MR. KRESS: Is there an implied assumption in this
19 exclusion of redundant systems that redundant systems that
20 age, when they fail they will not fail at the same time?

21 MR. REYNOLDS: Right. That's part of our
22 assumption. The system has redundancy; you won't have a
23 simultaneous failure, loss of system function due to aging.

24 MR. KRESS: What do you mean by simultaneous in
25 that? Is there a time frame associated with that like

1 between inspections or between tests or for these systems?

2 MR. REYNOLDS: I don't think we have defined that.

3 MR. TRAVERS: This is Bill Travers again. It's
4 one argument we use. However, in the statement of
5 consideration we recognize that simultaneous failures could
6 in fact occur although they are less likely so the argument
7 in part is based on this less likely expectation of aging
8 effects resulting in a simultaneous coincident failure such
9 that the system or structure failure would be lost.

10 MR. LINDBLAD: It seems to me that it is implicit
11 in the three descriptors of passive, long-lived, and the
12 like that there is a dispersion in time for failure not
13 prompted by the actuation if it is a passive structure and
14 that its life is long with respect to the operating life of
15 the plant.

16 MR. TRAVERS: Yes. Scott and Steve have both
17 pointed this out and I have to keep reminding myself and the
18 people I talk to that license renewal and what we are
19 causing to be reviewed for renewal is an additive
20 exercise and it is addi. of the aspects of the
21 current licensing basis th continue to apply, in fact,
22 some new ones that may develop over time.

23 We are looking now, for example, at adopting IWE
24 and IWL as in the Section 11 requirements, so as we get
25 experience we combine that new experience and the

1 possibility of new regulations and even backfits.

2 But all of the regulatory requirements that apply
3 in the first four years would continue so one way to look at
4 what we are doing in focusing the license renewal review is
5 to recognize that in connection with exercising in the most
6 efficient way we can a concentrated effort on that equipment
7 where we suspect the possibility at least that today
8 programs may not provide an adequate level of ensuring
9 functionality.

10 When we look, we may find that even the programs
11 that exist today for that equipment are in fact reliable
12 enough that we simply accept them for what they are and
13 apply them in the extended period of operation in the same
14 way that they apply them today but what we are doing in the
15 renewal is focusing on what at least has to be examined for
16 the issuance of a renewed license.

17 MR. WYLIE: Let me ask, the EPRI-URD has a section
18 on the aging management program requirements. Have you
19 examined that? Is that part of what you are referring to
20 here under managing aging?

21 MR. NEWBERRY: You mean the EPRI Utility
22 Requirements Document?

23 MR. WYLIE: That's right.

24 MR. NEWBERRY: That would be used for the
25 standardized designs?

1 MR. WYLIE: Yes. I mean they have a whole section
2 in there on aging management.

3 MR. NEWBERRY: I have to say personally I am not
4 familiar with it.

5 MR. WYLIE: I would think you'd have looked at
6 that.

7 MR. NEWBERRY: Thank you.

8 MR. CARROLL: Its applicability, Charlie, of
9 course is to the advanced reactors, not to -- just to the
10 advanced reactors, not to existing plants but there is a lot
11 of good wisdom in there.

12 MR. WYLIE: It's a good place to start because
13 they go into quite some detail as to how you do this.

14 [Slide.]

15 MR. REYNOLDS: The next major part of the rule I
16 would like to spend a couple minutes on is time-limited
17 aging analysis.

18 Bill Travers said earlier both it is continued
19 from the old rule but it is new in the fact that we
20 highlight it now. In the past it was part of the definition
21 of ARDUTLR. With the deletion of that and trying to be
22 clearer, we pulled it out and put it in as a separate
23 section in the rule. This is the one case where we added a
24 definition to the rule.

25 Bill spoke earlier and we skipped over the

1 definitions on page 8 that were deleted from the rule. Here
2 is one place where we think adding a definition makes it
3 clearer.

4 There appeared to be some confusion about exactly
5 what we meant by "time-limited aging analysis" so we put a
6 definition in the rule that spelled out what we mean. It's
7 those calculations and analysis that a Licensee relies upon
8 to determine their equipment will perform its intended
9 function and it is based on aging effects and it is based on
10 explicit assumptions during the current operating term.

11 A couple of examples that we consider a time-
12 limited aging analysis in addition to what Scott Newberry
13 talked about, EQ reactor vessel neutron embrittlement is a
14 time-limited issue, and in-service flaw growth, and concrete
15 containment tend to pre-stress are some examples that we
16 have for a time-limited aging analysis.

17 Some people have asked, well how many of these do
18 we have? So far on a generic basis we have only identified
19 very few. It is not a huge amount of issues. It is just a
20 very small subset.

21 One thing that we tried to do when we actually put
22 the language in the rule how to do it was you'd have to
23 identify and give us a list of time-limited issues but we
24 are going to give you three ways or give the Licensee three
25 ways to demonstrate that the equipment will perform its

1 intended function during the period of extended operation.

2 [Slide.]

3 MR. REYNOLDS: One of the way is to demonstrate
4 that the analysis that they had for 40 years would remain
5 valid -- is good for the next 20 years if the applicant
6 would choose to go for a 20-year renewal period, or they can
7 redo the analysis, project it out longer. When they redo
8 the analysis, it will be based on a current licensing basis.
9 They won't have to use a current standard that is not part
10 of the licensing basis.

11 The Fed option that we said would be acceptable to
12 us is if they develop an aging management program for the
13 systems, structures and components that deal with these
14 time-limited issues. We won't necessarily have to redo
15 analysis.

16 We figure any one of those three or any
17 combination of those three, the licensee can choose whatever
18 best fits their need, we'll allow them to do that.

19 [Slide.]

20 MR. REYNOLDS: With the changes that we have made
21 to the rules, integrated plan assessment and time limit
22 aging analysis, we had to change the standard or the finding
23 we have to make.

24 We deleted the term of ARDULTR. We had to change
25 the finding. We think it is a lot clearer now. It spells

1 out exactly what we are going to make -- the NRC is going to
2 make a finding on. Those actions that a licensee applicant
3 has made or will make for those structures and components
4 subject to aging and management review, and what actions the
5 licensee has taken or will take for those system structures
6 and components subject to a time-limit aging analysis.

7 MR. CARROLL: Why isn't systems in the first
8 bullet?

9 MR. REYNOLDS: What we did is we figured on the
10 focus on just those structures and components that -- it is
11 really when you go from redundant and non-redundant, whose
12 failure could result in loss of system function.

13 If you look at a system, why we included systems
14 for a time limit aging analysis is that some time limit
15 aging analysis is on a system basis. We really wanted to
16 focus on just structures and components, but we had to go to
17 system for time limit aging analysis.

18 MR. CARROLL: I'm happy.

19 MR. REYNOLDS: We added two new paragraphs to the
20 finding, and those paragraphs are sections -- we added for
21 clarity to say that a current term issue will be dealt with
22 in the current term or as a current operating issue, and
23 will not be a license renewal issue.

24 We had that question come up several times. We
25 tried to cross some language with the help of our general

1 counsel's office to say if you come up with the current term
2 operating, it is going to be handled, then current term will
3 not be a license renewal issue.

4 I think now with the specific changes we made to
5 the rule language and with the explanations and discussions
6 and examples that we have and the statement's consideration,
7 that the rule that we are proposing to go out with is a lot
8 simpler and a lot clearer, while it still was not going to
9 provide a considerable amount of flexibility for an
10 applicant.

11 We feel that this proposed rule which gives
12 maximum credit for maintenance rule and existing maintenance
13 program and activities will provide the stability and
14 predictability that will allow licensees and potential
15 applicants to determine whether or not they want to come in
16 and apply for a license renewal.

17 MR. CARROLL: What is the current situation? Are
18 there licensees or owner groups or whatever that are
19 actively following this and indicating that they are going
20 to be submitting applications?

21 MR. REYNOLDS: I will give you my answer, but we
22 have representatives from NEI who may also want to answer it
23 or clarify any statements I make.

24 We have been working with several owners groups.
25 In fact, we are meeting with B&W owners group this morning.

1 Baltimore Gas and Electric has still been involved with us
2 in license renewal. Virginia Power has indicated that they
3 are very interested and they may come in relatively short-
4 term as far as --

5 MR. CARROLL: Didn't I read that they are not
6 looking for the full 20 years?

7 MR. REYNOLDS: They have talked about coming in
8 for five years.

9 MR. CARROLL: Why is that? Do you know?

10 MR. REYNOLDS: I will show my ignorance in
11 economics, but they say it is based on economics, and I
12 can't take it much farther than take their word for it as
13 far as my economic values go.

14 MR. CARROLL: It would also seem to me it would be
15 just as easy to do 20 years as 5 years, and then you have
16 some flexibility.

17 MR. REYNOLDS: They indicated it would work out
18 better for them economically, and in discussions with their
19 public utility commission.

20 We think the technical evaluation is pretty much
21 the same. You are going to have to repeat it four times if
22 you going to have to end up going five, five, five, five.

23 MR. CARROLL: Yes.

24 MR. TRAVERS: When you consider that this is a
25 process driven rule, you are right, Jay. The advantage

1 isn't obvious why you would want to come in for five, but in
2 our discussions with VEPCO they have identified some pretty
3 significant economic returns in the way they amortize their
4 plan. That, at least in part, is what is driving them. I
5 think there is a perception that it might be somewhat
6 easier. There may be some lessened technical argument
7 associated with extending five years and 20.

8 But given the process nature, what would have to
9 be reviewed, the scope of it and so on and so forth, if you
10 envision ultimately going for as many as 20 and you envision
11 going through it four times, it could be prohibitive.

12 [Slide.]

13 MR. REYNOLDS: And the last thing I would like to
14 conclude with is our schedule. We are proposing a 90-day
15 comment period which should end up some time in October if
16 everything goes as we expect.

17 We think we can wrap up the public comments and
18 revise the rule package within five months and get back to
19 the Commission in March. That means that we will be back to
20 you somewhere around January this time, well ahead of the
21 Commission instead of one day ahead of time.

22 MR. CARROLL: Do you believe that in March of '95
23 there will be people beginning to submit applications or
24 prepare applications?

25 MR. REYNOLDS: I think people may start working on

1 applications, but I don't think we will get one that early -
2 - earlier indications, I don't know what their current
3 status is. Virginia Power said maybe sometime in '95 they
4 will come with an application or applications for their
5 plants.

6 MR. TRAVERS: One other piece of information that
7 we've had in working with the B&W owners group is that while
8 they haven't identified a specific B&W plant, they have
9 indicated that as a result of their generic efforts, they
10 would like to be in a position and they expect to be in a
11 position in fiscal '97 to come in with one of their plants
12 as the prototype B&W license renewal application.

13 MR. NEWBERRY: I think what we are going to see in
14 '96 and '97 are generic reports, so there will be a lot of
15 work after the rule, I would think, generically.

16 MR. LINDBLAD: Mr. Travers, Mr. Reynolds has said
17 you are going to be back to us after the public comment
18 period and before you go back to the Commission.

19 MR. REYNOLDS: That's correct.

20 MR. TRAVERS: Yes, that's right.

21 MR. LINDBLAD: Are you looking for a letter from
22 us today?

23 MR. TRAVERS: It is always difficult for the staff
24 to tell you whether you should have gone to the Commission
25 or not.

1 MR. LINDBLAD: I am saying, we may decide to do
2 one on our own volition, but do you find it required in your
3 process?

4 MR. TRAVERS: I think I would view it as useful.
5 Let me say that in the past the committee has written a
6 number, at least two or three, of letters on the subject of
7 renewal.

8 MR. CARROLL: That was to get your attention.

9 MR. TRAVERS: You have it. The last one was in
10 June, I think, of last year. Basically, your comments were
11 directed at a better recognition in the rule of existing
12 programs and their continued effectiveness in the extended
13 period of operation now. Regarding future communication
14 with the Commission, let me say that we are meeting with
15 them tomorrow, and let me say that they are interested in
16 moving out rather quickly on a proposed rule if they find
17 this one acceptable.

18 So if you do decide to communicate, it would
19 probably have to be in the relative near term to have
20 meaningful influence on their actions regarding this
21 proposed rule.

22 MR. LINDBLAD: Let me point out to the members
23 that what we have in Tab 4 is a close to final version of
24 what the SECY was that will go to the Commission tomorrow.
25 It was a six-week old version that just today we received

1 copies of something that is two weeks old, I suppose, that
2 will be used at the Commission. Through some inadvertence,
3 ACRS was not put on the distribution at the timely point, so
4 we only received the copies recently.

5 MR. TRAVERS: I am sorry to hear that, normally
6 the distribution is made elsewhere.

7 Let me make mention, if I may, Mr. Lindblad, of a
8 commitment that we had to update this committee on any
9 changes between the draft document that we sent to you and
10 this final package. We have reviewed what we sent you very
11 recently, and while we have made a number of changes in the
12 length of some of the justifications in the statement of
13 consideration, and some of the characterizations in the SSC,
14 we couldn't find significant changes between what we sent
15 you a number of weeks ago and this package that is before
16 the Commission now. So we don't think that exists, and if
17 we find out that that is wrong, we will let you know as soon
18 as we can.

19 MR. LINDBLAD: Fine. Thank you, Bill.

20 Any other questions of the staff?

21 [No response.]

22 MR. CARROLL: It sounds like they are going to get
23 this thing on the road on about the first anniversary of Jim
24 Curtiss' departure.

25 MR. LINDBLAD: Yes.

1 We have some remaining time, one could either use
2 Ivan's ability to work some more on his letter, or is there
3 interest in the committee in making sure we send a letter
4 out on this particular subject of license renewal that would
5 have to get to them before tomorrow.

6 MR. DAVIS: Don't we need to look at SECY 140 to
7 provide a meaningful letter.

8 MR. LINDBLAD: The one that was distributed early
9 is very close to it.

10 MR. DAVIS: I haven't looked at it yet.

11 MR. CARROLL: Our usual notion on writing letters
12 at this juncture, that is before it goes for public comment,
13 is, we see something badly flawed with what the staff is
14 going to put out for public comment, and we want to get our
15 oar in at that point because after it goes out for public
16 comment it sometimes seems like it is very difficult to
17 change things.

18 MR. LINDBLAD: Do you think we have triggered
19 that?

20 MR. CARROLL: In this case, I don't think we have
21 that kind of an issue. I think we could almost do it with
22 a -- my feeling from what I read is, we do a Larkins-gram
23 that says we don't --

24 MR. LINDBLAD: Looking forward to seeing you again
25 after the public comment period.

1 MR. CARROLL: That would be my recommendation.

2 MR. DAVIS: I will agree.

3 MR. LINDBLAL: I would think so, too.

4 MR. KRESS: That seems to be the sense of the
5 committee.

6 MR. CARROLL: That is what two people said.

7 MR. KRESS: Well, I looked around and reading
8 eyeballs it looks like there is a substantial agreement.

9 MR. SEALE: Unless you wanted to write something
10 that said, earlier we wanted to get their attention and it
11 looked like we did.

12 MR. LINDBLAD: That is an "I told you so."

13 MR. KRESS: We don't issue I told you sos.

14 MR. CARROLL: We don't do those kinds of letters.

15 MR. LINDBLAD: Mr. Chairman, I return the chair.

16 MR. KRESS: With that, Ivan, I would like to ask
17 when you have to leave?

18 MR. CATTON: Ten minutes.

19 MR. KRESS: Do you think it would be productive
20 for us to spend that ten minutes on your letter before you
21 leave?

22 MR. CATTON: I don't think so.

23 MR. MICHELSON: It didn't get you into any
24 difficulty that you might have foreseen?

25 MR. CATTON: I did add a sentence at the end

1 because Conrad reminded me that we had also committed to
2 review something called a Task Action Plan for fire
3 protection, and I didn't say that in the letter but felt I
4 should.

5 MR. MICHELSON: We didn't really review it.

6 MR. CATTON: No, that we would.

7 MR. MICHELSON: In other words, we are going to
8 review the rule as soon as it becomes available, and we also
9 plan to review the Task Action Plan in some detail in the
10 near future.

11 MR. CARROLL: What is it, the Task Action Plan for
12 what?

13 MR. CATTON: Do you remember 93-143?

14 MR. CARROLL: Right.

15 MR. CATTON: There are a whole bunch of things in
16 it.

17 MR. CARROLL: And it is to resolve those issues?

18 MR. CATTON: That's right. It is separate from
19 the rule.

20 MR. KRESS: I propose then that we take a --

21 MR. MICHELSON: Excuse me, one clarification. Did
22 you give us a sentence some where referring to the one-hour
23 versus three hours as we may have to do?

24 MR. CATTON: Yes, I stuck it in there. It is in
25 my draft that I left with Doug.

1 MR. KRESS: I propose then that we can now go off
2 the record for the rest of the day.

3 [Whereupon, at 2:11 p.m., the meeting was
4 adjourned.]

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings
before the United States Nuclear Regulatory
Commission
in the matter of:

NAME OF PROCEEDING: 410th ACRS Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the
United States Nuclear Regulatory Commission taken
by me and thereafter reduced to typewriting by me
or under the direction of the court reporting
company, and that the transcript is a true and
accurate record of the foregoing proceedings.

Marilynn Estep

Official Reporter
Ann Riley & Associates, Ltd.

NRR STAFF PRESENTATION
TO THE ACRS

- ◆ **Protective Action Guides and Their Use in
Emergency Planning**
- ◆ **Emergency Planning Considerations Under 10
CFR Part 52**

June 9, 1994

TOPICS TO BE DISCUSSED

- ◆ EPA Protective Action Guides (PAGs)
- ◆ Relationship of PAGs to Emergency Planning
- ◆ Emergency Planning Under 10 CFR Part 52
 - Early Site Permits
 - Standard Designs (CE System 80+)
 - Combined Operating Licenses
- ◆ Licensing Review of ABB-CE System 80+
- ◆ Staff's Current Examination of Emergency Planning Basis for Passive Reactors

PROTECTIVE ACTION GUIDES (PAG)

- ◆ A PAG is the projected dose from an unplanned release of radioactive material at which a specific protective action is recommended.
- ◆ US EPA, "Manual of Protective Actions Guides and Protective Actions for Nuclear Incidents," EPA 400-R-92-001, May 1992

Table 2-1 PAGs for the Early Phase of a Nuclear Incident

| Protective Action | PAG (projected dose) | Comments |
|---|-------------------------|---|
| Evacuation (or sheltering ^a) | 1-5 rem ^b | Evacuation (or, for some situations, sheltering ^a) should normally be initiated at 1 rem. Further guidance is provided in Section 2.3.1 |
| Administration of stable iodine | 25 rem ^c | Requires approval of State medical officials. |

RELATIONSHIP OF PAGs TO EMERGENCY PLANNING

- ◆ The regulations state that emergency plans must contain guidelines for the choice of protective actions that are consistent with Federal guidance. [10 CFR 50.47(b)(10)]
- ◆ NUREG-0654 states that protective actions be in accord with the recommendations of the EPA PAG Manual. (Criterion II.J.9)
- ◆ EPA PAGs were used in the development of the 10-mile Emergency Planning Zone (NUREG-0396)

**PLANNING BASIS
FOR THE CURRENT REQUIREMENTS FOR THE SIZE
OF THE 10-MILE EMERGENCY PLANNING ZONE (EPZ)**

- Projected doses from DBAs should not exceed PAGs outside the EPZ.
- Projected doses from most core melt sequences would not exceed PAGs outside the EPZ.
- For the worst core melt sequences, immediate life threatening doses would generally not occur outside the EPZ.
- Detailed planning within the EPZ would provide a substantial base for expansion of response efforts if necessary.

10 CFR PART 52

- ★ SUBPART A -- EARLY SITE PERMITS
- ★ SUBPART B -- STANDARD DESIGN CERTIFICATIONS
- ★ SUBPART C -- COMBINED LICENSES

EARLY SITE PERMITS

★ [52.17] Application must:

- Identify physical impediments to emergency planning
- Describe contacts and arrangements with offsite authorities

May propose major features of emergency plans or complete integrated plans

★ [52.18] NRC review in consultation with FEMA

★ Proposed Criteria: NUREG-0654/FEMA-REP-1, Revision 1, Supplement 2

STANDARD DESIGN CERTIFICATIONS

★ [52.47] Application must:

- Contain information relevant to design (not site specific)
- Demonstrate compliance with TMI requirements in 50.34(f).

★ Standard design includes:

- Technical Support Center (TSC)
- Operational Support Center (OSC)
- Support Facilities (lab and decon facility)

★ [52.47] Applicant must propose ITAAC

COMBINED LICENSES

- ◆ [52.79] application must contain emergency plans which provide reasonable assurance that adequate protective measures can and will be taken in the event of a radiological emergency.
- ◆ Applicant must propose ITAAC including those applicable to emergency planning.
- ◆ Prior to operation, NRC shall find that acceptance criteria are met.
- ◆ [52.81] application will be reviewed according to the standards in 10 CFR Parts 20, 50, etc...

ABB-CE SYSTEM 80 + STANDARD PLANT DESIGN EMERGENCY PLANNING REVIEW

- ◆ Nuclear power applicants must meet the emergency planning requirements of 10 CFR 50.47 and Appendix E to Part 50.
- ◆ ABB-CE System 80 + is being reviewed under 10 CFR Part 52.
- ◆ Emergency plans are not required for issuance of a design certification under Part 52.
- ◆ Standard designs required to demonstrate compliance with TMI requirements in 50.34(f) - [TSC, OSC]
- ◆ PAG dose calculation in Chapter 15 of ABB-CE System 80 + FSER does not signal change in assessment of EP for advanced reactors.

ACCIDENT ASSESSMENT REVIEW IN CHAPTER 15 OF ABB-CE SYSTEM 80+ FSER

- **Design Basis Accidents**
 - **Evaluated Against 10 CFR 100 Guidelines**
- **EPA PAG Dose Calculation**
 - **Done for Illustrative Purposes**

**SECY-93-087, "POLICY, TECHNICAL AND LICENSING
ISSUES PERTAINING TO EVOLUTIONARY AND
ADVANCED LIGHT WATER REACTOR (ALWR)
DESIGNS"**

- **Certain modifications to EP requirements may be appropriate for the passive designs based on their unique characteristics.**
- **Need to consider a plant's ability to prevent a release or to provide very long delay times for all but the most unlikely events.**
- **More information concerning source term and risk is required.**
- **EP requirements following the TMI-2 accident were not based on strictly technical factors.**
- **As a policy matter it may be that even very low calculated probabilities may not be considered a sufficient basis for changes to EP requirements.**

**SECY-93-092, "Issues Pertaining to the Advanced Reactor
(PRISM, MHTGR, and PIUS) and CANDU3 Designs
and their Relationship to Current Regulatory Requirements"**

ISSUE

Should advanced reactors with passive design safety features be able to reduce emergency planning zones and requirements?

Staff Response

- Staff proposes no change to the existing regulations at this time
- Information obtained from ongoing accident evaluations will be factored into the EP requirements for advanced designs
- Based in part on these accident evaluations, the staff will consider whether some relaxation from the current requirements may be appropriate

STAFF REQUIREMENTS MEMORANDUM OF JULY 30, 1993 (RESPONSE TO SECY-93-092)

- **Premature at this time to reach a conclusion on EP for advanced reactors.**
- **For ongoing review purposes, staff should use existing regulatory requirements.**
- **Staff should remain open to suggestions to simplify the EP requirements for reactors that are designed with greater safety margins.**
- **Staff was requested to submit recommendations for proposed technical criteria and methods to use to justify simplification of EP requirements.**
- **The work on EP for advanced reactors should be correlated with the work on Accident Evaluation and Source Term.**

STAFF ACTIONS IN RESPONSE TO SRM

- ◆ Staff initial response proposed three technical factors as possible basis for simplifying EP requirements:
 - Reduction in source term
 - Reduction in probability of release
 - Increase in delay time preceding release
- ◆ Staff noted EP must consider public perception of risk from nuclear power plant accidents
- ◆ Staff efforts are being focused on passive designs (SBWR and AP-600) as opposed to advanced reactors because:
 - Availability of design and risk assessment information
 - Level of licensing interest
 - Insights from review of EP for passive reactors should be applicable to advanced reactors
- ◆ Re-evaluation of planning basis in NUREG-0396 using the insights from NUREG-1150 and new source term initiated by RES
- ◆ Coordination with industry efforts (NEI)

THERMO-LAG FIRE BARRIERS

June 8, 1994

Steven West, Chief
Special Projects Section

Office of Nuclear Reactor Regulation

OVERVIEW

- October 1993 - Commission briefing by staff
- November 1993 - Commission briefing by NEI
- Commission concerns
 - NEI test method. Results and applicability of tests
 - Timeliness of resolution
- Staff actions
 - ACRS meetings
 - NRR-NEI senior management meetings
 - 50.54(f) request for additional information
 - SECY-94-128, status paper - conclusions regarding 1- and 3-hour barriers
 - SECY-94-127, options and policy issues

OPTIONS FROM SECY-94-127

1. Require compliance with existing NRC requirements. Grant limited plant-specific exemptions in accordance with the regulations and past practice.
2. Study feasibility of developing new guidance for rating fire barriers on the basis of representative plant fire hazards.
3. Develop performance-based approach for resolving Thermo-Lag issues with lead plant.
4. Develop performance-based fire protection rule (SECY-94-090).

OPTION 1 COMPLIANCE WITH EXISTING REGULATIONS

- Fundamental objective of Thermo-Lag Action Plan
- 22 units have or plan to achieve compliance
- 1-hour barriers can be upgraded
- 3-hour barriers are a problem but alternatives exist
 - relocate cables and components
 - reclassify as 1-hour and install suppression
 - replace barriers
- Staff will consider limited exemptions
- NRC resources are planned for this option
- 2 to 5 years estimated to return to compliance

OPTION 2 - FEASIBILITY STUDY RATE BARRIERS BASED ON FIRE HAZARDS

- ASTM E119 may exceed fire severity in some areas
- Developing fire severity curves tailored to actual plant fire hazards may be technically feasible
- If feasible, new curves can be used to achieve compliance with existing regulations
- Developing and implementing new curves will be complex and resource intensive
- Staff study, if approved by the Commission, will address technical feasibility, resource estimates, and schedules
- If approved, staff will report results within 6 months

OPTION 3 PERFORMANCE-BASED SOLUTIONS

- Existing regulation is prescriptive
- Performance-based methods use fire models and probabilistic assessments to define fire protection
- Proposed for 22 sites (35 plants)
- Could be developed with lead plant and incorporated into new fire protection rule
- Will be technically challenging
- May require additional resources
- Policy issues

OPTION 4 PERFORMANCE-BASED RULE

- SECY-94-090 institutionalized program
- NEI plans to submit petition for rulemaking
- Staff proposes to provide comments to the Commission on the petition 6 months after receipt
- Results of work with lead plant (Option 3) could be incorporated into new rule
- NRC resources are planned for this option

STAFF RECOMMENDED APPROACH (FROM SECY-94-127)

- The staff recommends continuation of Option 1 (compliance with existing NRC requirements) consistent with the Thermo-Lag Action Plan.
- If the Commission approves this option, the staff will advise industry of the Commission position and request continued industry efforts to implement the option.

STAFF POSITION ON REMAINING OPTIONS (FROM SECY-94-127)

- If acceptable to the Commission, the staff will evaluate the technical feasibility and resource estimates for Option 2 and will report back to the Commission in 6 months
- The staff will not proceed further with Option 3 unless the Commission approves the use of performance-based approaches to resolve the Thermo-Lag issues.
- The staff will continue to be receptive to the performance-oriented, risk based rulemaking described in SECY-94-090. The staff will provide its comments on NEI rulemaking petition 6 months after receipt of the petition. (Option 4)

BACKGROUND INFORMATION

STATUS AS REFLECTED IN SECY-94-128

- Senior management meetings
- 50.54(f) request for additional information
- GL 86-10, Supp. 1, Fire Test Acceptance Criteria
- NEI and licensee fire endurance tests
- NEI application guide
- NRC full-scale fire and ampacity derating tests
- Staff position on 1- and 3-hour barriers
- Combustibility of Thermo-Lag

OPTION 2- BACKGROUND STAFF-INDUSTRY INTERACTIONS

- September 1992 - NUMARC proposed to develop and use NPP-specific fire curves for rating fire barriers
- October 1992 - NUMARC changed its proposal and decided to use ASTM E119 for barrier tests because:
 - ASTM E119 is common with tests of all other assemblies and building components
 - Experience gained with ASTM E119
 - No new "standard" exposure can be defined to eliminate all objections
 - Utilities assess fire protection on basis of standard ASTM E119 exposure

REQUEST FOR ADDITIONAL INFORMATION

- Detailed information submitted on amounts
- Limited information submitted on installation methods and barrier parameters
- Limited information submitted on fire barrier designs outside the scope of the NEI program
- Evaluations of derating awaiting NRC acceptance of NEI program
- Alternatives - performance-based approaches (21 plants), exemptions, reevaluating shutdown methods and prior commitments.

GL 86-10, SUPPLEMENT 1 FIRE TEST ACCEPTANCE CRITERIA

- Issued March 25, 1994
- Clarifies previous guidance (GL 86-10)
- For future fire tests
- ASTM E-119 standard fire
- Provides options for hose stream tests
- Provides methods for addressing deviations

STAFF CONCLUSION REGARDING THERMO-LAG BARRIER PERFORMANCE

- 1-hour baseline Thermo-Lag fire barriers
 - Provide 20 to 30 minutes of fire endurance
 - Can be upgraded with Thermo-Lag materials
- 3-hour baseline Thermo-Lag fire barriers
 - Provide about 1 hour of fire endurance
 - Cannot be reasonably upgraded with additional Thermo-Lag materials

1 HOUR THERMO-LAG FIRE BARRIERS

- 14,000 lin. ft. on cable trays (33 units, 58% at 5 sites)
- 62,000 lin. ft. on Conduits (47 units, 62% at 5 sites)
- 5,500 sq. ft. on junction boxes (26 units)
- 1,400 sq. ft. on equipment enclosures (6 units)
- 800 sq. ft. as radiant energy shields (2 units)
- 200 sq. ft. as a fire wall (1 Unit)
- 142 sq. ft. as floor/ceiling assembly (1 Unit)
- 450 sq. ft. as penetration seals (2 units)
- 5,600 sq. ft. of miscellaneous applications (13 units)

3 HOUR THERMO-LAG FIRE BARRIERS

- 7,700 lin. ft. on cable trays (25 units, 60% at 3 sites)
- 25,000 lin. ft. on conduits (49 units, 52% at 7 sites)
- 3,300 sq. ft. on junction boxes (27 units)
- 700 sq. ft. on equipment enclosures (7 units)
- 50 sq. ft. as radiant energy shields (1 unit)
- 10,000 sq. ft. as fire walls (6 units)
- 1,100 sq. ft. as floor/ceiling assemblies (2 units)
- 635 sq. ft. as penetration seals (9 units)
- 13,000 sq. ft. of miscellaneous applications (28 units)

NON-FIRE RATED BARRIERS



- 1,900 lin. ft. for physical independence (5 units)
- 700 lin. ft. to enclose combustibles (1 unit)

J.K. Richardson, P.E.

Moving Toward Performance-Based Codes

We in North America are poised on the edge of a major change in the way we develop, use, and enforce fire safety codes.





The system of building regulations in the English-speaking world is 800 years old. It began in London, England, in 1189, when the first assize was written. Surprisingly enough, these early regulations were clearly performance-based: They allowed a person to construct a building, provided he was not a nuisance to his neighbors. The principal motive for those regulations was clearly to avoid disputes.¹

In North America, similar regulations were enacted in 1622 in Plymouth, Massachusetts, after the main storehouse burned. Other regulations were enacted later, in other municipalities, as fire became a problem.

As construction methods were codified, building regulations became more and more specific. Regulation developers were confident that, as long as a building did not deviate substantially from proven practice, there was a reasonable assurance of success. These regulations could be enforced with no explanation as to their intent. If it worked in the past, the regulation developers seemed to feel, it will work now, so do it.

Toward the end of the 19th century, construction practices began to change as the "skyscraper" made its appearance in North America. Such buildings required extensive knowledge of structural and mechanical engineering principles. As a result, building regulations were gradually amended to accept designs based on stated performance objectives. There were no similar developments in the field of fire safety, however.

Throughout the 20th century, fire safety regulations developed into an extensive set of specifications, often supported by an array of standards. Although efforts have been made to move most codes toward performance-based fire safety requirements, today's fire safety regulations do not ap-

CATHERINE WOODFORD


proach the performance-type requirements now in place for the structural and mechanical engineering aspects of building construction. With new fire safety design methods based on technically proven computer models, however, a North American performance-based code may be in place by the end of the century.²

A performance code

Exactly what is a performance-based code? To many, any model code available in North America today is a performance-based code. Some feel that any code, no matter how prescriptive, is performance-based because it relies on the proven "performance" of the various systems, designs, and approaches with which it deals. Others feel that these codes are performance-based because they describe, not how an item is made, but how it should perform during a fire.

However, none of these codes is performance-based in the sense that the codes of the United Kingdom and New Zealand are performance-based. How do the British and New Zealand codes differ from those followed in North America?

First, they state their objectives clearly and in terms of outcomes that are valuable in themselves—for example, lives and property saved—and not just because of a presumed link to valued



.....

Today's fire safety regulations do not approach the performance-type requirements in place for the structural and mechanical engineering aspects of building construction.

.....

outcomes. Second, they specify verifiable performance requirements with demonstrated, quantifiable links to the objectives. And third, they permit any solution that meets the performance re-

quirement. In addition, the performance goals generally specify a level of safety.³

Let's examine these two performance-based codes more closely.

New Zealand's building code

According to the *New Zealand Building Code*, a building performs acceptably if its design and the activities that take place within the building do not present an unreasonable probability of a fire occurring.⁴ A building is also considered to perform acceptably if, in the event of fire, all of its occupants have enough time to escape to a safe place without being overcome by the effects of the fire, and the fire service has enough time and suitable access to undertake rescue operations and protect property.

In addition, a building is said to perform acceptably during a fire if the fire does not spread to other fire cells within an acceptable time or to adjacent household units and other property and if significant hazardous substances are not released to the environment. If neither the building nor its contents are seriously damaged, and if any damage to the building can be easily repaired, the building has also performed acceptably.


The *New Zealand Building Code* then goes on to establish objectives, functional requirements, and performance statements about the outbreak of fire, the means of escape, the spread of fire, and the building's structural stability during a fire. For example, the objective of the clause dealing with a building's structural stability during a fire is to safeguard people from injury and to protect households and other property from damage resulting from structural instability caused by a fire.

The clause's functional requirements state that a building is to be constructed in such a way that it will remain structurally stable enough during a fire to allow people sufficient time to evacuate safely, to give firefighters enough time to undertake rescue and firefighting operations, and to keep adjacent households or other property from being damaged or collapsing.

The clause's performance provision notes that the fire resistance of a building's structural elements must be appropriate to their function, to the fire load, to the intensity of the fire, to the fire hazard, to the height of the building, and to the fire control facilities outside and within the building. Furthermore, the fire resistance of the structural elements should be no less than that of any element within the fire cell that they support. The collapse of elements with lesser fire resistance should not lead to the collapse of elements that are required to have a higher fire resistance.

FIGURE 1

Technology Needed to Support Performance-Based Codes



In this example, the objective is clearly to safeguard people from injury and protect property from damage due to structural failure during a fire. The code user will immediately ascertain that myriad technologies can be used to achieve this objective. The objective is further qualified in the functional requirements, which define how long the objective must be met, something that can be verified by test or calculation. The time duration is also stated in terms of allowing occupants enough time to evacuate the building and firefighters enough time to perform their operations.

The code user is free to choose any technology that will provide fire resistance for the lengths of time stated. These times can, in turn, be quantified through tests, calculations, or models of evacuations and post-flashover fires.

This approach clearly differs from the traditional North American prescriptive code for structural stability, which states that floor assemblies and their supporting structure must have a certain fire-resistance rating for a specified occupancy. The definition of the occupancy may contain numerous possible fire loads and ventilation configurations—which may be more or significantly less severe than can be protected by assemblies having the specific rating—and, hence, may result in numerous possible fire attacks on the structure. In addition, the actual length of time it takes to evacuate occupants from, and perform fire service operations in, a building may vary considerably from the time assumed by those who define the fire-resistance rating.

This example thus highlights the difference between the two approaches. One is flexible and based on stated, verifiable objectives. The other provides a minimum specified rating that may or may not be sufficient to achieve the objective the code writer had in mind.

It should be noted that New Zealand's performance-based code includes requirements for verifying proposed safety solutions using calculations, tests, and other means. The code user and enforcer must thus have some means of assessment, based on calculating risk, that will allow quantification.⁵ Since the code does not quantify the level of safety required in the global sense, those using it must have a large degree of fire engineering experience and judgment.

Building regulations in the United Kingdom

The United Kingdom's building regulations follow a pattern similar to that found in New Zealand's regulations.⁶ The regulations put forth five fire safety aims.



.....

If a performance-based code is to be applied properly, we must have fire safety engineering and risk assessment tools to demonstrate that we have met the stated performance objectives.

.....

First, they call for a satisfactory standard for means of escape for building occupants in the event of fire. Second, they require that fire spread over the internal linings of buildings be inhibited. Third, they require that buildings remain stable in the event of fire, that there be a sufficient degree of fire separation within buildings and between adjoining buildings, and that the unseen spread of fire and smoke in concealed spaces in buildings be inhibited. Fourth, they require that external walls and roofs adequately resist the spread of fire in the external envelope and that the spread of fire from one building to another be restricted. And finally, they require that fire appliances have satisfactory access to buildings and that buildings provide facilities to assist firefighters in saving lives in and around buildings.

Each of these aims is expanded to include a specific performance requirement and statements of expected performance. Considerable explanation follows these performance statements.

For example, the code's means of escape provisions state that a building must be designed and constructed to provide the occupants with some means of escape, which can be used safely and effectively at all times, to a place of safety outside the building. The code further states that this requirement will be satisfied if certain criteria are met.

The building must have enough suitably located routes of sufficient capacity to allow the occupants to escape to a

place of safety in the event of fire. These routes must be adequately protected from the effects of fire by an enclosure, where necessary, and they must be adequately lit. The exits must also be suitably marked. In addition, appropriate facilities must be available to limit the movement of smoke into the escape routes, or suitable measures must be taken to restrict the fire and to remove the smoke to the extent determined by the use of the building, its size, and its height.

Some means of measuring performance is integral to these regulations, and a fire safety engineering approach may be the only feasible way of achieving a satisfactory standard of fire safety in some large and complex buildings.

It is obvious from these two examples that a performance-based code is possible. If it is to be applied properly, however, we must have the appropriate fire safety engineering and risk assessment tools to demonstrate that we have met the stated performance objectives.

Technology to support a performance-based code

Figure 1 shows the hierarchy of technology needed to support a performance-based building code. The two lower tiers of the triangle have, for the most part, been fulfilled over the past decades and form the basis of our prescriptive codes. Emerging engineering methods that are now being validated consist of such fire safety design tools as CFAST and EXITT, which allow one to calculate certain fire safety aspects, and more complex risk assessment methods that provide calculations on the overall risk of fire to occupants of buildings.⁷ Recall that code writers in both New Zealand and the United Kingdom stated the need for such engineering methods.

There are many other technical requirements for a performance-based code and for the fire safety engineering methods available to satisfy some of these requirements.⁸ Although the level of validation for a number of these methods is not yet sufficient to give many code officials confidence in their results, the validation process is ongoing internationally.

The overall fire risk assessment methods, such as those developed by the National Institute of Standards and Technology (NIST) for the National Fire Protection Research Foundation and the National Research Council of Canada (NRCC) risk-cost assessment model, are still being validated, as well. Indeed, the latter model is in an advanced stage of validation.^{9,10} These models hold the key to providing a sound technical basis for a performance-based code because they quantify risk to building occupants,

the very thing the codes are attempting to regulate. This quantification provides code officials with comparative results for new, innovative designs and materials, compared to the pre-established minimum safety level embodied in the existing code.

The tools needed to support a performance-based code are emerging. In fact, many are currently available for use. Coupled with the need for the tools, however, is the need to teach potential users in the design and code regulatory professions how to use them. Education is a key element in the development and success of performance-based codes.¹¹


Status in North America

Canada and the United States still have a long way to go before performance-based codes become a reality. A number of changes must be made in moving toward such codes, some of which will affect designers, code officials, and code developers.¹² There are other roadblocks, as well, and the cost of liability insurance and the potential for litigation are significant issues.¹³

Despite these difficulties, however, progress is being made. Over the past 20 years or so, a number of major efforts have been undertaken in the United States to develop credible performance criteria and measurement methods for fire safety in buildings.¹⁴

One notable achievement was the fire safety evaluation system (FSES) that NIST developed for NFPA 101, the Life Safety Code[®]. Currently incorporated in NFPA 101M, Manual on Alternative Approaches to Life Safety, the FSES methods provide, to a certain extent, a means of quantifying fire safety, in general. Based on a committee consensus approach, these FSES methods serve as significant stepping stones in the development of engineering tools capable of supporting performance-based codes. There has been little movement in the development of the codes themselves, however.

In Canada, two methodologies have been developed to support a performance-based code, both assuming risk as a basis.¹⁵ One of these, the risk-cost assessment model developed at the NRCC in cooperation with Victoria University of Technology in Australia, appears to be in a good position to support the development of a performance-based code. The Canadian provincial building code authorities support the move toward a performance-based code, and the NRCC's Institute for Research in Construction has identified this as a priority for future research.



Fire risk assessment models will provide a sound technical basis for a performance-based code because they quantify risk to building occupants, the very thing the codes are attempting to regulate.

Where do we go from here?

We in North America are poised on the edge of a major change in the way we develop, use, and enforce building codes. Performance-based codes are becoming a reality in other parts of the world, and those in North America are moving in that direction, as well. We are leaders in developing the engineering methods essential for using performance-based codes, and professionals from all fire safety disciplines are calling for action.

Despite the numerous difficulties that are bound to arise in using and enforcing a performance-based code, such codes have many advantages. They clarify the intent of our regulations, they provide economic benefits to construction, and they allow greater design freedom and the removal of nontariff trade barriers—all of which make them an attractive option.

An interim step in our drive to develop performance-based codes may be to make both a performance code and a specification code available and let the designer choose which one to use. This is similar to the "acceptable solutions" option provided in the regulations of both New Zealand and the United Kingdom.

After we gain experience with performance-based fire safety codes, we will no doubt find that a gradual move toward their exclusive use is inevitable. Remember, the structural and mechani-

cal engineering aspects of codes have been performance-based for approximately a century, and it is doubtful that those professions are going to move toward more specification-based requirements.

As a leader in the development of fire safety standards in North America, the NFPA is in a key position to affect the development of a performance-based fire safety code in North America. It is, therefore, appropriate that the NFPA become a key player in this undertaking. ♦

J.K. Richardson, P.E., is head of the National Fire Laboratory at the National Research Council of Canada's Institute for Research in Construction in Ottawa.

1. R.F. Ferguson, "The Development of a Knowledge-Based Building Code," *Technical Paper No. 426*, National Research Council of Canada, Ottawa, Canada, 1974.

2. "Strategies for Shaping the Future," *Proceedings of the Conference on Firesafety Design in the 21st Century*, Worcester Polytechnic Institute, Worcester, Mass., 1991.

3. A.H. Buchanan, "Fire Engineering for a Performance-Based Code," *Proceedings of the Sixth International Fire Conference—Interflam 93*, Interscience Communications Ltd., London, England, 1993, pp. 457-468.

4. *New Zealand Building Code Handbook*, Building Industry Authority, Wellington, New Zealand, 1992.

5. A.H. Buchanan, "Fire Engineering for a Performance-Based Code."

6. *The Building Regulations 1991*, Department of the Environment and the Welsh Office, HMSO, London, England, 1991.

7. R. Friedman, "An International Survey of Computer Models for Fire and Smoke," *Journal of Fire Protection Engineering*, Vol. 4, No. 3, 1992, pp. 81-92.

8. R. Bukowski, "Toward the Goal of a Performance Fire Code," *Proceedings of the International Fire Safety Engineering Conference: The Concept and the Tools*, CSIRO, Sydney, Australia, 1992.

9. R. Bukowski, F.B. Clarke, J.R. Hall, and S.W. Stiefel, *Fire Risk Assessment Method*, National Fire Protection Research Foundation, Quincy, Mass., 1990.

10. D. Yung and G.V. Hadjisophocleous, "The Use of the NRCC Risk-Cost Assessment Model to Apply for the Code Changes for 3-Story Apartment Buildings in Australia," *Proceedings of the Symposium on Computer Applications in Fire Protection Engineering*, Society of Fire Protection Engineers, Boston, Mass., 1993.

11. "Strategies for Shaping the Future," *Proceedings of the Conference on Firesafety Design in the 21st Century*.

12. J.K. Richardson, "Regulatory System Changes Needed to Gain Acceptance of Fire Safety Engineering Methods," *Proceedings of the SFPE Seminar on International Fire Protection Engineering Issues*, Society of Fire Protection Engineers, Boston, Mass., May 1993.

13. D. Schulman, "Money is the Main Reason Performance Codes Will Not Continue to Work," *Fire Journal*, Vol. 82, No. 1 (January/February 1988).

14. J.E. Snell, "Status of Performance Fire Codes in the U.S.A.," *Proceedings of the Nordic Conference on Fire Safety Engineering*, V.T.T., Helsinki, Finland, 1993.

15. J.K. Richardson, I. Oleszkiewicz, and D. Yung, "Toward a Performance-Based Code in Canada," *Proceedings of the Nordic Conference on Fire Safety Engineering*, V.T.T., Helsinki, Finland, 1993.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 30, 1992 ³

07/02/93
Discussed w/
Andy Fowell.
SW.

Dr. Andrew J. Fowell, Chief
Fire Science and Engineering Division
Building and Fire Research Laboratory
National Institute of Standards and Technology
Building 224, Room B250
Gaithersburg, Maryland 20899

Dear Dr. Fowell:

This letter provides the results of our final review of the opinions expressed by Dr. Vytenis Babrauskas in a letter to Pat Madden of July 30, 1992, regarding (1) the use of fire severity/fuel load concept by licensees in lieu of 1 hour or 3 hour fire resistance ratings to justify providing abbreviated fire endurance, and (2) determining the time period for which fire endurance is needed based on predicted sprinkler activation times. Dr. Babrauskas stated that these approaches are nonconservative and are not permitted by U.S. building codes for the design of normal commercial buildings.

The fire barriers in question are unique in their purpose, design, test acceptance criteria, and by the fact that they are specified in Nuclear Regulatory Commission (NRC) regulations as an acceptable approach for the separation of redundant safe shutdown trains located within fire-resistive structures. We have concluded that within the context of the NRC's overall reactor fire protection program, which relies on the defense-in-depth concept and NRC evaluation and approval of deviations from NRC requirements, using the two design approaches within the framework of the overall fire hazards analysis is acceptable. Our bases for this conclusion are presented below.

The NRC adheres to the application of a defense-in-depth concept of echelons of safety systems to achieve the high degree of safety required for nuclear power plants. This concept is also applicable to nuclear power plant fire safety. Therefore, the NRC and the licensees do not solely rely upon general building and construction standards. The defense-in-depth approach applied to the fire protection program is aimed towards achieving an adequate balance in: (1) preventing fires from starting; (2) detecting quickly, controlling, and extinguishing promptly those fire that occur; and (3) protecting structures, systems, and components so that a fire that is not promptly extinguished will not prevent the safe shutdown of the plant. The defense-in-depth principle states that strengthening any one of the three echelons can compensate for weaknesses in the others. The NRC's fire protection guidance implements this defense-in-depth approach and specifies a level of fire protection which considers the potential consequences that a fire may have on the safe shutdown of the reactor.

The NRC's fire protection regulation is Title 10 of the U.S. Code of Federal Regulations, Part 50, Section 50.48, "Fire protection," (10 CFR 50.48). Section 50.48 states that each operating reactor must have a fire protection program that satisfies General Design Criterion (GDC) 3, "Fire protection," of

Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50. The objective of the fire protection program is to minimize both the probability and consequences of fires.

Appendix R, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979," to 10 CFR Part 50 establishes fire protection features required to satisfy GDC 3. The Appendix R requirements of interest here are specified in Section III.G, "Fire protection of safe shutdown capability." The objective of Section III.G is to ensure that a means of achieving and maintaining safe shutdown conditions will be available after a nuclear power plant fire. When redundant trains of systems needed to achieve and maintain shutdown conditions are located in the same fire area, licensees can satisfy Section III.G by either (1) separating the redundant trains by a fire barrier having a 3-hour fire resistance rating, or (2) separating the redundant trains by more than 20 feet with no intervening combustibles or fire hazards and installing fire detectors and an automatic fire suppression system in the fire area, or (3) enclosing one of the redundant trains in a fire barrier having a 1-hour rating and installing fire detectors and an automatic fire suppression system in the fire area.

The fire barriers in question are unique in that they are required specifically by the NRC to separate redundant safe shutdown trains. The fire barriers are located within fire-resistive structures. They are not structural components nor are they installed to satisfy life safety or other typical building code objectives. The NRC fire protection requirements of interest here are focused on fire protection features needed to protect nuclear safety-related systems with emphasis on protecting the systems needed to perform shutdown functions in the event of a fire. Compliance with the NRC's fire protection requirements does not relieve a licensee from its responsibilities to satisfy fire protection requirements imposed by other authorities having jurisdiction over its plant. In addition, at this point, it is important to mention that reactor licensees cannot deviate from the NRC's fundamental regulatory requirement to provide either 1-hour or 3-hour rated fire barriers to separate redundant safe shutdown functions without prior NRC approval.

Guidance for implementing NRC fire protection requirements is contained in (1) Branch Technical Position Auxiliary and Power Conversion Systems Branch 9.5-1, "Guidelines for Fire Protection for Nuclear Power Plants," May 1976, (2) Appendix A to BTP APCS 9.5-1, "Guidelines for Fire Protection for Nuclear Power Plants Docketed Prior to July 1, 1976," August 23, 1976, and (3) Standard Review Plan (NUREG 0800), Section 9.5-1, "Guidelines for Fire Protection for Nuclear Power Plants," July 1981.

These documents provide information, staff recommendations, and guidance which may be used by the licensees to meet the requirements of 10 CFR 50.48, Appendix R, and GDC 3. These documents also refer the licensees to national consensus standards, such as American Society for Testing and Materials (ASTM) and National Fire Protection Association (NFPA) standards, for detailed guidance on implementing typical industrial fire protection features such as fire detectors, sprinkler systems, and building construction. Designs and methods different from the guidelines recommended in these documents can be

used by a licensee if the licensee provides suitable bases and justification for its alternative approaches and the staff concludes that adequate fire protection is provided by the alternative approaches.

Using the NRC guidance and applying the defense-in-depth concept, the licensees determine the fire protection features for plant safety systems and fire areas by analyzing the effects of the postulated fire relative to maintaining the ability to safely shut down the plant. The variables used to evaluate the level of fire protection needed in a given fire area extend well beyond fuel loads, calculated fire severities, and automatic suppression system actuation times. A full fire hazards analysis is performed by the licensee to demonstrate that the plant will maintain the ability to perform safe shutdown functions in the event of a fire. The licensee in the fire hazards analysis addresses the following attributes:

- The NRC fire protection requirements and guidance that apply.
- Fire loading and *in-situ* fire hazards.
- Automatic fire detection and suppression capability.
- Layout and configurations of safety trains.
- Reliance on fire barriers including, the quality of the materials and system, and the quality of the installation.
- Fire area construction (walls, floor, ceiling, dimensions, volume, ventilation, and congestion).
- Location and type of manual fire fighting equipment and accessibility for manual fire fighting.
- Potential disabling effects of fire suppression systems on shutdown capability.
- Availability of oxygen (for example, inerted containment).
- Amount of cable insulation and other combustible materials.
- Alternative or dedicated shutdown capability.

During reviews of licensee fire protection programs and subsequent inspections, the NRC evaluated these variables to ensure that each licensee provided an adequate level of protection. In addition, the NRC has granted licensee requests for exemptions from specific Appendix R requirements and has approved deviations from staff guidance. As discussed below, the staff performed safety evaluations and granted the exemptions and deviations based on fire hazards analyses performed by the licensees that demonstrated that an alternative approach provided an adequate level of fire protection.

When the fire hazards analysis shows that adequate fire protection can be provided by an alternative approach (i.e., an approach different from that

specified by NRC guidance such as the use of a 1-hour fire rated barrier where a 3-hour barrier is specified), the licensee may request NRC approval of a deviation from a specific NRC requirement or guideline. This request must demonstrate that the fire protection defense-in-depth is appropriately maintained. In order to maintain an adequate balance in the level of fire protection provided, the licensee may be required to install or improve automatic suppression and/or detection in the area of concern and or implement more restrictive fire prevention measures (e.g., improved controls over combustibles and ignition sources). This is not unlike the trade-offs and substitutions of alternate methods and materials allowed by commercial building codes used in the United States. The licensee must submit a technical justification for the alternative approach for NRC review and approval. Of the two analysis approaches questioned by Dr. Babrauskas, the analyses submitted with the justification typically includes fuel load and fire severity as one element. The licensees rarely propose to take credit for calculated or predicted sprinkler system actuation times. In addition to one or both of these elements, the analyses typically address the remaining elements of the fire hazards analysis. The NRC evaluates the deviations based on fire hazards analyses performed by the licensees to ensure that the alternative approach provides an adequate level of fire protection.

It is also important to note that this fire hazards analysis approach is consistent with that recommended in NFPA 803, "Standard for Fire Protection for Light Water Nuclear Power Plants." The standard recommends, in part, that the fire hazards analysis consider "the types of fires, based on the quantities of combustible materials, their estimated severity, intensity, duration, and the hazards created." The standard also recommends that for each fire reviewed that the total time involved be indicated in the fire hazards analysis.

In summary, the fire barriers in question are unique in their purpose, design, test acceptance criteria, and by the fact that they are required specifically by the NRC to separate redundant safe shutdown trains located within fire-resistive structures. The fire barriers are not structural components of a building nor are they installed to satisfy life safety or other model building code requirements. In addition, the level of fire resistance required, 1-hour or 3-hours, is specified by NRC regulation. Moreover, a licensee must obtain NRC approval before it can deviate from this regulation. In limited cases, the NRC has approved reduced fire resistance for specific barriers. However, such approvals were based on defense-in-depth designs. Fuel loads, calculated fire severities, and predicted suppression system actuation times are generally included with the licensees' technical justifications for reduced requirements and alternative approaches, but in and of themselves, these were not the only factors used by the licensees or the NRC for determining the acceptability of reduced fire resistance. We have concluded that within the context of the overall NRC reactor fire protection program, which relies on the defense-in-depth concept and NRC staff evaluation and approval of licensee proposed deviations from NRC requirements for using fire barriers to protect redundant safe shutdown trains, the use by licensees of the two design approaches questioned by Dr. Babrauskas, within the framework of their overall fire hazards analyses, is acceptable.

June 30, 1993

A copy of 10 CFR Part 50, Section 50.48, and General Design Criteria 3 are enclosed for your information. Copies of the other NRC documents referenced in this letter were previously provided to Dr. Babrauskas.

If you have any questions, please contact Steven West at 504-1220.

Sincerely,


Original signed by

Conrad E. McCracken, Chief
Plant Systems Branch
Division of Systems Safety and Analysis
Office of Nuclear Reactor Regulation

Enclosures:
As stated

Distribution
SPLB TSI File
Central File
JTaylor
TMurley
FMiraglia
WRussell
ATHadani
MVirgilio
CMcCracken
SWest
PMadden
DOudinot
DWilliams

*See previous concurrences.


SPLB:DSSA
PMadden
6/23/93
AT

SPLB:DSSA
SWest*
6/10/93

OAC:DRIL
JLee*
6/10/93

SPLB:DSSA
CMcCracken*
6/10/93

DD:DSSA
MVirgilio*
6/14/93

D:DSSA
ATHadani
6/23/93

[G:\THERMOLA\FOWELL.SW]

Industry Thermo-Lag Program

OBJECTIVE:

To re-establish the technical and licensing basis to qualify Thermo-Lag materials for use in one and three hour fire ratings as required by Appendix R

Thermo-Lag 330

- Predominant cable raceway fire barrier material used for Appendix R
- Large scope of installation:
 - 1 hour conduit: 69,000 linear feet
 - 1 hour cable trays: 16,000 linear feet
 - 3 hour conduit: 22,000 linear feet
 - 3 hour cable trays: 13,000 linear feet
- All previous tests declared indeterminate by NRC staff

Generic Fire Barrier Test Program

- Purpose:
 - Assess Thermo-Lag performance for representative plant cable raceway installations
 - » Baseline
 - » Upgrades using Thermo-Lag
 - » Upgrades using other materials

- Scope:
 - 13 test configurations
 - Phase 1 - six tests
 - Phase 2 - seven tests
 - Further tests may be undertaken

Phase 1 Test Results

- All Phase 1 tests were *upgrades* designed by TSI, using 330-1 material
- Phase 1 configurations exhibiting satisfactory performance
 - 1-hour rated conduits (3 sizes, steel and aluminum) and junction box
 - 3-hour rated straight run 24" steel cable tray
 - 3-hour rated junction box
 - 3-hour rated 3/4" conduit

Phase 1 Test Results (Continued)

- Phase 1 upgraded configurations with temperature exceedances in final 1 to 13 minutes of test, no cable damage observed
 - 3-hour rated 24" aluminum cable tray with "T" section
 - 3-hour rated wide span (36") steel cable tray
 - 1-hour rated wide span (36") steel cable tray
- Phase 1 upgraded configurations not demonstrating satisfactory performance:
 - 3-hour rated medium and large conduits
 - 3-hour rated air drop assembly

Phase 1 Test Results (Cont)

- “Limiting” baseline installations contributed to test results
 - Minimum material thickness
 - Minimum construction attributes
- Observed failure mechanisms considered in design of Phase 2 upgrades

Phase 2 Test Results

- Duration of satisfactory performance for one hour *non-upgraded* fire barriers:
 - 3/4" conduit 27 minutes
 - 2" conduit 39 minutes
 - 4" conduit 48 minutes
 - 6" conduit 50 minutes

 - 6" cable tray 48 minutes
 - 24" cable tray 21 minutes

 - Boxed conduits 60 minutes
(mounted to concrete)

Phase 2 Test Results (Cont)

- Duration of satisfactory performance for three hour *non-upgraded* fire barriers:
 - 3/4" conduit 63 minutes
 - 3" conduit 91 minutes
 - 6" conduit 102 minutes

 - 6" cable tray 85 minutes
 - 24" cable tray 85 minutes

Phase 2 Test Results (Cont)

- Upgraded one hour configurations providing satisfactory performance for full duration:
 - 3/4" conduit
 - 3" conduit
 - 6" conduit

 - 6" cable tray
 - 24" cable tray
 - 36" cable tray (with internal barrier supports)

 - Conduits in box enclosure mounted to concrete

Program Applicability

- Many parameters of installation have been shown through testing to affect Thermo-Lag performance
 - material thickness
 - pre grouting of joints
 - direction of structural ribs
 - internal panel supports
 - band or tie wire spacing
 - type of joints
 - unsupported span distance
 - support protection
 - cable fill
 - raceway mass
 - raceway dimensions
 - raceway material
 - others

Industry Application Guide

- Purpose:
 - Provide guidance for use of test results, comparison to installed configurations
 - Address installation parameters

- Intent:
 - Achieve agreement with NRC on content, provide final version to industry ASAP

Industry Application Guide


- Makes use of all generically applicable test data
 - TUEC
 - TVA
 - NUMARC Phase 1 and 2
- Addresses evolution of test/acceptance criteria
- Will be updated to reflect further applicable test results
- Addresses baseline and upgrade testing

Chronology

- Draft submitted to NRC on March 4
- NRC meeting to discuss March 16
- Draft provided to WG on March 25
- Draft provided to industry on April 13
- Discussed in detail at April 20-21 industry meeting
- NRC staff comments received April 7

Chronology (Cont)

- NEI response to NRC staff comments: May 18
- Final revision underway
 - Address NRC and WG comments
 - Incorporate Phase 2 test results
- Will provide final revision to NRC on June 17





*United States
Nuclear Regulatory Commission*

**Presentation to the
Advisory Committee on Reactor Safeguards**

**Proposed Amendment to the License Renewal Rule
(10 CFR Part 54)**

June 9, 1994

Table of Contents

- ◆ Background
- ◆ Approach to Rulemaking
- ◆ Objectives of License Renewal Rulemaking
- ◆ Retained in Proposed Revision
- ◆ Principal Changes
- ◆ Integrated Plant Assessment
- ◆ Time-limited Aging Analyses
- ◆ Standards for Issuance of a Renewed License
- ◆ Schedule

Background

- ◆ Final Part 54 effective January 1992
- ◆ Industry and NRC experience implementing the rule
- ◆ Senior NRC management review of issues
- ◆ September 1993 public workshop
- ◆ December 1993 staff recommendation to revise rule
- ◆ February 1994 Commission SRM to revise rule
- ◆ March 1994 public meeting with Nuclear Energy Institute (NEI)

Approach to Rulemaking

- ◆ SRM used to develop proposed rulemaking package --
retain *Principles of License Renewal*

- ◆ Steering Group and Working Group established to give priority attention to
this rulemaking.
 - Steering Group: NRR, RES, and OGC senior managers, and
Deputy EDO

 - Line Management

 - Working Group: NRR, RES, and OGC senior staff

Objectives of License Renewal Rulemaking

- | | |
|---------------------------------------|--|
| <i>Clarity</i> | ✓ Be clear on what is and what is not subject to review. |
| <i>Simplicity</i> | ✓ Simplify rule by not using terms like ARDUTLR, ITLR, SSCs, and by minimizing the use of definitions. |
| <i>Flexibility</i> | ✓ Allow applicant the flexibility to develop methodology for determining the review scope. |
| <i>Stability / Predictability</i> | ✓ Be straight forward and clear such that an applicant can make a timely decision whether to pursue license renewal. |

Retained in Proposed Revision

◆ Principles of License Renewal

- Regulatory process is adequate to ensure the current licensing basis (CLB) will continue to provide an acceptable level of safety --- with the possible exception of aging effects in the period of extended operation.
- The plant-specific CLB must be maintained during the period of extended operation.

Retained in Proposed Revision (cont'd)

- ◆ Integrated Plant Assessment (IPA)
 - Initial broad consideration of plant systems, structures, and components.
 - Quickly focuses review.

- ◆ Initial Scope of License Renewal.

- ◆ Review of Time-Limited Aging Analyses.

Principal Changes

- ◆ Focus on Aging Effects vs. Aging Mechanisms.
 - Performance and condition monitoring.

- ◆ Focus on Ensuring *Functionality*.
 - Regulatory process ensures all other CLB aspects.

- ◆ Eliminates the Term ARDUTLR
 - Other definitions also deleted.
 - Concept of ARDUTLR retained.

Principal Changes (cont'd)

◆ Definitions Deleted from Current Rule.

- ARDUTLR.
- Age-related degradation.
- Aging mechanisms.
- Effective Program.
- SSCs ITLR.

Principal Changes (cont'd)

- ◆ Narrowing the Focus of the Aging Management Review
 - Current rule results in unnecessarily broad review.
 - Proposed revision credits the effectiveness of the regulatory process and existing programs and activities as adequate for certain structures and components.
 - Resultant review focuses on
 - 1) Structures and components that are "passive," "long-lived," and "nonredundant" and
 - 2) Systems, structures and components that are subject to time-limited aging analysis.

Principal Changes (cont'd)

- ◆ Simplified Integrated Plant Assessment (IPA).
 - Deletes requirement to list *Systems, structures and components important to license renewal.*
 - Flexibility to develop methodology for identifying "passive," and "long-lived," and "nonredundant" structures and components.

- ◆ Reduced Information in Final Safety Analysis Report (FSAR) Supplement.
 - Proposed revision would require only a summary description.
 - Currently entire application submitted as FSAR supplement.

Principal Changes (cont'd)

- ◆ Reduced Reporting and Control Requirements.
 - Minimizes special requirements for license renewal.
 - Relies on existing regulatory process.
 - Approach for treating and controlling information is consistent with treatment of similar information during the current operating term.

§54.21(a) Integrated Plant Assessment

- ◆ "Identify and list those structures and components subject to an aging management review."
 - "Passive" and
 - "Long-lived" and
 - "Nonredundant"

"Passive"

- ◆ Term not used in proposed rule.
 - Extensive review of existing definitions and standards.
 - No one definition captured all the equipment judged to warrant review.
- ◆ Structures & components that "perform an intended function, without moving parts or without a change in configuration or properties."
 - "These structures & components include, but are not limited to, pressure retaining boundaries, component supports, reactor coolant pressure boundaries, the reactor vessel..."
 - "Excluding, but not limited to, pumps (except casing), valves (except body), motors, batteries, relays, breakers, and transistors"

"Long-lived"

- ◆ Term not used in proposed rule.

- ◆ Structures and components not subject to replacement by either:
 - Qualified service life, or
 - Specified time period.

"Nonredundant"

- ◆ Term not used in proposed rule.
- ◆ Structures and components "whose failure would result in loss of intended system or structure function as described in §54.4(b) during the period of extended operation."

§54.21(a) Integrated Plant Assessment (cont'd)

- ◆ "Describe and justify the methods used..."
- ◆ "Demonstrate that the effects of aging will be managed so that the intended function(s) will be maintained for the period of extended operation."

Time-limited Aging Analyses

- ◆ Definition in proposed rule.

- ◆ "[L]icensee calculations and analyses that form the basis for a licensee conclusion regarding the capability of systems, structures, and components within the scope of this part to perform their intended function(s) that --
 - (1) Consider the effects of aging; and
 - (2) Are based on explicit assumptions defined by the current operating term of the plant."

§54.21(c) Time-limited Aging Analyses

- ◆ Provide a list of time-limited aging analyses.

- ◆ Demonstrate that --
 - The analyses remain valid for the period of extended operation; or
 - The analyses have been projected to the end of the period of extended operation; or
 - The effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

§54.29 Standards for Issuance of a Renewed License

- ◆ "Actions ... have been or will be taken with respect to ---"
 - Structures and components subject to an aging management review, and
 - Systems, structures, and components subject to time-limited aging analyses.

- ◆ Not current term issues.

Schedule for Completing the Rulemaking

- ◆ Proposed amendment published for public comment. 07/94
(Environmental Assessment and Regulatory Analysis are also available for public comment)
- ◆ End of public comment period (90 days). 10/94
- ◆ Final rule to Commission for review and approval. 03/95

Will keep Steering Group / Working Group approach to meet the aggressive schedule for completing the final rule.