

DCS-MS-016

APR 15 1983

Docket No. 50-368

Mr. John M. Griffin
Vice President, Nuclear
Operations
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

DISTRIBUTION:

Docket File	JMTaylor
NRC PDR	ACRS-10
L PDR	RAClark
NSIC	PMKreutzer-3
ORB#3 Rdg	ETourigny
DEisenhut	Gray File
JHeltemes	ORAB
OELD	PShemanski
ELJordan	RLee

Dear Mr. Griffin:

SUBJECT: SAFETY EVALUATION FOR ENVIRONMENTAL QUALIFICATION OF
SAFETY-RELATED ELECTRICAL EQUIPMENT

RE: Arkansas Nuclear One - Unit 2

This letter transmits the Safety Evaluation with attached Technical Evaluation Report (TER) for the Environmental Qualification of Safety-Related Electrical Equipment at your facility. This evaluation is based on your response to our previous Safety Evaluation, dated September 14, 1981 and subsequent submittals dated July 29 and August 13, 1982. The Safety Evaluation presents the results of the Environmental Qualification Review for safety-related electrical equipment, exposed to a harsh environment, in accordance with NRC requirements. You should provide to us by May 20, 1983, your plans for qualification or replacement of the equipment in NRC Categories I.B, II.A, II.B and IV as applicable to your plant (presented in the Technical Evaluation Report) in addition to the justification for continued operation (JCO) required in the near term, and the schedule for accomplishing your proposed corrective actions in accordance with the Equipment Qualification rule (10 CFR 50.49(g) issued on January 21, 1983, Federal Register Volume 48, No. 15, PP 2729-2734).

As indicated in the conclusion section of the Safety Evaluation, we request that you reaffirm the justification for continued operation and within thirty (30) days of receipt of this letter, submit information for items in NRC Categories I.B, II.A and IV (presented in the attached Technical Evaluation Report) for which justification for continued operation was not previously submitted to the NRC. In addition, for items in NRC Category II.B, justification for continued operation, if not previously provided, is to be provided within ten (10) days of receipt of this letter. Should issues or conflicts exist which prohibit a response in a timely manner, a 10 CFR Part 50.54(f) letter will be issued. Guidelines set forth in paragraph (i) of 10 CFR 50.49 should be considered in your justification for continued operation for your facility.

Upon completion of the plant specific review for all plants, a cross-reference of non-qualified equipment existing in any plant will be conducted by the NRC staff to determine if the same equipment exists on other plants and has been declared qualified. Should the cross-reference indicate that they do exist in your plant, the staff will contact you to reconfirm the qualification of these items for your plant.

8304260082 830415
PDR ADDCK 05000368
PDR

OFFICE
SURNAME
DATE

Appendix D of the TER provides a technical review of your statements regarding the justification for continued operation (JCO) that was submitted in the 90-day response to an earlier staff safety evaluation (published in mid-1981). Appendix D is not necessarily applicable to the deficiencies identified in the TER. You should review all JCOs provided to date to ensure that a JCO exists for all equipment which may not be qualified.

As a separate action to your response to this letter, the Commission has promulgated an Equipment Qualification rule which in Paragraph (g) of the rule requires that by May 20, 1983, licensees identify electrical equipment important to safety within the scope of the rule that is already qualified, and submit a schedule for the qualification or replacement of the remaining electric equipment within the scope of the rule in accordance with the qualification deadline specified in paragraph (g). The submittal required by the rule should specifically indicate whether your previous submittals comply with paragraphs (a) and (b) of 10 CFR 50.49. In addition, you are requested to discuss the methods used to identify the equipment covered by paragraph 10 CFR 50.49(b)(2) and to establish any qualification programs not previously described for such equipment. This rule specifies the requirements the staff intends to use in resolving the EQ program.

The Technical Evaluation Report contains certain identified information which you have previously claimed to be proprietary. We request that you inform us as indicated in the proprietary review section of the Safety Evaluation whether any portions of the identified pages still require proprietary protection. It should be noted that the NRC's policy on proprietary information, as specified in SECY 81-119, is that summary data on equipment qualification testing will not be treated as proprietary by the NRC. This information shall be submitted within thirty (30) days of receipt of this letter. A general guideline is enclosed.

Questions regarding the enclosed SE and attached TER, especially the findings and actions required, should be directed through the NRC Project Manager for AND-2.

Sincerely,

Original signed by
Robert A. Clark

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosures:

1. Safety Evaluation with attached FRC TER
2. Proprietary Review Guidelines

cc w/o Proprietary FRC
TER: See next page

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORAB	ORB#3:DL		
SURNAME	PMK Reutzer	E. Tourigny/p	R. Lee	T. Polito	R. A. Clark		
DATE	4/1/83	4/12/83	4/13/83	4/14/83	4/15/83		

Arkansas Power & Light Company

cc:

Mr. John Marshall
Manager, Licensing
Arkansas Power & Light Company
P. O. Box 551
Little Rock, Arkansas 72203

Mr. James M. Levine
General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220
7910 Woodmont Avenue
Bethesda, Maryland 20814

Nicholas S. Reynolds, Esq.
c/o DeBevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Charles B. Brinkman
Manager - Washington Nuclear
Operations
C-E Power Systems
7910 Woodmont Avenue
Bethesda, Maryland 20814

Regional Administrator
Nuclear Regulatory Commission, Region IV
Office of Executive Director for Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. J. Callan
U.S. NRC
P. O. Box 2090
Russellville, Arkansas 72801

U.S. Environmental Protection Agency
Region VI Office
ATTN: Regional Radiation
Representative
1201 Elm Street
Dallas, Texas 75270

Mr. Frank Wilson
Director, Division of Environmental
Health Protection
Arkansas Department of Health
4815 West Markmar Street
Little Rock, Arkansas 72201