





Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 2 - 82 - 71  
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION  
CRD N-10 (50-39) Uncoupled  
OCCURRED 9/30/82 0515  
DATE TIME

SYSTEM AFFECTED 300 PLANT STATUS AT TIME OF EVENT  
CRD MODE S/U, PWR(MWT) 10, LOAD(MWE) 0 TESTING YES NO

DESCRIPTION OF EVENT  
During startup, control rod N-10 was found to be uncoupled. The CRD was inserted to position "00" and electrically disarmed.

EQUIPMENT FAILURE N/A  
10 CFR50.72 NRC RED PHONE NOTIFICATION MADE YES NO  
RESponsible SUPERVISOR Gary L. Smith DATE 9/30/82

PART 2 OPERATING ENGINEER'S COMMENTS  
Drive was recoupled at greater than 20 percent power and will be overhauled during the next refueling outage.

EVENT OF PUBLIC INTEREST  
TECH. SPEC. VIOLATION  
NON REPORTABLE OCCURRENCE  
14 DAY REPORTABLE/T.S.  
30 DAY REPORTABLE/T.S. 6.6.B.2.b  
ANNUAL/SPECL REPORT REQ'D  
24-HOUR NRC NOTIFICATION REQ'D  
TELEPH Tom Tongue (courtesy) 9/30/82 0800  
TELEGM/TELECOPY N/A  
CECO CORPORATE NOTIFICATION MADE  
5-DAY WRITTEN REPORT REQ'D PER 10CFR21  
Telecopy Dennis P. Galle 10/4/82 0822  
CECO CORPORATE OFFICER

PRELIMINARY REPORT COMPLETED AND REVIEWED John M. Almer 10/1/82  
OPERATING ENGINEER DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW  
J Brunner 10/13/82  
John M. Almer 10/14/82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION  
Douglas Post 10/14/82  
STATION SUPERINTENDENT DATE