

October 18, 1982

DISTRIBUTION

Docket WPaulson
 NRC PDR ORB Reading
 Local PDR ELJordan
 NSIC JMTaylor
 DCrutchfield
 HSmith LJHarmon(2)
 REmch
 OELD
~~XXXXXXXX~~
 ACRS (10)
 RDiggs
 LSchneider
 TBarnhart(4)
 SEPB
 FMiraglia
 MFairfile

Docket No. 50-155
LS05-82-10-063

Mr. David J. Vandewalle
Nuclear Licensing Administrator
Consumers Power Company
1945 W. Parnall Road
Jackson, Michigan 49201

Dear Mr. Vandewalle:

SUBJECT: BIG ROCK POINT - TMI ITEM II.F.1(3) HIGH RANGE RADIATION
MONITOR AND CONTAINMENT LEAK TESTING INTERVAL

The Commission has issued the enclosed Amendment No. 54 to Facility Operating License No. DPR-6 for the Big Rock Point Plant. This amendment consists of changes to the Technical Specifications in response to your requests dated December 15, 1981 and January 7, 1980.

The amendment approves Technical Specification changes which pertain to (1) the containment high-radiation monitor required by TMI Item II.F.1(3), "Additional Accident Monitoring Instrumentation, Containment High-Range Radiation Monitor," and (2) the testing interval for Appendix J Type B and C leak tests.

The changes pertaining to the radiation monitor have been revised slightly over the changes proposed by Consumers Power Company. These revisions have been mutually agreed to by us and your staff.

Copies of our Safety Evaluation Report in support of this amendment and the Notice of Issuance are also enclosed.

Sincerely,

Original signed by
Dennis M. Crutchfield

Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
Division of Licensing

8210250323p

Enclosures:

1. Amendment No. 54 to License No. DPR-6
2. Safety Evaluation
3. Notice of Issuance

SEOI

ASU USE EX(18)

AMDT + FR
NOTICE

OFFICE	cc w/enclosures: See next page	DL:ORB#5	DL:ORB#5	OELD <i>cyb</i>	DL:ORB#5	DL:ORB#5
SURNAME		HSmith:ais	REmch <i>RLE</i>	R.Bachmann	DCrutchfield	FMiraglia
DATE		10/4/82	10/4/82	10/5/82	10/16/82	10/4/82