

Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201
Telephone (205) 868-5131



Dave Morey
Vice President
Farley Project

Southern Nuclear Operating Company

the southern electric system

June 9, 1994

10 CFR 50.90

Docket No.: 50-364

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Joseph M. Farley Nuclear Plant Unit 2
Amendment No. 99 Technical Specifications Page Correction

Ladies and Gentlemen:

Amendment Nos. 104 and 97 to the Farley Unit 1 and Unit 2 Technical Specifications were issued December 29, 1994. These amendments changed the Technical Specifications to allow elimination of the steam/feedwater flow mismatch reactor trip (Table 4.3-1, Functional Unit No. 14). The amendments were to be implemented upon completion of necessary design modifications following each unit's next refueling outage. Subsequently, Amendment Nos. 106 and 99 (Units 1 and 2, respectively,) were issued May 16, 1994. These Technical Specifications amendments changed the surveillance test intervals and allowed outage times for the Reactor Trip System and Engineered Safety Features Actuation System which affected Table 4.3-1. At the time Amendment Nos. 106 and 99 were issued, the plant modification to eliminate the steam/feedwater flow mismatch reactor trip had been completed on Unit 1, but had not been completed for Unit 2. (The Unit 2 modification is scheduled for the spring 1995 refueling outage.) Due to the timing of the design change modifications and the issuance of the two amendments for each unit, Page 3/4 3-13 must be corrected to reflect deletion of the steam/feedwater flow mismatch on Amendment Nos. 106 and 99. The updated page for the Unit 2 Technical Specifications is attached to this letter. The updated Unit 1 page was provided by Southern Nuclear to the NRC by letter dated June 3, 1994.


The updated page provided with this letter is purely an editorial change not subject to 10 CFR 50.90 since Unit 2 Amendment Nos. 97 and 99 have both been approved under this process.

9406150197 940609
PDR ADOCK 05000364
PDR

Adol
1/1

If you have any questions, please advise.

Respectfully submitted,



Dave Morey

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 9th DAY OF June 1994

Martha Gayle Dow
Notary Public

My Commission Expires: 11/01/97

Attachment

BLM/elt.rstst2.doc

cc: Mr. S. D. Ebner
Mr. B. L. Siegel
Mr. T. M. Ross
Dr. D. E. Williamson