

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | F | L | S | L | S | 1 | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T
 01 | L | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 5 | 0 | 3 | 2 | 2 | 8 | 3 | 0 | 4 | 1 | 9 | 8 | 3 | 3
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While shutdown for refueling LPSI pump 1B breaker was being "slow closed"
 03 | for an alignment check when the closing latch pin broke. This rendered
 04 | the breaker incapable of closing. St. Lucie Unit 1 has approximately 50
 05 | breakers of this type and in over 7 years of operation this is the first
 06 | failure of this type. There was no adverse effect on the health or
 07 | safety of the public.

09 | S | F | E | B | C | K | T | B | R | K | A | Z | 8 | 3 | 0 | 2 | 0 | 0 | 3 | L | 0 | A | Z | W | 1 | 2 | 0 | 1
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 LE/R/O REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED APPROX. FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The breaker involved in this event was a Westinghouse Porcel-line air
 11 | circuit breaker model 50DHP250. The pins from two identical breakers on
 12 | the same bus were removed and ultrasonically and dyepenetrant tested with
 13 | no indication of degradation. Because of the absence of previous failures
 14 | and the above test results, this event is considered a random failure.

15 | H | 0 | 0 | 0 | 0 | NA | B | PREVENTATIVE MAINTENANCE
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 PERSONNEL INJURIES NUMBER DESCRIPTION
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 PUBLICITY ISSUED DESCRIPTION
 NRC USE ONLY

NAME OF PREPARER: G. E. Walling

PHONE: 305/465-3550 x3427