



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

October 15, 1982
(82-573)

Mr. R. W. Starostecki, Director
U. S. Nuclear Regulatory Commission
Region 1
Division of Resident and Project Inspection
631 Park Avenue
King of Prussia, PA 19406

RE: Nine Mile Point Unit 2
Docket No. 50-410


Dear Mr. Starostecki:

Enclosed is an interim 30-day report in accordance with 10CFR50.55(e) for the potential deficiency regarding environmental and/or seismic qualification documentation of certain control room equipment.

This condition was reported by telephone to Mr. W. Baunack of your staff on September 21, 1982 as a potentially reportable deficiency.

Very truly yours,

Niagara Mohawk Power Corporation


S. F. Manno
Vice President
Nuclear Construction

SFM:TL:bjs
Enclosure

xc: R. D. Schulz, Resident Inspector

82102503785

1E27

DESCRIPTION OF DEFICIENCY

A recent NMPC QA inspection indicated that sufficient environmental and/or seismic qualification documentation did not exist for certain control room equipment. The control room equipment includes:

GE Type 185 Position Indicator	(Environmental & Seismic)
Eagle Signal Multipulse Timer	(Environmental & Seismic)
GE Type CR2820B Relay	(Environmental)
Eagle Signal Cycle Flex Timer	(Seismic)
GE CR105D Contactor	(Environmental)
Cutler Hammer Type 10250T Control Switch	(Environmental)
Master Specialties Switch & Light Unit	(Seismic)
Bailey Type 701 Controller	(Environmental)
Bailey Type 701 Square Root Extractor	(Environmental)
Bailey Type 701 Summer	(Environmental)
Bailey Type 701 Alarm Unit	(Environmental)
Bailey Type 701 Flow Controller	(Environmental)
Leeds & Northrup Speedomax Mark III Recorder	(Environmental & Seismic)
GE Vertical Meter Type 185	(Environmental)
Riley Temperature Switch	(Environmental)
Automatic Electric Series BQA Relay	(Environmental & Seismic)
GE Range Switch	(Environmental)

General Electric has been requested to provide the sufficient documentation. A final report will be submitted by December 31, 1982.